



Portland Fire Department

3/13/2019

OLIVER BRADSHAW
PO BOX 1538
SCARBOROUGH, ME 04070
ocbradshaw@aol.com

CERTIFIED MAIL

RE: 39 KELLOGG ST
PORTLAND, ME

017 E023001

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 2/14/2019 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 4/18/2019 10:30:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-31.2.2.1	1-hour fire rated doors and assemblies required, including self-closing and self-latching mechanisms.	Basement door is on order will be installed upon arrival.	3/15/2019
NFPA 101-31.3.4.5; City Code 10-3(i)	Photoelectric, hardwired with battery backup smoke alarms must be provided in every sleeping room, outside every sleeping area, and on every level, including the basement.	IMMEDIATELY install temporary alarms where required. Fully compliant, permanent alarms must be installed by the date given.	3/15/2019
City Code 10-3(l)	Hardwired with battery backup Carbon Monoxide alarms are required in each unit, and on each level, including basements.	Immediately install temporary CO alarms where required. Fully compliant, permanent alarms must be installed by the date given.	3/15/2019
NFPA 101-24.3.4.1; City Code 10-3(i)	Photoelectric smoke alarms must be provided in every sleeping room, outside each sleeping area, and on every level, including the basement. Smoke alarms must be hardwired with battery backup or 10-year sealed lithium battery alarms.	3rd floor unit	7/4/2017
City Code 10-3(l)	Photoelectric, hardwired with battery backup Carbon Monoxide alarms are required in each unit, and on each level, including basements.	IMMEDIATELY install temporary CO alarms where required. Fully compliant, permanent alarms must be installed by the date given. All units	7/27/2017