Scale: ½” = 1’

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/16/15

FORTE

MEMBER REPORT *Level, Floor: Flush Beam*

2 piece(s) 1 3/4" x 7 1/4" 2.0E Microllam® LVL

Overall Length: 9' 7.00"

RESURGAM CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 09/16/15

All locations are measured from the outside face of left support (or left cantilever end). All dimensions are horizontal.

Design Results	Actual @ Location	Allowed	Result	LDF	Load: Combination (Pattern)
Member Reaction (lbs)	2370 @ 2.00"	4961 (3.50")	Passed (48%)	--	1.0 D + 1.0 S (All Spans)
Shear (lbs)	1927 @ 10.75"	5544	Passed (35%)	1.15	1.0 D + 1.0 S (All Spans)
Moment (Ft-lbs)	5289 @ 4' 9.50"	8182	Passed (65%)	1.15	1.0 D + 1.0 S (All Spans)
Live Load Defl. (in)	0.308 @ 4' 9.50"	0.308	Passed (L/360)	--	1.0 D + 1.0 S (All Spans)
Total Load Defl. (in)	0.390 @ 4' 9.50"	0.463	Passed (L/284)	--	1.0 D + 1.0 S (All Spans)

System : Floor
Member Type : Flush Beam
Building Use : Residential
Building Code : IBC
Design Methodology : ASD

- Deflection criteria: LL (L/360) and TL (L/240).
- Bracing (Lu): All compression edges (top and bottom) must be braced at 9' 7.00" o/c unless detailed otherwise. Proper attachment and positioning of lateral bracing is required to achieve member stability.

Supports	Bearing Length			Loads to Supports (lbs)			Accessories
	Total	Available	Required	Dead	Snow	Total	
1 - Stud wall - HF	3.50"	3.50"	1.67"	501	1869	2370	Blocking
2 - Stud wall - HF	3.50"	3.50"	1.67"	501	1869	2370	Blocking

- Blocking Panels are assumed to carry no loads applied directly above them and the full load is applied to the member being designed.

Loads	Location	Tributary Width	Dead (0.90)	Snow (1.15)	Comments
1 - Uniform (PSF)	0 to 9' 7.00"	6' 6.00"	15.0	60.0	ROOF LOAD

Weyerhaeuser Notes

Weyerhaeuser warrants that the sizing of its products will be in accordance with Weyerhaeuser product design criteria and published design values. Weyerhaeuser expressly disclaims any other warranties related to the software. Refer to current Weyerhaeuser literature for installation details. (www.woodbywy.com) Accessories (Rim Board, Blocking Panels and Squash Blocks) are not designed by this software. Use of this software is not intended to circumvent the need for a design professional as determined by the authority having jurisdiction. The designer of record, builder or framer is responsible to assure that this calculation is compatible with the overall project. Products manufactured at Weyerhaeuser facilities are third-party certified to sustainable forestry standards.

The product application, input design loads, dimensions and support information have been provided by Forte Software Operator

SUSTAINABLE FORESTRY INITIATIVE