



CITY OF PORTLAND

**Inspection Services
389 Congress Street, Room 315
Portland, ME 04101
(207)874-8300
Fax: (207)874-8716**

Fax Transmission Cover Sheet

Date: 6/10/99

To: LINDA MATTISON, Cmp

Fax #: 791-8000

Re: 7 Kellogg STREET, DAVID C. DRISKELL

From: MICHAEL A. COLLINS

Phone#: 874-8694

*You should receive 2 page(s), including this cover sheet. If
you do not receive all the pages, please call (207)874-8693.
Thank you!*

Inspection Services
Michael Collins,
Electrical Inspector



Department of Urban Development
Joseph E. Gray, Jr.
Director

CITY OF PORTLAND

6/10/99

Linda Mattison
Central Maine Power
162 Canco Road
Portland, ME 04103
Fax number: 791-8000

RE: 7 KELLOGG STREET; DAVID C. DRISKELL
CBL: 017-E-032

Dear Ms. Mattison;

At this time I am ordering immediate disconnection of electrical services to the above-mentioned address, due to electrical hazards which present a clear and present danger to the building and its occupants. This order shall remain in affect until further notice.

Sincerely,

Michael A. Collins
Chief Electrical Inspector
City of Portland

City of Portland

Planning and Urban Development

Joseph E. Gray Jr.

Director

Owner/Manager
Driskell David C &
4206 Decatur St
Hyattsville, MD 20781

Inspection Type: **Housing**
Date: **Wed, Jun-2-1999**
Time: **1:45 PM**
Status:
Re-inspect By: **Saturday, July 03, 1999**
Reason For Re-inspection:
Note

Address: **7 Kellogg St**
Parcel ID: **017- E-03200101**
Units:
Inspector: **David Caddell**

	Compliance ?	Code	Int/Ext	Floor	Apt/Unit No	Location	Description of Violation	Repair Code
1.	<input type="checkbox"/>	6-108.4	Exterior			entry	Stairway & Porch In Disrepair	
2.	<input type="checkbox"/>	6-113.5	Interior	1st		Kitchen	Loose Ceiling Fixture	
3.	<input type="checkbox"/>	6-116.5	Interior	throughout		smoke detectors	No Hard Wired Smoke Detectors	
4.	<input type="checkbox"/>	6-113.5	Interior	2nd		Throughout	Exposed Wiring, Damaged Switches & Receptacles	
5.	<input type="checkbox"/>	6-109.5	Interior			Throughout	Rodent Infestation/ Interior & Exterior	

Code Enforcement Officer