



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

June 4, 1985

Mr. Raymond Auger
13 Deering Street
Portland, Maine 04101

Re: 87 Monument Street, 2nd. Fl.,
Portland, Maine 04101


Dear Mr. Auger:


We recently received a complaint and an inspection was made by Code Enforcement Officer Marland Wing of the property owned by you at 87 Monument Street, 2nd. Fl., Portland, Maine. As a result of the inspection, you are hereby ordered to correct the following substandard housing conditions:

1. OVERALL - windows - loose glass. 108-3
2. LIVING ROOM - window - broken. 108-3
3. BATHROOM - ceiling - illegal wiring. 113
4. KITCHEN - ceiling - peeling paint. 108-2
5. LIVING ROOM - floor - illegal extension cord. 113
6. OVERALL - windows - missing counterbalance cords. 108-3
- *7. FRONT BEDROOM - ceiling - frayed wiring-light fixture. 113
8. OVERALL - windows - loose sashes. 108-3

The above mentioned conditions are in violation of Article V of the Municipal Code of the City of Portland, Maine, and must be corrected on or before July 1, 1985. Failure to comply with this order may result in a complaint being filed for prosecution in District Court.

Sincerely yours,
Joseph F. Gray, Jr. Director of
Planning & Urban Development

By 
P. Samuel Hoff
Chief of Inspections


Code Enforcement Officer - M. Wing (1)

jmr