

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

DURRELL TERRY D & MARK D ROGERS JTS

**Located at**

25 SHERIDAN ST

**PERMIT ID:** 2017-00436

**ISSUE DATE:** 06/22/2017

**CBL:** 017 F019001

has permission to **Replace 2nd floor drywall, flooring, and electrical wiring.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.	A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	---

*/s/ Jason Grant*

*/s/ Laurie Leader*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Three dwelling units

***Building Inspections***

**Use Group:** R-2

**Type:** 5B

Three dwelling units

SECOND FLOOR

MUBEC/IBC 2009

***Fire Department***

**Classification:**

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status of Permit or Schedule an Inspection at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

### **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping

Above Ceiling Inspection

Electrical Close-in w/Fire & Draftstopping

Final - Electric

Final - Fire

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2017-00436	<b>Date Applied For:</b> 04/05/2017	<b>CBL:</b> 017 F019001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same: 3 dwelling units		<b>Proposed Project Description:</b> Replace 2nd floor drywall, flooring, and electrical wiring.		
<hr/>				
<b>Dept:</b> Zoning	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Christina Stacey	<b>Approval Date:</b> 04/07/2017	<b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
<ol style="list-style-type: none"> <li>1) This property shall remain three dwelling units. Any change of use shall require a separate permit application for review and approval.</li> <li>2) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only.</li> <li>3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li> </ol>				
<hr/>				
<b>Dept:</b> Building Inspecti	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Laurie Leader	<b>Approval Date:</b> 05/11/2017	<b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
<ol style="list-style-type: none"> <li>1) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings undergoing alterations, hard wired to the electrical system. Interconnection is required, where permanent wiring is feasible, which shall be verified upon inspection.</li> <li>2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.</li> <li>3) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.</li> <li>4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.</li> </ol>				
<hr/>				
<b>Dept:</b> Fire	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Jason Grant	<b>Approval Date:</b> 06/22/2017	<b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/>
<b>Conditions:</b>				
<ol style="list-style-type: none"> <li>2) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas. <ol style="list-style-type: none"> <li>1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas</li> <li>2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.</li> </ol> </li> <li>3) City of Portland Code Chapter 10 section 10-3 (i) all new smoke alarm must use photoelectric technology. In existing apartment building smoke detectors must be the buildings electrical service and must have a secondary power source (battery). Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations <ol style="list-style-type: none"> <li>1. Inside all sleeping rooms.</li> <li>2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas</li> <li>3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.</li> </ol> In new construction per NFPA 101 2009 section 9.6.2.10.3 where 2 or more smoke detectors are required within a dwelling unit they shall be arranged so that the operation of any smoke alarm shall cause the alarm of all smoke alarms within the dwelling unit. </li> </ol>				

- 4) All penetrations for cables, cable trays, conduits, pipes, tubes, vents, ducts, wires and similar items that pass through or penetrate a fire rated wall ceiling or floor assembly shall be protected and sealed by a listed firestop system and installed to comply with the systems manufactures recommendation.
- 5) All construction shall comply with City Code, Chapter 10.  
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters  
All construction shall comply with 2009 NFPA 1, Fire Code.  
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).  
All means of egress to remain accessible at all times.  
If applicable, all outstanding code violations shall be corrected prior to final inspection.