

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0035	Issue Date: JAN 26 2006	BL: 017 F020001
-----------------------	----------------------------	--------------------

Location of Construction: 21 SHERIDAN ST	Owner Name: 145 NEWBURY STREET ASSOCI	Owner Address: 145 NEWBURY ST	Phone: 207 774 849
---	--	----------------------------------	-----------------------

Business Name:	Contractor Name: Waynes Plumbing and Heating	Contractor Address: 158 St. John St Portland	Phone: 207 774 849
----------------	---	---	-----------------------

Lessee/Buyer's Name	Phone:	Permit Type:	Zone: R-6
---------------------	--------	--------------	--------------

Past Use: 3 Unit Residential	Proposed Use: 3 Unit Residential/ install Trinity Ti Wall hung boiler in back storage area	Permit Fee: \$120.00	Cost of Work: \$10,500.00	CEO District: 1
---------------------------------	---	-------------------------	------------------------------	--------------------

FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied TO NFPA 54	INSPECTION: Use Group: U Type: State Gas Regs Signature: Greg Cass
---	---

Proposed Project Description:
install Trinity Ti Wall hung boiler in back storage area

Signature: *[Signature]* Date: _____

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)

Action: Approved Approved w/Conditions Denied

Permit Taken By: Idobson	Date Applied For: 01/06/2006	Zoning Approval	
-----------------------------	---------------------------------	------------------------	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: 1/25/06	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: 1/25/06
---	---	---	--

CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK. TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 31-23 Sheridan St Port Use of Building Res Date 1/5/05

Name and address of owner of appliance Ed Gardner 80 Caprice St Portland

Installer's name and address Waynes Plumbing 158 St John St Port

Telephone 8281394

Location of appliance:

- Basement Floor
- Attic Roof

Back Storage Area wall hung

Type of Fuel:

- Gas Oil Solid

Appliance Name: Trinity Ti

U.I. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PAT 130
- Other _____

Type of Chimney:

- Masonry Lined
Factory built _____

- Metal
Factory Built U.L. Listing # _____

- Direct Vent
Type pvc UL# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank NA

Number of Tanks NA

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ 3500.00 x 3 ^{unit} _{1,2,3}

Permit Fee: \$ 120⁰⁰/100

Approved

Fire: _____

Ele.: _____

Bldg.: _____

Approved with Conditions

- See attached letter or requirement

Inspector's Signature _____

Date Approved _____

Signature of Installer [Signature]

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0035	Date Applied For: 01/06/2006	CBL: 017 F020001
------------------------------	--	----------------------------

Location of Construction: 21 SHERIDAN ST	Owner Name: 145 NEWBURY STREET ASSOCI	Owner Address: 145 NEWBURY ST	Phone:
Business Name:	Contractor Name: Waynes Plumbing and Heating	Contractor Address: 158 St. John St Portland	Phone (207) 774-7849
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: 3 Unit Residential1 install Trinity Ti Wall hung boiler in back storage area	Proposed Project Description: install Trinity Ti Wall hung boiler in back storage area
--	--

Dept: Zoning **Status:** Approved **Reviewer:** Tammy Munson **Approval Date:** 01/25/2006
Note: **Ok to Issue:**

Dept: Building **Status:** Approved with Conditions **Reviewer:** Tammy Munson **Approval Date:** 01/25/2005
Note: **Ok to Issue:**

1) The installation must comply with the State of Maine Gas Regulations.

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 01/09/2006
Note: **Ok to Issue:**

1) Install to comply with NFPA 54 and as designed.