


**NOTES:**

1. MINIMUM SLOPE FOR ALL SANITARY SEWER SERVICES SHALL BE  $\frac{1}{4}$ "/FT
2. MINIMUM SLOPE FOR ALL STORM DRAIN SERVICES SHALL BE 0.005
3. REFER TO SECTION II, FIGURE II-19 OF THE CITY OF PORTLAND, MAINE TECHNICAL AND DESIGN STANDARDS AND GUIDELINES FOR WYE CONNECTION DETAIL
4. UTILITY SERVICES SHALL BE CAPPED 3' FROM R.O.W. AND FIELD STAKED. 2X4 STAKE TO BE CUT OFF 6" BELOW FINISH GRADE WITH 16D NAIL DRIVEN IN END/TOP



**WOODARD & CURRAN**  
 Engineering • Science • Operations  
 41 Hutchins Drive - Portland, Maine 04102  
 DESIGN BY: JBC/NTD/CHECK BY: DAS DATE: 08/03/2006

STATE OF MAINE  
 DEPARTMENT OF TRANSPORTATION

OCEAN GATEWAY PHASE 1

CUMBERLAND COUNTY

CITY OF PORTLAND

CUMBERLAND COUNTY

PROJECT NUMBER: MH-9215(500)X, NH-9215(600)X, & STP-9215(700)X  
 PIN NUMBER: 9215.50, 9215.60, & 9215.70

LONGFELLOW UTILITY SERVICES  
 HANCOCK STREET

SK-C008