H.B. FLEMING, INC.

CONTRACTING · ENGINEERING

89 Pleasant Ave. South Portland, ME 04106

Phone 207-799-8514 Fax 207-799-8538

www.hbfleming.com

AGCMAINE

PDC PILE DRIVING CONTRACTORS ASSO

CITY OF PORTLAND, MAINE — RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/27/17

PILE DRIVING BRIDGES SUBMARINE PIPELINES

Summit Geoengineering Services
145 Lisbon St., Suite 701
Lewiston, ME 04240

10/27/2017

Re: WEX Foundation Piles

Attn: Bill Peterlein

Dear Bill,

We are writing to confirm that we considered corrosion loss when evaluating HP10x42 piles sections for the WEX project. Corrosion loss was considered at a rate of 0.001" per year.

We are also writing to confirm that two high-strain dynamic loads tests were performed on selected test piles.

Please forward this information for review by the project architects and other reviewing parties. Please contact us if you need any additional information.

Thank You,

David Gifford

H.B. Fleming. Inc.

STATE OF MAINE
DAVID RAYMOND GIFFORD
No. 11284
LICENSED PROFESSIONAL ENGINEER

10/27/17