STANDARD MOUNTING HEIGHTS FOR MISCELLANEOUS WALL-MOUNTED ACCESSORIES

STANDARD PLUMBING FIXTURES AND WALL-MOUNTED ACCESSORY MOUNTING HEIGHTS

STANDARD MOUNTING HEIGHTS FOR BATHTUB AND SHOWER FIXTURES

STANDARD HEIGHTS FOR TRANSACTION COUNTER/ SHELVING/ SEATING

TYPICAL MOUNTING HEIGHTS J4
1/4" = 1'-0"

WALL MOUNTED HANDRAIL J1
1 1/2" = 1'-0"

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0224 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0224 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0218 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

NOTES:
1. REFER TO FLOOR PLAN FOR RATED WALLS.
2. ACOUSTICAL SEALANT MAY BE USED IN PLACE OF FIRE/SMOKE SEALANT IF WALL IS NOT RATED.
3. COMPLY WITH REQUIREMENTS OF UL SYSTEM HW-D-0388 (OR EQUAL) WHERE WALL IS INDICATED TO BE FIRE OR SMOKE RATED.
4. TAPE AND CAULK ALL PENETRATIONS.

TOP OF WALL DETAILS A11
3" = 1'-0"

TYPE F1.a NON-RATED

ONE LAYER 5/8"GWB TAGGED SIDE OF 7/8" HAT CHANNELS.

TYPE F2.a NON-RATED

ONE LAYER 5/8"GWB TAGGED SIDE OF 1 5/8" METAL STUDS.

TYPE F3.a NON-RATED

ONE LAYER 5/8"GWB TAGGED SIDE OF 3 5/8" METAL STUDS.

TYPE S2.a NON-RATED

(STC 45) ONE LAYER 5/8"GWB EACH SIDE OF 2 1/2" METAL STUDS.

TYPE S3.a NON-RATED

(STC 45) ONE LAYER 5/8"GWB EACH SIDE OF 3 5/8" METAL STUDS.

TYPE S6.a NON-RATED

(STC 45) ONE LAYER 5/8"GWB EACH SIDE OF 6" METAL STUDS.

TYPE X3.1 1 HR FIRE RATED

(STC 45) ONE LAYER 5/8"GWBX EACH SIDE OF 3 5/8" METAL STUDS. UL# U419

TYPE X6.1 1 HR FIRE RATED

(STC 45) ONE LAYER 5/8"GWBX EACH SIDE OF 6" METAL STUDS. UL# U419

TYPE Y3.1 1 HR SMOKE RATED

(STC 45) ONE LAYER 5/8"GWBX EACH SIDE OF 3 5/8" METAL STUDS. UL# U419

TYPE Y6.1 1 HR SMOKE RATED

(STC 45) ONE LAYER 5/8"GWBX EACH SIDE OF 6" METAL STUDS. UL# U419

TYPE G1 FRAMELESS GLASS

WALL TYPES A1
1 1/2" = 1'-0"

WALL TYPE NOTES:

1. ALL INTERIOR PARTITIONS TO BE TYPE S3.a UNLESS OTHERWISE INDICATED.

REV	DESCRIPTION	DATE
1	SI - 4	05/31/18
0	ISSUED FOR CONSTRUCTION	04/16/18

SI - 4
05/31/18
CURRENT ISSUE STATUS:

SMRT Architects and Engineers
144 Fore Street/P.O. Box 618
Portland, Maine 04104
ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY
SMRT

WEX
CORPORATE HEADQUARTERS
PORTLAND, ME

GENERAL MOUNTING HEIGHTS, WALL TYPES & TOP OF WALL DETAILS
SHEET TITLE:

SCALE: AS NOTED

PROJECT MANAGER:	GWV	PROJECT NO:	17120-01
A/E OF RECORD:	GWV		
JOB CAPTAIN:	CBM		
DRAWN BY:	CBM		
SMRT FILE:	GI002-17120-01	SHEET No.	GI002

© COPYRIGHT 2017 SMRT INC