


CORE & SHELL NOTE:
 THESE DOCUMENTS ARE INTENDED TO SHOW THE CORE AND SHELL SYSTEMS FOR A BUILDING THAT WILL ALSO HAVE A TENANT FIT - UP COMPLETED DURING THE INITIAL BUILDING CONSTRUCTION PHASE. NO TEMPORARY CONDITIONING OF SPACES ARE NECESSARY. CORE BUILDING MECHANICAL AND PLUMBING SYSTEMS HAVE BEEN DESIGNED TO SUPPLY CHILLED WATER, HOT WATER, VENTILATION AND EXHAUST AIR TO ALL AREAS OF THE BUILDING. DURING FIT - UP DESIGN INTERIOR SYSTEMS WILL BE DEFINED.

FUTURE TENANT SHAFT:
 SHAFT WITH DUCTWORK WILL BE PROVIDED UP THRU BUILDING TO SERVE RETAIL RESTAURANT TENANT ON 1st LEVEL. DUCTWORK SIZES AND OTHER UTILITIES WILL BE CONFIRMED AND INSTALLED BEFORE THE COMPLETION OF THE TENANT FIT UP ON FLOORS 2 & 3. SIZES AND UTILITIES AT THIS POINT ARE PRELIMINARY FOR COORDINATION PURPOSES. ALL ASSUMPTIONS TO BE VARIFIED PRIOR TO INSTALL. SHAFT WILL HAVE A UL LISTED GREASE DUCT OF 18" DIA. W/3" FIREWRAP. (THIS IS GOOD FOR 2,800 CFM OF TYPE I EXHAUST). SHAFT WILL HAVE A 14" DIA. ALUMINUM DUCT FOR TYPE II EXHAUST. (GOOD FOR 1,200CFM). SHAFT WILL HAVE A 24" X 18" MAKEUP AIR SUPPLY DUCT W/INSULATION. (GOOD FOR 4,000 CFM OF SUPPLY AIR). SHAFT WILL HAVE TWO 20" X 18" DUCTS FOR SUPPLY/RETURN. (GOOD FOR 3,000 CFM). SPACE IN SHAFT WILL ALSO ALLOW FOR FUTURE REFRIGERATION LINES & ELECTRICAL CONDUITS IF NECESSARY.

1 2ND FLOOR HVAC B
 1/8" = 1'-0"



Prepared For:

Consultant:
JOHNSON & JORDAN
 MECHANICAL CONTRACTORS
 55 BROAD STREET, 10TH FLOOR
 PORTLAND, ME 04101
 TEL: (207) 883-8345

Architect:
ARCHITECTYPE
 architects
 48 Union Wharf Portland, Maine 04101
 (207) 772-6022 ARCHITYPE@ARCHITYPE.COM

Project:
 0 HANCOCK STREET
 0 HANCOCK STREET, PORTLAND
 MAINE

Revisions:
 ISSUED FOR PERMIT
 10/20/17

Date: Oct. 10 2017
 Scale: 1/8" = 1'-0"
 SECOND FLOOR HVAC
 PLAN

M102B