WALL TYPE SCHEDULE						
1A NON-BEARING U.L.# N.A.	ONE LAYER OF %" GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 8" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION 5/8" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 1 7/8" AIR SPACE PRECAST CONCRETE PANEL	1J NON-BEARING U.L.# N.A.	ONE LAYER OF %" TYPE X GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 6" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION %" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 1 3/4" AIR SPACE CONCRETE MASONRY VENEER	2A NON-BEARING STC 45-49 RAL-TL07-357 U.L.# N/A	%" GYPSUM BOARD 3 %" 25 GA. GALV. METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION %" GYPSUM BOARD NOTE: EXTEND CONSTRUCTION 2" MINIMUM ABOVE NON-FIRE RATED FINISH CEILING. BRACE TO ADJACENT STRUCTURE AT 4'-0" O.C. DO NOT PENETRATE FIRE RATED FLOOR/CEILING.	## GYPSUM BOARD METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION 1/2" MIN. AIR SPACE (REFER TO PLANS) RATED WALL ASSEMBLY AS NOTED ON PLANS FURRED PARTITION - METAL 1 1/2" = 1'-0"
1B NON-BEARING U.L.# N.A.	ONE LAYER OF %" GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 8" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION 5/8" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 7/8" AIR SPACE PRECAST CONCRETE PANEL UP TO 4-0" AFF METAL TILE ABOVE	1K NON-BEARING U.L.# N.A.	ONE LAYER OF %" TYPE X GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 8" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION 5%" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 1 3/4" AIR SPACE CONCRETE MASONRY VENEER	2B NON-BEARING STC 45-49 RAL-TL07-357 U.L.# N/A	%" GYPSUM BOARD 6" 25 GA. GALV. METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION 5%" GYPSUM BOARD NOTE: EXTEND CONSTRUCTION 2" MINIMUM ABOVE NON-FIRE RATED FINISH CEILING. BRACE TO ADJACENT STRUCTURE AT 4'-0" O.C. DO NOT PENETRATE FIRE RATED FLOOR/CEILING.	VINYL CONTROL JOINT CJV16 AS MANUF. BY VINYL CORP. OR EQUAL ½" MAX, GAP GWB LAMINATING SCREW AS REQ'D ½" TYPE "C" GWB BACKING GWB WALL CONTROL JOINT 1 1/2" = 1'-0"
1C NON-BEARING U.L.# N.A.	ONE LAYER OF %" GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 10" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION 5/8" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 7/8" AIR SPACE PRECAST CONCRETE PANEL UP TO 4-0" AFF METAL TILE ABOVE	1 L NON-BEARING U.L.# N.A.	ONE LAYER OF %" TYPE X GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 8" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION %" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 1 3/4" AIR SPACE BRICK VENEER	NON-BEARING STC 50-54 RAL TL05-080 GA WP 1049 1 HR.	CORRIDOR SIDE %" TYPE X GYPSUM BOARD ½" RESILIENT GALV. METAL CHANNEL HORIZONTAL @ 24" O.C. 3 %" 25 GA. GALV. METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION %" TYPE X GYPSUM BOARD %" TYPE X GYPSUM BOARD %" TYPE MR GYPSUM BOARD AT TUB/SHOWER AS REQ'D NOTE: EXTEND CONSTRUCTION TO BOTTOM OF FLOOR/ROOF DECK	GWB STUD WALL RES. CHANNEL FASTENERS PER UL OR GA CRITERIA NOTE: INSTALL CHANNELS W/ MOUNTING FLANGE DOWN RESILIENT CHANNELS 1 1/2" = 1'-0"
1D NON-BEARING U.L.# N.A.	ONE LAYER OF %" GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 10" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION 5/8" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 1 7/8" AIR SPACE PRECAST CONCRETE PANEL	1M NON-BEARING U.L.# N.A.	ONE LAYER OF %" GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 8" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION 5/8" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 7/8" AIR SPACE PRECAST CONCRETE PANEL UP TO 4'-0" AFF METAL TILE ABOVE	3B NON-BEARING STC 50-54 RAL TL05-080 GA WP 1049 1 HR.	CORRIDOR SIDE %" TYPE X GYPSUM BOARD ½" RESILIENT GALV. METAL CHANNEL HORIZONTAL @ 24" O.C. 6" 25 GA. GALV. METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION %" TYPE X GYPSUM BOARD %" TYPE MR GYPSUM BOARD AT TUB/SHOWER AS REQ'D NOTE: EXTEND CONSTRUCTION TO BOTTOM OF FLOOR/ROOF DECK	METAL STUD WALL PARTITION, REFER TO PLANS ELECTRICAL OUTLET BOX NOTE: 1. STACK MULTIPLE BOXES VERTICALLY WHEN ON SAME SIDE OF WALL AS REQUIRED BY INTERIOR DESIGN DRAWINGS. 2. BOXES LOCATED ON OPPOSITE SIDES OF WALL OR PARTITIONS SHALL BE SEPARATED BY A MINIMUM HORIZONTAL DISTANCE OF 24 INCHES. THE MINIMUM
1E NON-BEARING U.L.# N.A.	ONE LAYER OF %" TYPE X GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 6" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION %" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 1 3/4" AIR SPACE BRICK VENEER			AA NON-BEARING STC 55-59 NRCC 818-NV U.L.# U423 2 HR.	TWO LAYERS OF %" TYPE X GYPSUM BOARD 3 %" GALV. METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION TWO LAYERS OF %" TYPE X GYPSUM BOARD %" TYPE MR GYPSUM BOARD AT TUB/SHOWER AS REQ'D NOTE: EXTEND CONSTRUCTION TO BOTTOM OF FLOOR/ROOF DECK	SEPARATION DISTANCE BETWEEN BOXES MAY BE REDUCED WHEN "WALL OPENING PROTECTIVE MATERIALS" (CIIV" ARE INSTALLED ACCORDING TO TEH REQUIREMENTS ON THEIR CLASSIFICATION. THE SURFACE AREA OF THE INDIVIDUAL BOXES SHALL NOT EXCEED 16 SQ. IN. THE AGGREGATE SURFACE AREA OF TEH BOXES SHALL NOT EXCEED 100 SQ. IN. PER 100 SQ. FT. OF WALL SURFACE. PLAN AT OUTLETS 1 1/2" = 1'-0"
1F NON-BEARING STC 50 U.L.# N.A.	ONE LAYER OF %" TYPE X GYPSUM BOARD 4 MIL. POLYETHYLENE VAPOR BARRIER 6" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION %" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD METAL TILE			AB NON-BEARING STC 55-59 NRCC 818-NV U.L.# U423 2 HR.	TWO LAYERS OF %" TYPE X GYPSUM BOARD 6" GALV. METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION TWO LAYERS OF %" TYPE X GYPSUM BOARD %" TYPE MR GYPSUM BOARD AT TUB/SHOWER AS REQ'D NOTE: EXTEND CONSTRUCTION TO BOTTOM OF FLOOR/ROOF DECK	
1G NON-BEARING STC 50 U.L.# N.A.	ONE LAYER OF %" TYPE X GYPSUM BOARD 4 MIL. POLYETHYLENE VAPOR BARRIER 6" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION %" TYPE X FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD HIGH PRESSURE LAMINATE (HPL) PANEL RANSCREEN			AC NON-BEARING STC 55-59 NRCC 818-NV U.L.# U423 2 HR.	TWO LAYERS OF %" TYPE X GYPSUM BOARD 8" GALV. METAL STUDS AT 24" O.C. FIBERGLASS BATT SOUND INSULATION TWO LAYERS OF %" TYPE X GYPSUM BOARD NOTE: EXTEND CONSTRUCTION TO BOTTOM OF FLOOR/ROOF DECK	NOTES: 1. ALL BUILDING WRAP JOINTS TO BE TAPED IN ACCORDANCE WITH MANUFACTURER'S WRITTEN INSTRUCTIONS. 2. ALL COMMON AREA REST ROOM WALL COMPONENTS TO EXTEND TO UNDERSIDE OF DECK. 3. ALL COMPONENTS OF RATED WALLS TO EXTEND TO UNDERSIDE OF DECK AND FIRESTOPPED WITH THE REQUIREMENTS OF IBC SECTION 714. 4. PROVIDE DEFLECTION TRACK WHERE WALLS ATTACHED TO LONG STRUCTURAL MEMBERS. DESIGN BY LIGHT GAGE CONTRACTOR. 5. WOOD BLOCKING TO BE INSTALLED AT ALL CABINET, CHAIR RAIL, COUNTERTOP, BATHROOM ACCESSORIES, WINDOW TREATMENTS, RAILING, CLOSET SHELVES AND RODS, AND AT MISCELLANEOUS LOCATIONS AS REQUIRED. 6. ADD ADDITIONAL INSULATION TO FILL CAVITY OF 8" STUD WALL. 7. WHEN INSULATION IS INSTALLED IN WALLS USE SPRAY ADHESIVE OR OTHER ACCEPTABLE METHOD TO HOLD IN PLACE UNTIL COVERED WITH SHEATHING. MECHANICALLY FASTEN AT AREAS WITHOUT SHEATHING. 8. STC AND IIC RATINGS SHALL BE IN ACCORDANCE WITH ASTM E90 AND ASTM E492, RESPECTIVELY. PROVIDE ACOUSTICAL SEALANT AT BASE OF WALLS BETWEEN GUESTROOMS AND DWELLING UNITS 9. RATED WALL ASSEMBLIES SHALL BE INSTALLED PER U.L. ASSEMBLY NUMBER. REFER TO U.L. LISTING FOR SPECIFIC INSTALLATION REQUIREMENTS. 10. WHERE TILE IS INDICATED ON THE PLANS SUBSTITUTE 5/8" "DENS-SHIELD FIREGUARD" TILE BACKER BOARD WHERE TILE IS TO BE APPLIED. 11. SUBSTITUTE 5/8" TYPE X MOISTURE RESISTANT G.W.B. AT BATHROOMS AND OTHER AREAS SUBJECT TO DAMP OR WET CONDITIONS
NON-BEARING STC 50 U.L.# N.A.	ONE LAYER OF %" GYPSUM BOARD 6 MIL. POLYETHYLENE VAPOR BARRIER 10" GALV. METAL STUDS AT 24" O.C. R-21 FIBERGLASS BATT INSULATION 5/8" FIBERGLASS-MAT FACED GYPSUM SHEATHING WRAPSHEILD SA (SELF ADHERED) WRB/AIR SHIELD BY VAPROSHIELD 1 3/4" AIR SPACE CONCRETE MASONRY VENEER			NON-BEARING STC 64 U.L.#U493 2 HR.	%" TYPE MR GYPSUM BOARD AT TUB/SHOWER AS REQ'D TWO LAYERS OF %" TYPE X GYPSUM BOARD 3 %" 20 GA. GALV. METAL STUDS AT 24" O.C. 3 1/2" THERMAFIBER SAFB (SOUND ATTENUATION FIRE BLANKET) AIR SPACE 3 %" 20 GA. GALV. METAL STUDS AT 24" O.C. 3 1/2" THERMAFIBER SAFB (SOUND ATTENUATION FIRE BLANKET) BRACING - CUT FROM GWB, LENGTH EQUAL TO STUD CAVITY & 6" WIDTH TWO LAYERS OF %" TYPE X GYPSUM BOARD %" TYPE MR GYPSUM BOARD AT TUB/SHOWER AS REQ'D NOTE: EXTEND CONSTRUCTION TO BOTTOM OF DECK	 THAT DO NOT RECEIVE TILE. 12. NON-RATED WALL ASSEMBLIES SHALL NOT PENETRATE FIRE-RATED FLOOR/CEILING ASSEMBLIES. 13. GYPSUM BOARD SHALL BE CONTINUOUS BEHIND TUB/SHOWER ENCLOSURES AT FIRE-RATED WALL ASSEMBLIES. PROVIDE ADDITIONAL LAYER AT THESE LOCATIONS. 14. EXTERIOR AND INTERIOR LIGHT GAGE LOAD BEARING STEEL FRAMING IS SCHEMATICALLY SHOWN AND DESIGN IS TO BE BY OTHERS. COORDINATE LOCATIONS WITH STRUCTURAL DRAWINGS. REFER TO STRUCTURAL DRAWINGS AND NOTES FOR ADDITIONAL REQUIREMENTS. 15. MAXIMUM HEIGHT FOR NON-STRUCTURAL INTERIOR WALLS SHALL BE IN ACCORDANCE WITH SSMA "LIMITING WALL HEIGHT TABLES NON-COMPOSITE". 16. ALL HOURLY FIRE RATINGS SHOWN ARE THE MAXIMUM ALLOWED FOR THAT ASSEMBLY. REFER TO FLOOR PLANS FOR REQUIRED HOURLY FIRE RATING OF SEPARATION ASSEMBLIES. 17. REFER TO STRUCTURAL DRAWINGS FOR ADDITIONAL SHEAR WALL REQUIREMENTS AND LOCATIONS. 18. ALL FIRE-RATED WALL ASSEMBLIES SHALL BE IDENTIFIED WITH SIGNS OR STENCILING IN ACCORDANCE WITH IBC SECTION 703.6.

OPECHEE CONSTRUCTION CORPORATION AC HOTELS by MARRIOTT 10-18-16 60% MARRIOT REVIEW 10-21-16 BUILDING SHELL PERMI' . project architect: KAK

> WALL TYPE SCHEDULE