

20 THAMES STREET RESIDENTIAL

> CONDOMINIUM 20 THAMES STREET

ESSEXNORTH 20 THAMES LLC P.O. Box 1383 SANIBEL, FL 33957

PORTLAND, MAINE

THE 8"/6" FIRE LINE AND THE 4" DOMESTIC WATER LINE SHALL BE SEPARATED BY A MINIMUM OF 2 FEET FACE TO FACE.

THE SHUTOFF VALVES FOR THE 8" FIRE AND 4" DOMESTIC

SHALL BE PLACED A MINIMUM OF 2' FROM THE FACE OF

PRIOR TO INSTALLATION OF ADDITIONAL JOINTS (REDUCER,

TREES WELLS AND STREET LIGHTS SHALL BE LOCATED A MINIMUM OF 10 FEET FROM THE WATER SERVICE.

SCALE in FEET 1"=5'

GENERAL NOTES

RIGHT-OF-WAY.

1. EXISTING UTILITIES SHOWN ARE APPROXIMATE AND SHALL BE FIELD VERIFIED.

2. COORDINATE INSTALLATION OF FIRE SERVICE AND DOMESTIC WATER SERVICE WITH PORTLAND WATER DISTRICT.

BACKWATER VALVES (BACKFLOW PREVENTER) SHALL BE INSTALLED ON EACH SANITARY LINE AS IT EXITS THE BUILDING. EACH VALVE SHALL BE PLACED WITHIN AN ACCESS BOX SUPPLIED BY MANUFACTURER.

4. A LICENSE FROM THE CITY OF PORTLAND SHALL BE REQUIRED FOR ANY BACKWATER VALVES WITHIN THE CITY

5. TO ABANDON EXISTING WATER SERVICE ON THAMES STREET, REMOVE VALVE AND TAPPING SLEEVE AND INSERT REPAIR SLEEVE AND PIPE. SHUT DOWN OF MAIN SHALL BE REQUIRED. CAP FREE END OF SERVICE.

DOMESTIC WATER SERVICE LINE TO BE PROTECTED FROM BACKFLOW BY INSTALLATION OF A REDUCED PRESSURE ZONE

(RPZ) DEVICE AFTER THE METER, AS REQUIRED BY THE


PORTLAND WATER DISTRICT. PROPER DRAINAGE IN THE MECHANICAL ROOM IS RECOMMENDED.

SCALE

SCALE in FEET 1"=20'

CURB ON FORE STREET.

ESSEXNORTH PORTLAND LLC P.O. BOX 394 TOPSFIELD, MA 01983



MAUREEN P. McGLONE, PE #7705 400 COMMERCIAL STREET, SUITE 404 PORTLAND, ME 04101 207-772-2891

RANSOM

Engineers and Scientists

400 Commercial Street, Suite 404 Portland, ME 04101 Tel. (207) 772-2891 Fax (207) 772-3248 www.ransomenv.com

UTILITY PLAN

2	ADDENDUM 2		08/15/17
1	REVISION 1		08/07/17
Ε	ISSUED FOR BID		07/14/17
D	PER CMP COMMENTS		06/30/17
С	PER REVIEW COMMENTS		06/09/17
В	CONSTRUCTION REVIEW		05/26/17
Α	CITY SUBMISSION		03/09/17
No.	Revision/Issue		Date
Design by:		Checked by:	
MPM		SJB	

MPM Approved by: 150.06094 FEBRUARY 2017