W30 WALL 30A&B - NON-RATED PARTITION

NON-RATED, NON-BEARING PARTITION

'B' USES 6" STUDS IN PLACE OF 3-5/8" STUDS.

MSG CORROSION-PROTECTED STEEL, MIN DEPTH TO

ACCOMMODATE STUD SIZE, WITH MIN 1-1/4 IN. LONG LEGS,

TYPE X GYP BOARD - (1) LAYERS 5/8 IN. THICK, 4 FT WIDE.

STEEL SCREWS SPACED 12" O.C. GYPSUM PANELS WITH

JOINTS ON OPPOSITE SIDES OF STUDS NEED NOT BE

BD AT ALL INTERIOR FACES OF BATH ROOMS

GYP BD FOR CONTINUOUS BLOCKING

LAYER OF COMPOUND OVER ALL JOINTS.

CONTROL. BOTH SIDES OF WALL.

BASE - SEE FINISH SCHEDULE

ATTACHED TO CONCRETE DECK WITH FASTENERS 24 IN. OC

GYPSUM BOARD SECURED TO STUDS WITH 1" LONG TYPE S-12

BEVELED, SQUARE OR TAPERED EDGES, APPLIED VERTICALLY

OR HORIZONTALLY. VERTICAL JOINTS CENTERED OVER STUDS

AND STAGGERED ONE STUD CAVITY ON OPPOSITE SIDES OF

STUDS. HORIZONTAL JOINTS NEED NOT BE BACKED BY STEEL

FRAMING. HORIZONTAL EDGE JOINTS AND HORIZONTAL BUTT

PLYWOOD (TAGGED SIDE) - 1/2" PLYWOOD INSTALLED UNDER

CAULKING AND SEALANTS - A BEAD OF ACOUSTICAL SEALANT

TAPE AND COMPOUND - (NOT SHOWN) VINYL, DRY OR PREMIXED

APPLIED AROUND THE PARTITION PERIMETER FOR SOUND

JOINT COMPOUND, APPLIED IN TWO COATS TO JOINTS AND

SCREW HEADS, PAPER TAPE, 2 IN. WIDE, EMBEDDED IN FIRST

FLOOR RUNNER - CHANNEL SHAPED. FABRICATED FROM MIN 25

BLOCKING - (NOT SHOWN) WOOD BLOCKING AS NEEDED

MSG CORROSION-PROTECTED STEEL, MIN DEPTH TO ACCOMMODATE STUD SIZE, WITH MIN 1-1/4 IN. LONG LEGS, ATTACHED TO CONCRETE DECK WITH FASTENERS 24 IN. OC

STAGGERED. NOTE: USE TYPE MRX MOISTURE RESISTANT GYP

STUDS - CHANNEL SHAPED, FABRICATED FROM MIN 25 MSG

CORROSION-PROTECTED STEEL, MIN DEPTH AS INDICATED

UNDER ITEM 5. SPACED A MAX OF 24 IN. OC. STUDS TO BE CUT

3/8 TO 3/4 IN. LESS THAN ASSEMBLY HEIGHT. NOTE: WALL TYPE

CEILING RUNNER - CHANNEL SHAPED. FABRICATED FROM MIN 25

SOUND - N/A

W28 WALL 28A&B - NON-RATED PARTITION

-4 1/4" , B=6 5/8

3 5/8"

NON-RATED, NON-BEARING PARTITION

<u>W29A</u> <u>W29B</u>

SOUND - N/A

STUDS - CHANNEL SHAPED, FABRICATED FROM MIN 25 MSG CORROSION-PROTECTED STEEL, MIN DEPTH AS INDICATED UNDER ITEM 5, SPACED A MAX OF 24 IN. OC. STUDS TO BE CUT

3/8 TO 3/4 IN. LESS THAN ASSEMBLY HEIGHT. NOTE: WALL TYPE **CEILING RUNNER - CHANNEL SHAPED, FABRICATED FROM MIN 25** NO. 936

Portland

'B' USES 6" STUDS IN PLACE OF 3-5/8" STUDS. MSG CORROSION-PROTECTED STEEL, MIN DEPTH TO ACCOMMODATE STUD SIZE, WITH MIN 1-1/4 IN. LONG LEGS, ATTACHED TO CONCRETE DECK WITH FASTENERS 24 IN. OC TYPE X GYP BOARD - (1) LAYERS EA. SIDE. 5/8 IN. THICK, 4 FT WIDE. GYPSUM BOARD SECURED TO STUDS WITH 1" LONG TYPE

S-12 STEEL SCREWS SPACED 12" O.C. GYPSUM PANELS WITH BEVELED, SQUARE OR TAPERED EDGES, APPLIED VERTICALLY OR HORIZONTALLY. VERTICAL JOINTS CENTERED OVER STUDS AND STAGGERED ONE STUD CAVITY ON OPPOSITE SIDES OF STUDS. HORIZONTAL JOINTS NEED NOT BE BACKED BY STEEL FRAMING. HORIZONTAL EDGE JOINTS AND HORIZONTAL BUTT JOINTS ON OPPOSITE SIDES OF STUDS NEED NOT BE STAGGERED. NOTE: USE TYPE MRX MOISTURE RESISTANT GYP BD AT ALL INTERIOR FACES OF BATH ROOMS

CAULKING AND SEALANTS - A BEAD OF ACOUSTICAL SEALANT APPLIED AROUND THE PARTITION PERIMETER FOR SOUND CONTROL, BOTH SIDES OF WALL. BLOCKING - (NOT SHOWN) WOOD BLOCKING AS NEEDED

TAPE AND COMPOUND - (NOT SHOWN) VINYL, DRY OR PREMIXED JOINT COMPOUND, APPLIED IN TWO COATS TO JOINTS AND SCREW HEADS, PAPER TAPE, 2 IN. WIDE, EMBEDDED IN FIRST LAYER OF COMPOUND OVER ALL JOINTS. **BASE - SEE FINISH SCHEDULE**

FLOOR RUNNER - CHANNEL SHAPED, FABRICATED FROM MIN 25 MSG CORROSION-PROTECTED STEEL, MIN DEPTH TO ACCOMMODATE STUD SIZE, WITH MIN 1-1/4 IN. LONG LEGS, ATTACHED TO CONCRETE DECK WITH FASTENERS 24 IN. OC

W29 WALL 29A&B - NON-RATED FURRING WALL

1 1/2" = 1'-0"

NON-RATED, NON-BEARING PARTITION <u>W28A</u> <u>W28B</u> 3 5/8" | 6"

STUDS - CHANNEL SHAPED, FABRICATED FROM MIN 25 MSG CORROSION-PROTECTED STEEL, MIN DEPTH AS INDICATED UNDER ITEM 5, SPACED A MAX OF 24 IN. OC. STUDS TO BE CUT 3/8 TO 3/4 IN. LESS THAN ASSEMBLY HEIGHT. NOTE: WALL TYPE **'B' USES 6" STUDS IN PLACE OF 3-5/8" STUDS. CEILING RUNNER - CHANNEL SHAPED, FABRICATED FROM MIN 25**

MSG CORROSION-PROTECTED STEEL, MIN DEPTH TO ACCOMMODATE STUD SIZE, WITH MIN 1-1/4 IN. LONG LEGS, ATTACHED TO CONCRETE DECK WITH FASTENERS 24 IN. OC

TYPE X GYP BOARD - (1) LAYERS EA. SIDE. 5/8 IN. THICK, 4 FT WIDE. GYPSUM BOARD SECURED TO STUDS WITH 1" LONG TYPE S-12 STEEL SCREWS SPACED 12" O.C. GYPSUM PANELS WITH BEVELED, SQUARE OR TAPERED EDGES, APPLIED VERTICALLY OR HORIZONTALLY. VERTICAL JOINTS CENTERED OVER STUDS AND STAGGERED ONE STUD CAVITY ON OPPOSITE SIDES OF STUDS. HORIZONTAL JOINTS NEED NOT BE BACKED BY STEEL FRAMING. HORIZONTAL EDGE JOINTS AND HORIZONTAL BUTT JOINTS ON OPPOSITE SIDES OF STUDS NEED NOT BE STAGGERED. NOTE: USE TYPE MRX MOISTURE RESISTANT GYP BD AT ALL INTERIOR FACES OF BATH ROOMS

PLYWOOD (TAGGED SIDE) - 1/2" PLYWOOD INSTALLED UNDER GYP BD FOR CONTINUOUS BLOCKING CAULKING AND SEALANTS - A BEAD OF ACOUSTICAL SEALANT APPLIED AROUND THE PARTITION PERIMETER FOR SOUND

CONTROL, BOTH SIDES OF WALL **BLOCKING - (NOT SHOWN)** WOOD BLOCKING AS NEEDED

TAPE AND COMPOUND - (NOT SHOWN) VINYL, DRY OR PREMIXED JOINT COMPOUND, APPLIED IN TWO COATS TO JOINTS AND SCREW HEADS, PAPER TAPE, 2 IN. WIDE, EMBEDDED IN FIRST LAYER OF COMPOUND OVER ALL JOINTS. **BASE -** SEE FINISH SCHEDULE **FLOOR RUNNER -** CHANNEL SHAPED, FABRICATED FROM MIN 25

MSG CORROSION-PROTECTED STEEL, MIN DEPTH TO ACCOMMODATE STUD SIZE, WITH MIN 1-1/4 IN. LONG LEGS, ATTACHED TO CONCRETE DECK WITH FASTENERS 24 IN. OC

INTERIOR

[7]

ALL