KVS-8-L FIRE SUPPRESSION SYSTEM COMPONENTS

	LEGEND
1	ANSUL R-102 SUPPLY : (6 GALLONS – DOUBLE TANK (2-3 GALLON) = 22 FLOW POINTS)
2	(2)FILTER BOX PROTECTION NOZZLES (1/2N TYPE) ANSUL #56929 – 1/2 FLOW POINT EACH
3	(1)PLENUM PROTECTION NOZZLE (N TYPE) ANSUL #56930 – 1 FLOW POINT EACH
4	(8) APPLIANCE PROTECTION NOZZLES (INS SWIVEL TYPE) ANSUL #415566 – 1 FLOW POINT EACH
5	165° FUSIBLE LINK – ANSUL #415739

NOTE:
FIRE PROTECTION SYSTEM IS ENGINEERED, SIZED, AND SUPPLIED AS INTEGERAL PART OF THE KVS AND ITS LISTING (UL FILE #MH17853).

CLASS "K" EXTINGUISHER , WITH APPROVED PLACARD, WILL BE PROVIDED WITHIN 30 FEET OF HAZARD AREA.
ALL HAND HELD EXTINGUSISHERS ARE TO BE SUPPLIED AND INSTALLED BY OTHERS.

Reviewed for Code Compliance
Inspections Division
Fire Protection Division
Date: 02/07/18

THIS DRAWING MUST BE CHECKED, SIGNED AND RETURNED TO THE APPROPRIATE FACTORY. PLEASE VERIFY THE FOLLOWING:
1. ALL DIMENSIONAL INFORMATION, MOUNTING POSITION AND CLEARANCES.
2. THE LOCATION AND TYPE OF COOKING EQUIPMENT.
NOTE TO APPROVER
ANY CHANGES IN COOKING EQUIPMENT SUCH AS INCREASED ENERGY INPUTS OR EQUIPMENT POSITION MAY AFFECT EXHAUST AIRFLOW. HALTON MUST BE NOTIFIED IN ANY OF THESE CHANGES OCCUR. A RECALCULATION EXHAUST AIRFLOW MAY BE REQUIRED.
☐ REVISE AND RESUBMIT
APPROVED FOR FABRICATION
☐ WITH NO CHANGES ☐ WITH CHANGES AS

APPROVED BY | DATE

COMPLIES WITH NFPA-96

MAIL APPROVED DRAWINGS TO APPROPRIATE FACTORY BELOW:

HALTON CO. (CANADA)
1021 BREVIK PLACE
MISSISSAUGA, ON L4W 3R7
1-905-624-0301

HALTON CO. (USA)
101 INDUSTRIAL DRIVE
SCOTTSVILLE, KY 42164
1-270-237-5600

WEBSITE: WWW.HALTONCOMPANY.COM

REV.	REVISION DESCRIPTION	BY	DATE
1			
2			
3			
4			
5			
6			

PROJECT: AC MARRIOTT
LOCATION: PORTLAND, ME
DRAWN BY: RB | DATE: 11/15/16
SCALE: NOT TO SCALE
CONSULTANT:

Halton

DRAWING No.: U16-761
DRAWING TITLE: KVS-8-L
REV. No.: 0
SHEET No.: 2 of 2