

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
ENGINE HOUSE LLC

Located at
97 INDIA ST

PERMIT ID: 2015-02729 **ISSUE DATE:** 12/22/2015 **CBL:** 020 A005001

has permission to **Install one building wall sign (19" x 13'4"), one directory sign (30" x 54") and a 20" x 25" sign panel by main entry**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
offices

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-02729	Date Applied For: 11/09/2015	CBL: 020 A005001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: offices	Proposed Project Description: Install one building wall sign (19" x 13'4"), one directory sign (30" x 54") and a 20" x 25" sign panel by main entry			
Dept: Historic Status: Approved w/Conditions Reviewer: Deborah Andrews Approval Date: 12/22/2015 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Scale on letters on main building sign to be revised as per drawing e-mailed by Kayla of Burr Signs to HP staff on 12/22/15. (Revised drawing shows greater contrast between size of letters of 97 India and Engine House. 2) Both directory sign and main building sign to feature gold lettering.				
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 12/03/2015 Note: Reviewed under B2b requirements Ok to Issue: <input checked="" type="checkbox"/> multi-tenant - Alternative 2 (Table 2.13 - Building Signs) -front façade approx. 900 sf (30' x 30') - 5% = 45 sf allowed - 35.8 sf proposed - OK -1 per tenant & on additional per building face - OK Conditions: 1) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Laurie Leader Approval Date: 12/04/2015 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code.				