GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 2X4 WOOD STUDS AT 16" O.C. - 3-1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NA	N/A	N/A	35-39	N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 2X4 WOOD STUDS AT 16" O.C. - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NB	N/A	N/A	N/A	N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 2X6 WOOD STUDS AT 16" O.C. - 5-1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NC	N/A	N/A	35-39	N/A

1 ENLARGED PLANS
1/2" = 1'-0"

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/11/16

© 2016 RYAN SENATORE ARCHITECTURE

CLOUDPORT OFFICES

63 FEDERAL STREET
PORTLAND, MAINE

RSA
RYAN SENATORE
ARCHITECTURE
565 CONGRESS STREET
PORTLAN, MAINE 04101
207-650-6414
senatorearchitecture.com

CONSULTANTS:

REVISIONS:
1 REVISION #1 - 04/03/16

DATE:	29 MARCH 2016
PROJECT No.	1617
DRAWN BY:	RRT
CHECKED BY:	RJS
SCALE:	AS NOTED

SHEET TITLE:
ENLARGED BATHROOM PLANS

A1-1