

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**  
SUNENBLICK STEPHEN

**Located at**  
63 FEDERAL ST

**PERMIT ID:** 2016-01728      **ISSUE DATE:** 07/28/2016      **CBL:** 020 A007001

has permission to **HVAC; Installing Daikin Mini Splits**  
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*  
offices

*Building Inspections*

*Fire Department*

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

## **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2016-01728	<b>Date Applied For:</b> 06/29/2016	<b>CBL:</b> 020 A007001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Offices	<b>Proposed Project Description:</b> HVAC; Installing Daikin Mini Splits			
<p><b>Dept:</b> Historic      <b>Status:</b> Approved w/Conditions      <b>Reviewer:</b> Robert Wiener      <b>Approval Date:</b> 07/27/2016</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p> <p>1) Bottom of rooftop condensers is to be as low as possible - maximum of 20" off roof surface, so the total height does not exceed 50" above the roof surface.</p> <p>2) HP staff understands that all rooftop heat pump condensers are to in line with the proposed location of the middle pair shown on the HVAC plans, close to the edge of the roof furthest from Federal Street. (The two pairs proposed near the front (Federal Street) edge of the roof are to be moved.) In addition, all condensers are to be as far as possible from the India Street edge of the building.</p> <p><b>Dept:</b> Zoning      <b>Status:</b> Approved      <b>Reviewer:</b> Christina Stacey      <b>Approval Date:</b> 07/22/2016</p> <p><b>Note:</b>      <b>Ok to Issue:</b> <input checked="" type="checkbox"/></p> <p><b>Conditions:</b></p>				