

COMMENTS

4/10/01 - Went over requirements for stair construction throughout -
7-11 rule applies to this facility - Will ask for variance to move
doors so 11 inch rule is observed - will call if any other questions

9/17/01 Final inspection. Ready for C/O subject to electrical and FIRE Dept C/O for

Inspection Record		Date
Type		
Foundation:	_____	_____
Framing:	_____	_____
Plumbing:	_____	_____
Final:	_____	_____
Other:	_____	_____



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 105 India St

CBL 020 A008001

Issued to Maps /SF Flynn-Z

Date of Issue 10/01/2001

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 01-0171, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

4 Unit Structure
With Office on 1st floor
Use Group: R2 Type: 3B Construction

Limiting Conditions:

None

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.