COMMENTS

10-19: Inspected Property – Found wiring repairs needed in utility Room & BALASTERS NEEDED FOR Common STAIRWELLS & RAILING NEEDED AT ARCH OUTSIDE OF UTILITY Room.

10:14: RE-INSPECTED & FOUND ABOVE LISTED ISSUES CORRECTED. APPROVED CHANGE OF USE FROM 2 FAMILY W/ OFFICE IN BASEMENT TO 3 FAMILY ONLY.

AKW.

CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 24 MONTFORT STREET 020-B-001

Issued to **DENNIS MARTIN** Date of Issue **NOV. 15 2000**

This is to certify that the building, premises, or part thereof, at the above location, built – altered – changed as to use under Building Permit No. **001078** , has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES	APPROVED OCCUPANCY
ENTIRE	THREE FAMILY USE GROUP R3 TYPE 5B BOCA 99

Limiting Conditions:

This certificate supersedes certificate issued

Approved: 11-15-2K A.K. Wentworth

cord

Date