

CITY OF PORTLAND
Fire Department
 380 Congress Street
 Portland, Maine 04101

Fire Inspection Violations

Business	Location	Number	Inspection Type
	0049 HANCOCK ST	66603-0-0	FP Routine Inspection
Owner/Manager	CBL	Inspector	
FITZPATRICK JOHN E	020 B013001	ERIC DUNN Shift: 002 Unit: L1	

	Type	Location	Notification Date	Target Compliance	Actual Compliance
1	60-MIN FIRE DOOR ASSEMBLIES REQ	1ST , 2ND AND 3RD FLOOR FRONT STAIRS	10/9/09	11/11/09	11-10

CITY OF PORTLAND
Fire Department
380 Congress Street
Portland, Maine 04101

11-14-09

Explanation For Violations

FIRE DOORS

A FIRE DOOR ASSEMBLY IS A LISTED AND LABELED DOOR AND FRAME; AND MUST BE SELF- OR AUTOMATIC-CLOSING. DOOR ASSEMBLIES OPENING ONTO THE SAME ATMOSPHERE AS A COMMON STAIR SHALL BE LISTED FOR 60-MINUTES. OTHERS SHALL BE LABELED FOR 20-MINUTES OR BE 1 3/4 INCHES SOLID CORE WITH 3/4 INCH FRAMES AND BE SELF- OR AUTOMATIC-CLOSING. SELF-CLOSING HINGES ARE AVAILABLE FOR RESIDENTIAL USE WHEN AT LEAST TWO ARE USED ON EACH DOOR.

Attention: Benjamin Wallace
Doing Renovations by 11-1-11

we will install 60-min fire doors 1st 2nd 3rd floor front stairs. please give us until 11-1-11 as we agreed on the phone. my husband/owner of 49 Hancock was diagnosed w/ Stage 4 cancer and is very ill at this time w/ radiation & Chemo regimen frequently. Renovations could be done earlier than agreed date if he continues to improve at the rate he has.

Thank you,
Cindy Fitzpatrick
749-2782

Questions Call-