



Ann Machado <amachado@portlandmaine.gov>

49 Hancock Street - Revision 1- Permit #201500151

Liv Chase <livchase@yahoo.com>

Fri, Apr 15, 2016 at 11:03 AM

Reply-To: Liv Chase <livchase@yahoo.com>

To: Ann Machado <amachado@portlandmaine.gov>

Hi Ann,

Please see attached admin updated sheet with today's date. In regards to average grade plan. Elevation heights for each corner of the building were determined based on the existing grade. The four elevation heights as denoted on the site plan are: 53.89, 53.89, 52.2, 52.5. The average grade was determined by adding these 4 numbers together and dividing by four. The average grade plan is 53.12.

Let me know if you have any other questions.

Thanks,

Liv Chase

From: Ann Machado <amachado@portlandmaine.gov>

To: Liv Chase <livchase@yahoo.com>

Cc: Brent Adler <brentadler@gmail.com>

Sent: Friday, April 15, 2016 10:38 AM

Subject: Re: 49 Hancock Street - Revision 1- Permit #201500151

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.



updatedadmin.pdf

508K