

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

CATAMONT PROPERTIES LLC

Located at

45 HANCOCK ST

PERMIT ID: 2017-00378

ISSUE DATE: 07/19/2017

CBL: 020 B014001

has permission to **Renovating and expanding upper story with dormers and addition, creating one additional dwelling unit for a total of 6 units in the building. Construct rooftop decks.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Six dwelling units

Building Inspections

Use Group: R-2 Type: 3B
Residential Apartments (6 units)
Occupant Load = 25
NFPA 13 R sprinkler system
Floors 3, 4 & roof
MUBEC/IBC 2009

Fire Department

Classification:
Apartment Building
ENTIRE
NFPA 101 CH# 31

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Certificate of Occupancy/Final Inspection

Final - Electric

Final - Fire

Framing Only

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00378	Date Applied For: 03/30/2017	CBL: 020 B014001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: 6 dwelling units	Proposed Project Description: Renovating and expanding upper story with dormers and addition, creating one additional dwelling unit for a total of 6 units in the building. Construct rooftop decks.			
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 04/05/2017 Note: IS-FBC zone, UN subdistrict Ok to Issue: <input checked="" type="checkbox"/> No minimum lot area/DU Off-street parking - plan shows 6 spaces Dormer/upper story expansion OK per Planning IS-FBC review Existing footprint 1,860 sf - 80% = 1,488 sf upper story floor area expansion max, 768 sf proposed - OK Max height 45', proposed 44' - OK Conditions: 1) This property shall remain six dwelling units. Any change of use shall require a separate permit application for review and approval. 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Jeanie Bourke Approval Date: 07/18/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Window sills in locations more than 72 inches from finished grade shall be a minimum of 24 inches above the finished floor of the room, unless a window fall prevention devices is installed in accordance with section IRC Sec. R612.3 or IBC Sec. 1405.13.2. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 3) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery. 4) All existing fire separation partitions, barriers and horizontal assemblies at adjacent occupancies or dwelling units shall be maintain for rating and continuity. Additional materials may need to be added for compliance. 5) All penetrations shall maintain the fire resistance rating of walls and ceilings with approved firestop materials, including electrical fixtures and exhaust vents per IBC Sec. 713 and IRC Sec. R302.4 6) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings undergoing alterations, hard wired to the electrical system. Interconnection is required, where permanent wiring is feasible, which shall be verified upon inspection. 7) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
Dept: Fire Status: Approved w/Conditions Reviewer: Jason Grant Approval Date: 06/01/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas. 1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas 2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.				

- 2) All construction shall comply with City Code, Chapter 10.
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters
All construction shall comply with 2009 NFPA 1, Fire Code.
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).
All means of egress to remain accessible at all times.
- 3) A separate City of Portland Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.
The Fire Alarm installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations; NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine
- 4) A separate City of Portland Water-Based Fire Suppression System Permit is required for all new sprinkler systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.
Sprinkler system installation shall comply with 2016 NFPA 13R.
- 5) City of Portland Code Chapter 10 section 10-18 (h) All structures with a life safety signaling system (fire alarm) or a fire suppression system (sprinkler) shall have a Knox Box. All keys required to access the building and operate the fire alarm or suppression system shall be maintained in the box.
- 6) The means of egress shall be illuminated and marked in accordance with 2009 NPFA 101, sections 7.8 and 7.10.
7.8.1.3 The minimum illumination of the egress path for stairs shall be at least 10 ft-candle and the minimum illumination of the egress path of floors and other walking surfaces other than stairs shall be at least 1 ft-candle.
- 7) Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. The quantity, size, type and location shall be in accordance with NFPA 1, 13.6.8.
For light or ordinary hazard buildings a 2-A rated extinguisher (5lb. Dry Chemical Ext.) is required no more than 75 feet of travel distance from anywhere in the building and at least 1 extinguisher per story.