



PERMIT ISSUE - 09/27/07

NO.	REVISION	DATE
SCALE: 3/32"=1' 0"		
DATE: 09/27/07	DRAWN BY: GCH	CHECKED BY: DAH

92467

**R. W. Sullivan Engineering**  
HVAC, Electrical, Plumbing, Fire Protection, Code  
 The Service Center  
 520 Main Street, Suite 203  
 Boston, Massachusetts 02129-1107  
 Phone: (617) 524-8277  
 Fax: (617) 524-8216  
 www.rwsusa.com  
 RWS Job No. 2273.00

PROJECT  
**RESIDENCE INN  
 BY MARRIOTT**  
 PORTLAND, ME  
 JOB# 802

TITLE  
**LIGHTING PLAN  
 THIRD AND  
 FOURTH FLOORS**

GROUP ONE  
 21 W. THIRD STREET, BOSTON, MA 02127  
 TEL: (617)268-7000 FAX: (617)268-0209

DRAWING NO.  
**E1.03**

- LIGHTING PLAN NOTES:**
1. REFER TO DRAWING E0.01 FOR LEGEND & GENERAL NOTES.
  2. LIGHT FIXTURES SHALL BE INSTALLED AT MOUNTING HEIGHTS AND LOCATIONS AS INDICATED ON THE ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, PART PLANS AND DETAILS. CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR INFORMATION.
  3. CIRCUIT NUMBERS ARE SHOWN FOR DESCRIPTIVE PURPOSES ONLY. EXACT NUMBERS SHALL BE DETERMINED IN FIELD AND SHALL BE NOTED ON THE CONTRACTOR'S AS-BUILT DRAWINGS.
  4. EXIT SIGNS, FIXTURES DESIGNATED AS NIGHT LIGHTS AND EMERGENCY BATTERY UNITS SHALL BE CONNECTED TO AN UNSWITCHED, CONSTANT 'ON' SOURCE AS INDICATED. THE ASSOCIATED CIRCUIT BREAKER SHALL BE PROVIDED WITH A HANDLE LOCK.
  5. BRANCH CIRCUIT CONDUCTORS SHALL BE SIZED AND INSTALLED FOR A MAXIMUM VOLTAGE DROP OF 3%. CONTRACTOR SHALL PROVIDE #10AWG CONDUCTORS FOR ALL 120 VOLT CIRCUITS GREATER THAN 60 FEET IN LENGTH. CONTRACTOR SHALL PROVIDE #8AWG CONDUCTORS FOR ALL 120 VOLT CIRCUITS GREATER THAN 100 FEET, BUT LESS THAN 160 FEET IN LENGTH. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS AND OPTIONS.