



PERMIT ISSUE - 09/27/07

NO.	REVISION	DATE
SCALE: 3/32"=1' 0"		
DATE: 09/27/07		
	DRAWN BY: GCH	CHECKED BY: DAH

STATE OF MAINE
MICHAEL DAVID TRICKETT
No. 9760

RWS
R. W. Sullivan Engineering
The Small Center
520 Main Street, Suite 203
Boston, Massachusetts 02129-1107
Phone: (617) 523-8222
Fax: (617) 523-8216
www.rwsinc.com
RWS Job No. 2273.00

PROJECT
RESIDENCE INN BY MARRIOTT
PORTLAND, ME
JOB# 802

TITLE
LIGHTING PLAN FIFTH FLOOR

GROUP ONE
21 W. THIRD STREET, BOSTON, MA 02127
TEL (617)268-7000 FAX: (617)268-0209

DRAWING NO.
E1.04

- LIGHTING PLAN NOTES:**
- REFER TO DRAWING E0.01 FOR LEGEND & GENERAL NOTES.
 - LIGHT FIXTURES SHALL BE INSTALLED AT MOUNTING HEIGHTS AND LOCATIONS AS INDICATED ON THE ARCHITECTURAL REFLECTED CEILING PLANS, ELEVATIONS, PART PLANS AND DETAILS. CONTRACTOR SHALL REFER TO THE ARCHITECTURAL DRAWINGS FOR INFORMATION.
 - CIRCUIT NUMBERS ARE SHOWN FOR DESCRIPTIVE PURPOSES ONLY. EXACT NUMBERS SHALL BE DETERMINED IN FIELD AND SHALL BE NOTED ON THE CONTRACTOR'S AS-BUILT DRAWINGS.
 - EXIT SIGNS, FIXTURES DESIGNATED AS NIGHT LIGHTS AND EMERGENCY BATTERY UNITS SHALL BE CONNECTED TO AN UNSWITCHED, CONSTANT 'ON' SOURCE AS INDICATED. THE ASSOCIATED CIRCUIT BREAKER SHALL BE PROVIDED WITH A HANDLE LOCK.
 - BRANCH CIRCUIT CONDUCTORS SHALL BE SIZED AND INSTALLED FOR A MAXIMUM VOLTAGE DROP OF 3%. CONTRACTOR SHALL PROVIDE #10AWG CONDUCTORS FOR ALL 120 VOLT CIRCUITS GREATER THAN 60 FEET IN LENGTH. CONTRACTOR SHALL PROVIDE #8AWG CONDUCTORS FOR ALL 120 VOLT CIRCUITS GREATER THAN 100 FEET, BUT LESS THAN 160 FEET IN LENGTH. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS AND OPTIONS.

LIGHTING PLAN - FIFTH FLOOR
3/32" = 1'-0"