

LIGHTING FIXTURE SCHEDULE

FIXTURE TYPE	DESCRIPTIONS	LIGHT FIXTURE ACCEPTABLE MANUFACTURERS AND CATALOG NUMBER		LAMPS		FIXTURE TOTAL WATTAGE	MOUNTING	VOLTAGE	NOTES	FIXTURE TYPE	DESCRIPTIONS	LIGHT FIXTURE ACCEPTABLE MANUFACTURERS AND CATALOG NUMBER		LAMPS		FIXTURE TOTAL WATTAGE	MOUNTING	VOLTAGE	NOTES
		MANUFACTURER	CATALOG NUMBER	QTY.	TYPE							MANUFACTURER	CATALOG NUMBER	QTY.	TYPE				
D04	14" DIA. CEILING MOUNTED DOME LIGHT FIXTURE	ASHLEY LIGHTING	73026-OW3-0100	1	FT40W/2611/830/835/841	40W	CEILING	120V	LF12	R01	5" DIA. RECESSED DOWNLIGHT	LIGHTOLIER	100_2FU1/1046	1	CF013W/G240/827/830/835/841	13W	RECESSED	120V	
D08	CEILING TRACK LIGHTING	LIGHTOLIER	9104HH	1		50W	CEILING	120V	LF12	R02	6 3/4" DIA. RECESSED DOWNLIGHT	LIGHTOLIER	1100_FTU/1146	1	26W OR 32W TRIPLE TUBE	26/32W	RECESSED	120/277V	
D09	CHANDELIER	REFER TO D05A/D05B					CEILING			R06	6 3/4" DIA. RECESSED DOWNLIGHT	LIGHTOLIER	1102_PI/1146	1	150W A-21	150W	RECESSED	120V	
D28	WALL MOUNTED 150W CERAMIC METAL HALIDE SCIENCE	INSIGHT LIGHTING	WT-527-IBB-1-TW-WPVS	1		150W	WALL	120V		R07	6 3/4" DIA. RECESSED DOWNLIGHT	LIGHTOLIER	1102PI/1148	1	90W PAR 38 NFL	75W	RECESSED	120V	
D62	18" DIA. CEILING MOUNTED DOME LIGHT FIXTURE	ASHLEY LIGHTING	73007-OW3-0100	1	FT40W/2611/830/835/841	40W	CEILING	120V		R09	5" DIA. RECESSED DOWNLIGHT	LIGHTOLIER	1002_PI/1013	1	75 PAR 30 FLOOD	75W	RECESSED	120V	
D63	6 3/8" DIA. WALL MOUNTED LAMP	ASHLEY LIGHTING	71019-OW5-0100	1	13W SPRING LAMP 2-PIN	60W	WALL	120V		R11	RECESSED DOWNLIGHT	LIGHTOLIER	16FR2X10/1002E1/1046	1	CF013W/G240/827/830/835/841	13W	RECESSED	120/277V	
D64	CEILING PENDANT	KICHLER LIGHTING	34206	1			CEILING	120V		R27	3 3/4" RECESSED DOWNLIGHT	LIGHTOLIER	2011-2000MCV-16FR2X10	1	20W-35W MR16	35W	RECESSED	120V	
D65	WALL VANITY LIGHTING FIXTURE	CHALLENGER LIGHTING	VA2463-00	2	F25TB/SP30X 30-25W	100W	WALL	120V		R29	3" APERTURE RECESSED DOWNLIGHT	LIGHTOLIER	CSLV/C3MRACLW	1	MR 16 FL	50W	CEILING	120V	
D66	UNDER CABINET HI-LOW-OFF ROCKER	KICHLER LIGHTING	10581WH	3	18W	54W	UNDER CABINET	120V		T03	4" DIA. CEILING MOUNTED DOWNLIGHT	TECHNICAL CONSUMER PRODUCTS	11730/32W-HP	1	26W	26W	CEILING	120V	
D75	14" DIA. CEILING MOUNTED FIXTURE	ASHLEY LIGHTING	73013-OW3-0100	1	FT40W/2611/830/835/841	100W	CEILING	120V		T03A	4" DIA. CEILING MOUNTED DOWNLIGHT	TECHNICAL CONSUMER PRODUCTS	11730/32WH-HP	1	32W CIRCLELINE (P/N 32032)	32W	CEILING	120V	
D75A	14" DIA. CEILING MOUNTED FIXTURE	ASHLEY LIGHTING	73016-QV1-0010Z	2	18W BI-PIN	36W	CEILING	120V		X01	LED EXIT SIGN	LIGHTOLIER	LDSNU (R OR G) WITH BATTERY LDSAU (R OR G) WITH BATTERY		LED COMES W/ FIXTURE	2W	UNIVERSAL	120V	
D76	4" DIA. ROUND FLUSH CANOPY PENDANT	LBL LIGHTING	HS-240-OP-SC-1B-35-MET/CK0011-FI-SC	1		35W	CEILING	120V		X02	LED EXIT SIGN	LIGHTOLIER	LDSNU (R OR G) WITH BATTERY LDSAU (R OR G) WITH BATTERY		LED COMES W/ FIXTURE	2W	UNIVERSAL	120V	
D77	4" DIA. WALL MOUNTED LAMP	ASHLEY LIGHTING	71026-OW5-0100	2	13W 2-PIN	100W	WALL	120V		X03	E3 SERIES EMERGENCY LIGHT	LIGHTOLIER	E3_1_1BL_2_S9_W	2	9W	18W	WALL	120V	
D92	4 1/4" DIA. WALL MOUNTED LAMP	ASHLEY LIGHTING	71068-052-0100	2	F25/TBSP30	50W	WALL	120V		Z01	FLOOD LIGHT	HADCO LIGHTING	1020_H/B12	1	90 PAR 38	90W	STAKE	120V	
F05	2'X2' RECESSED LIGHT FIXTURE	LIGHTOLIER	DPA 26 9LP 3ET-120V-X3	3	FT40W/2611/830/835/841	117W	RECESSED	120V		Z04	SITE LIGHT	EXCELINE	SMR-404-MA-8	1	400W MH	400W	POLE	120V	
F07	CORRIDOR LUMINAIRE	LIGHTOLIER	JS4_C232_120-S0	2	F0327B	70W	SURFACE	120V		Z05	WALL MOUNTED SCIENCE	KICHLER LIGHTING	MS-9368AGZ	1	PLS 18 WATT G240-2	18W	WALL	120V	
F09	2'X4" RECESSED FLUORESCENT TROFFER	LIGHTOLIER	SPS 26 FSVA 432-120-04	4	F0327B	70W	RECESSED	120V		Z06	WALL MOUNTED SCIENCE	KICHLER LIGHTING	MS-9367AGZ	1	PLS 18 WATT G240-2	18W	WALL	120V	
F09A	2'X4" RECESSED FLUORESCENT TROFFER	LIGHTOLIER	DPA 2S 18LS 332-120-03	3	F0327B	70W	RECESSED	120V		Z07	DECORATIVE LIGHTING	HADCO LIGHTING	S-5884-N	1	150 MH	150W	POST ZOB	120V	
F13	STAGGERED STRIP SURFACE FLUORESCENT	LIGHTOLIER	SS 2S 217 HPF 120_S0	2	17W T8	34W		120V		Z08	POLE FOR 207	HADCO LIGHTING	SP-5884-N				CONC. PAD	N/A	
F17	3.75" DIA. STRIP LIGHT	SCOTT LAMP CO	3702-26-BC	2	17Bx24"L -WARM	34W	SURFACE	120V		Z14	POLE	LYTEPOLES	101-5011-30-DB				CONC. PAD	N/A	
F18	3.75" DIA. STRIP LIGHT	SCOTT LAMP CO	3702-50-BC	2	32TBx48"L -WARM	64W	SURFACE	120V		Z15	POLE	LYTEPOLES	101-5011-25-DB				CONC. PAD	N/A	
F24A	NARROW WIDTH CHANNEL STRIP LIGHT	LIGHTOLIER	SN 4S 132 HPF-120-S0	1	F032/830XP /ECO T8 OCTRON	34W	UNDERCABINET	120V		Z24	POLE AND LIGHT	SPORT COURT, INC.						N/A	
F24B	NARROW WIDTH CHANNEL STRIP LIGHT	LIGHTOLIER	SN 3S 125 HPF-120-S0	1	F025/830XP /ECO T8 OCTRON	28W	UNDERCABINET	120V		Z25	ARCHITECTURAL WALLPACK UPLIGHT	EXCELINE	GXSM42-HF-W-HW-8	1	42 WATT	42W	22 DEG UP	277V	
F24C	NARROW WIDTH CHANNEL STRIP LIGHT	LIGHTOLIER	SN 2S 117 HPF-120-S0	1	F017/830XP /ECO T8 OCTRON	21W	UNDERCABINET	120V		003								120V	
F24D	NARROW WIDTH CHANNEL STRIP LIGHT	LIGHTOLIER	SN 1S 115 HPF-120-S0	1	T8	15W	UNDERCABINET	120V											
F26	STANDAR STRIP WIDE LIGHT	LIGHTOLIER	SW 4S 232 HPF 120_S0	2	T8-32W	64W	WALL	120V-277V											

LIGHTING FIXTURE SCHEDULE NOTES:

(LIGHTING FIXTURE NOTES LF1 THRU LF7 ARE NOT LISTED ON THE SCHEDULE BUT ARE TYPICAL AND APPLY TO ALL LIGHT FIXTURES)

LF1. REFER TO ARCHITECT'S REFLECTED CEILING PLANS AND ELEVATIONS FOR FINAL LOCATIONS AND MOUNTING HEIGHTS OF ALL FIXTURES.

LF2. CATALOG NUMBERS INDICATED ARE FOR REFERENCE ONLY. CONTRACTOR IS RESPONSIBLE FOR FINAL FIXTURE COORDINATION AND INSTALLATION. CONTRACTOR SHALL PROVIDE ALL ACCESSORIES REQUIRED FOR INSTALLATION OF LIGHT FIXTURES INCLUDING, BUT NOT LIMITED TO, BAR HANGERS, SWIVEL STEM HANGERS, PENDANTS, END CAPS, CONNECTORS, MOUNTING BOXES, MOUNTING CLIPS.

LF3. COORDINATE LIGHTING FIXTURE INSTALLATION AND TRIM KIT WITH CEILING TYPE. PROVIDE FRAME KIT AS REQUIRED TO INSTALL FIXTURE IN CEILING TYPE.

LF4. ALL FLUORESCENT LAMPS SHALL HAVE A MINIMUM CRI RATING OF 82.

LF5. FINAL FINISHES AND COLORS OF ALL LIGHT FIXTURES SHALL BE APPROVED BY ARCHITECT AND LIGHTING DESIGNER.

LF6. ALL FIXTURES SHALL BE SUPPORTED FROM THE BUILDING STRUCTURE BY THREADED ROD OR CHAIN. REFER TO THE SPECIFICATIONS FOR METHOD. SUPPORTING FIXTURES FROM HUNG CEILING IS NOT ALLOWED.

LF7. ALL INCANDESCENT LAMPS SHALL BE SOFT-WHITE TYPE, DOUBLE-LIFE TYPE.

(LIGHTING FIXTURE NOTES LF8 THRU LF15 APPLY ONLY WHERE NOTED ON FIXTURE SCHEDULE)

LF8. NUMBER OF FACES, DIRECTIONAL ARROWS AND MOUNTING AS SHOWN ON THE PLAN.

LF9. COORDINATE TASK LIGHT FIXTURE INSTALLATION WITH CASEWORK AS DETAILED ON ARCHITECTURAL DRAWINGS.

LF10. PROVIDE REQUIRED NUMBER OF BALLASTS TO ACCOMMODATE LIGHTING FIXTURES WITH MULTI-LEVEL SWITCHING AS INDICATED ON FLOOR PLANS.

LF11. COORDINATE AND VERIFY PENDANT LENGTHS WITH ARCHITECT PRIOR TO INSTALLATION FOR REQUIRED MOUNTING HEIGHTS OF PENDANT FIXTURES.

LF12. FIXTURE SHALL BE U.L. WET LOCATION LISTED.

LF13. FIXTURE SHALL BE U.L. DAMP LOCATION LISTED.

LF14. PROVIDE ELECTRONIC DIMMER BALLAST AS MANUFACTURED BY LUTRON, HI-LUME MODEL FOR 1% DIMMING RATING ONLY. COORDINATE WITH FLUORESCENT DIMMING CONTROL SWITCHES, LIGHT FIXTURE AND/OR SYSTEM FOR A COMPLETE AND OPERABLE SYSTEM. ONLY LUTRON HI-LUME DIMMING BALLASTS ARE ACCEPTABLE.

LF15. REFER TO CIVIL AND LANDSCAPE SITE PLANS FOR FINAL SITE LIGHT FIXTURE LOCATIONS.

PERMIT ISSUE - 09/27/07

NO.	REVISION	DATE
-----	----------	------

SCALE: NONE DRAWN BY: GCH
DATE: 09/27/07 CHECKED BY: JCL

	<p>R. W. Sullivan Engineering HVAC, Electrical, Plumbing, Fire Protection, Code The Small Center 529 Main Street, Suite 203 Boston, Massachusetts 02129-1107 Phone: (617) 524-8221 Fax: (617) 524-8016 www.rwsusa.com RWS Job No. 2273.00</p>
--	--

PROJECT

RESIDENCE INN BY MARRIOTT

PORTLAND, ME

JOB# 802

TITLE

ELECTRICAL SCHEDULES

GROUP ONE
 21 W. THIRD STREET, BOSTON, MA 02127
 TEL: (617)268-7000 FAX: (617)268-0209

DRAWING NO.

E6.01