


ULTRASONIC INSPECTION REPORT

CUSTOMER: SW COLE GRAY OFFICE		DATE OF INSPECTION	M	D	Y
		06	09	08	
ATTENTION:		REPORT No.	QAL-08-1085		
PROJECT: MARRIOTT HOTEL		PAGE	1	OF	1
COMPONENT INSPECTED: 2ND FLOOR FRAMING		JOB No.	06-0726		
AREA OF INTEREST: MOMENT CONNECTIONS		P.O. No.	VERBAL		
COMPONENT LOCATION: PORTLAND, ME		INSTRUMENT			
CUSTOMER WORK ORDER No: N/A	PART No.: N/A	MAKE: PANAMETRICS			
MATERIAL: CARBON STEEL	HEAT No.: N/A	MODEL: LTC			
COMPONENT SURFACE CONDITION: AS WELDED		EQUIPMENT No.:			
EXAMINATION DATA		MATERIAL THICKNESS: 12.7 mm (0.500 in.)			
Project Code/Spec: AWS D1.1		SCREEN RANGE: 10"			
U.T. Procedure No.		U.T. Technique No.			
RESULTS: AS NOTED		INDICATIONS: NONE			
REMARKS: PERFORMED ULTRASONIC INSPECTIONS ON 2ND FLOOR FRAMMING MOMENT CONNECTIONS IAW AWS.D1.1. GRID LINES: 12 MOMENT CONNECTION W THRU N LINES 23 TO 29 TOP & BOTTOM //LAST ITEM <p style="text-align: center;">FAA REPAIR STATION NUMBER RX5R187N METHOD(S),PROCESS(ES),PROCEDURE(S) MERCURY FREE</p>		TRANSDUCERS			
		MAKE: PANAMETRICS			
		FREQ.: 2.25 MHz		ANGLE: 70°	
		SIZE: 12.7 mm (0.500 in.)			
		STYLE: SINGLE		SHAPE: SQUARE	
		EQUIPMENT No.:			
		MAKE: PANAMETRICS			
		FREQ.: 2.25 MHz		ANGLE: 0°	
		SIZE: 25.4 mm (1.000 in.)			
		STYLE: SINGLE		SHAPE: ROUND	
EQUIPMENT No.:					
MAKE:					
FREQ.:		ANGLE:			
SIZE:					
STYLE:		SHAPE:			
EQUIPMENT No.:					
REFERENCE BLOCKS					
MAKE: PANAMETRICS					
TYPE: IIW					
MATERIAL: CARBON STEEL					
EQUIPMENT No.:					
SENSITIVITY: 66.3db - 6db					
TRANSFER VALUE:					
ADDITIONAL INFORMATION - SEE ATTACHED:		<input type="checkbox"/> SKETCH(ES) <input checked="" type="checkbox"/> SUPPLEMENTARY SHEET(S) <input type="checkbox"/> VIDEO			
SIGNATURES		CERTIFICATION		DATE	
INSPECTOR S. DYER 		ASNT II		06 09 08	
SUPERVISOR					
AUTHORIZED INSPECTOR					
CUSTOMER REPRESENTATIVE					

RSD