Portland, Maine



Yes. Life's good here.

March 17, 2016

FILIPOS DAVID P

36 FEDERAL ST #3

PORTLAND, ME 04101

CBL: 020 D002001

Located at 36 FEDERAL ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

| Owner/Manager FILIPOS DAVID P | | | | Inspector Alan Greene | | Inspection Date | |
|----------------------------------|--|---|------------|--------------------------|---------------|--------------------------------|--|
| | | | | | | 3/16/2016 | |
| Location | | CBL | | Status | | Inspection Type | |
| 36 FEDERA | LST | 020 🗅 | 002001 | Failed | | Fire Company-FP Routine Inspec | |
| Code | Option and the second s | Int/Ext | Floor | Unit No. | Area | Compliance Date | |
| 1) 4.001 | | Interior | | | Basement | | |
| Violation: | NFPA 101- 8.7.3.1 AND 8.7.3.2 FUEL POWERED DEVICE STORED INSIDE; The storage and handling of flammable liquids or gases shall be in accordance with the following applicable standards: NFPA 30, Flammable and Combustible Liquids Code NFPA 54, National Fuel Gas Code NFPA 58, Liquefied Petroleum Gas Code (8.7.3.1). No storage or handiling of flammable liquids or gases shall be permitted in any location where such storage would jeopardize egress from the structure, unless otherwise permitted by 8.7.3.1 (8.7.3.2) CHAIN SAW AND LAWN MOWER STORED IN BASEMENT. | | | | | | |
| 2) 5.005 | | Interior | | | Basement | | |
| Violation: | NFPA 58- 8.3.1 L.P.G. STORED INSIDE EXCEEDS LIMITS; STORAGE OF CYLINDERS IN BUILDINGS SHALL BE IN ACCORDANCE WITH TABLE 8.3.1(A) OR TABLE 8.3.1(B) OR THE REQUIREMENTS OF SECTION 8.3 | | | | | | |
| Notes: | 20 LB I | PROPANE CYL | INDER IN I | BASEMENT | | | |
| 3) 2.140 | | Exterior | | | Cellar Stairs | | |
| Violation: | NFPA 1- 10.1.1 STRUCTURE NEEDS REPAIR; Every new and existing building or structure shall be constructed, arranged, equipped, maintained, and operated in accordance wih this code so as to provide a reasonable level of life safety, property protection, and public welfare from the actual and potential hazards created by fire, explosion, and other hazradous conditions. | | | | | | |
| Notes: | REAR | REAR STAIRS TO BASEMENT, TOP STEP MISSING | | | | | |
| Commonte: | | | | | | | |

Comments:

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

David Filipos Defendant

SUMMONS NUMBER:

354539

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 05/09/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 05/09/2016.

Dated: 3/25/6

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Counsel

City of Portland 389 Congress St Portland, ME 04101 207-874-8480