


|                               |  |                      |  |   |  |  |  |
|-------------------------------|--|----------------------|--|---|--|--|--|
| Location of Construction:     |  | Owner:               |  | Phone:  |  | Permit No:<br><b>980361</b>  |  |
| Owner Address:                |  | Lessee/Buyer's Name: |  | Phone:  |  | BusinessName:  |  |
| Contractor Name:              |  | Address:             |  | Phone:  |  | <div style="border: 2px solid black; padding: 5px;"> <b>PERMIT ISSUED</b><br/>  </div>  |  |
| Past Use:                     |  | Proposed Use:        |  | <b>COST OF WORK:</b><br>\$ _____<br><b>PERMIT FEE:</b><br>\$ _____  |  |  |  |
| Proposed Project Description: |  |                      |  | <b>FIRE DEPT.</b> <input checked="" type="checkbox"/> Approved<br><input type="checkbox"/> Denied<br>Signature: _____   |  | <b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b><br>Action: Approved <input type="checkbox"/><br>Approved with Conditions: <input type="checkbox"/><br>Denied: <input type="checkbox"/><br>Signature: _____ Date: _____  |  |
|                               |  |                      |  | Zoning Approval:<br><b>Special Zone or Reviews:</b><br><input type="checkbox"/> Shoreland<br><input type="checkbox"/> Wetland<br><input type="checkbox"/> Flood Zone<br><input type="checkbox"/> Subdivision<br><input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm |  | <b>Zoning Appeal</b><br><input type="checkbox"/> Variance<br><input type="checkbox"/> Miscellaneous<br><input type="checkbox"/> Conditional Use<br><input type="checkbox"/> Interpretation<br><input type="checkbox"/> Approved<br><input type="checkbox"/> Denied |  |
| Permit Taken By:              |  | Date Applied For:    |  | <b>Historic Preservation</b><br><input type="checkbox"/> Not in District or Landmark<br><input type="checkbox"/> Does Not Require Review<br><input type="checkbox"/> Requires Review  |  | <b>Action:</b><br><input type="checkbox"/> Approved<br><input type="checkbox"/> Approved with Conditions<br><input type="checkbox"/> Denied<br>Date: _____   |  |

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..


PERMIT ISSUED WITH REQUIREMENTS

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

|   |          |       |        |
|---|----------|-------|--------|
| SIGNATURE OF APPLICANT                      | ADDRESS: | DATE: | PHONE: |
| RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE |          |       | PHONE: |

CEO DISTRICT



COMMENTS

8/25/99 insp. w/ Arthur and Contractor Peter Reynolds. regarding stairs / railing rise & run good except top step (9" rise, nosing not acceptable.

Peter had questions on guardrail/handrail height, we will get back to him on code requirements for this use group "B"

Guardrail 36" - handrail 30"-38" Tried to contact Peter Thru. Janet Demons at office several times in 2 weeks since insp. - no reply from Peter. (JTB)

10/20 Met On Site with Peter Reynolds discuss handrail/guardrail ok as Proposed, require top rise to be reconfigured (DC)

4/16/98 Checked framing started brislatting checked Plumbing rough in ok

5/15/98 Electricaly started OK to close in good  
6/19/2000 Completed. All

98-0361

020-D-010

Inspection Record

| Type        | Date  |
|-------------|-------|
| Foundation: | _____ |
| Framing:    | _____ |
| Plumbing:   | _____ |
| Final:      | _____ |
| Other:      | _____ |