



SECOND FLOOR FRAMING PLAN

3/16"=1'-0"

NOTES:

- INDICATES SPAN DIRECTION OF 3/4" T&G APA RATED FLOOR SHEATHING
- H1, H2, ETC. INDICATES STRUCTURAL HEADER. REFER TO SCHEDULE, THIS DRAWING
- INDICATES INTERIOR STUD BRG WALL BELOW
- BLOCK SOLID BELOW ALL POSTS FOR CONTINUOUS LOAD PATH TO SUPPORTING MEMBER/FOUNDATION BELOW
- FOR TOP OF STEEL ELEVATION, SEE PLAN.
- ALL HARDWARE USED IN CONJUNCTION WITH P.T. WOOD SHALL BE MANUFACTURED BY SIMPSON STRONG-TIE INC & SHALL BE Z MAX COATED OR STAINLESS STEEL
- 5.25 PSL INDICATES 5 1/4"x5 1/4" PSL POST
- DF INDICATES DOUGLAS FIR. ALL DOUGLAS FIR FOR EXT DECK CONSTRUCTION SHALL BE NO.1 OR BETTER
- TRUSSES SHALL BE DESIGNED FOR THE FOLLOWING LOADS:
TC DL = 11 PSF
TC LL = 40 PSF
BC DL = 5 PSF
BC LL = 0 PSF
- INDICATES MOMENT CONNECTION. SEE DETAILS DWG S1.6.
- BP-1, BP-2, ETC INDICATES COL BASE PLATE TYPE. SEE DETAILS DWG S1.6.

HEADER SCHEDULE		
MARK	SIZE	TRIMMER (U.N.O.)
H26	(2) 2x6	(1) 2x6
H36	(3) 2x6	(1) 2x6
H39	3 1/2"x9 1/2" PSL	(2) 2x6
H14	1 3/4"x14 LVL	-
H312	(3) 2x12	(2) 2x6

HANGER SCHEDULE	
JOIST/BM/HDR	SIMPSON HGR
1 3/4"x14 LVL	MIT1.B1/14
3 1/2"x14 LVL	MIT414
2x8	LUS28
6x12	HU612TF

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND SHALL REMAIN THE PROPERTY OF BECKER STRUCTURAL ENGINEERS INC. IT SHALL NOT BE REPRODUCED, COPIED, LENT OR DISPOSED OF DIRECTLY OR INDIRECTLY NOR USED FOR ANY PURPOSE OTHER THAN FOR WHICH IT IS SPECIFICALLY FURNISHED AND MUST BE RETURNED TO BECKER STRUCTURAL ENGINEERS INC. ON COMPLETION OF WORK, IF REQUESTED.

Approved	
Issued For	ISSUED FOR CONSTRUCTION
Date	09/14/05
Rev. No	

FEDERAL ST TOWNHOMES
44 Federal Street
Portland, Me.

Designed	Scale	NOTED
Drawn	Date	09/14/2005
Checked	Becker Job Number	1330
PBB		

S1.2