



THIRD FLOOR FRAMING PLAN

3/16"=1'-0"

NOTES:

1. INDICATES SPAN DIRECTION OF 3/4" T&G APA RATED FLOOR SHEATHING
2. H1, H2, ETC. INDICATES STRUCTURAL HEADER. REFER TO SCHEDULE, THIS DRAWING
3. INDICATES STUD BRG WALL BELOW
4. BLOCK SOLID BELOW ALL POSTS FOR CONTINUOUS LOAD PATH TO SUPPORTING MEMBER/FOUNDATION BELOW
5. FOR TOP OF STEEL ELEVATION, SEE PLAN.
6. ALL HARDWARE USED IN CONJUNCTION WITH P.T. WOOD SHALL BE MANUFACTURED BY SIMPSON STRONG-TIE INC & SHALL BE Z MAX COATED OR STAINLESS STEEL
7. 5.25 PSL INDICATES 5 1/4"x5 1/4" PSL POST
8. TRUSSES SHALL BE DESIGNED FOR THE FOLLOWING LOADS:
 TC DL = 11 PSF
 TC LL = 40 PSF
 BC DL = 5 PSF
 BC LL = 0 PSF
9. INDICATES MOMENT CONNECTION. SEE DETAILS DWG S1.6.

HEADER SCHEDULE		
MARK	SIZE	TRIMMER (U.N.O.)
H26	(2) 2x6	(1) 2x6
H36	(3) 2x6	(1) 2x6
H39	3 1/2x9 1/2 PSL	(2) 2x6
H14	1 3/4x14 LVL	-
H312	(3) 2x12	(2) 2x6

HANGER SCHEDULE	
JOIST/BM/HDR	SIMPSON HGR
1 3/4x14 LVL	MIT1.81/14
3 1/2x14 LVL	MIT414
2x8	LUS2B
6x12	HU612TF

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND SHALL REMAIN THE PROPERTY OF BECKER STRUCTURAL ENGINEERS INC. IT SHALL NOT BE REPRODUCED, COPIED, LENT OR DISPOSED OF DIRECTLY OR INDIRECTLY NOR USED FOR ANY PURPOSE OTHER THAN FOR WHICH IT IS SPECIFICALLY FURNISHED AND MUST BE RETURNED TO BECKER STRUCTURAL ENGINEERS INC. ON COMPLETION OF WORK, IF REQUESTED.

Issued For	ISSUED FOR CONSTRUCTION
Date	09/14/05
Rev. No	

FEDERAL ST TOWNHOMES
 44 Federal Street
 Portland, Me.

Designed	Scale	NOTED
Drawn	Date	09/14/2005
Checked	Becker Job Number	1330
APP	PBB	