




NOTE: SOUND DATA CALCULATED BASED ON TWENTY (20) UNITS OPERATING SIMULTANEOUSLY AT THE SAME DISTANCE FROM THE CLOSEST BUILDING AND EACH UNIT OPERATING AT 54 dBA AT A DISTANCE OF 3.3FT.

22'-6"  
50.3 dba

95'-0"  
37.8 dba

83'-9"  
39.0 dba

41'-7"  
45.0 dba

Date: 10-30-2014		Scale: 1/8" = 1'-0"		Revisions:		Project: SEAPORT LOFTS		Consultant:  <b>BENNETT ENGINEERING</b> MECHANICAL, ELECTRICAL AND PLUMBING		Prepared For:	
ROOFTOP EQUIPMENT SOUND DATA				ISSUED FOR PERMIT				Architect: NEWBURY / HANCOCK ST., PORTLAND ME			
<b>M1.05A</b>											