

Inspection Services
Michael J. Nugent
Manager

Department of Urban Development
Joseph E. Gray, Jr.
Director



CITY OF PORTLAND

October 6, 2000

Tim Napolitano
986 Braodway
South Portland, Maine 04105

Re: 125 Newbury Street: Dangerous location of electrical service entrance cables
CBL: 020-D-023

Dear Mr. Napolitano,

During an inspection of the above listed property, it was determined that the location of the service entrance cables passing in close proximity to the basement door puts them in a potentially dangerous status. As per the Portland City Ordinance the following codes apply.

Article 3, Electrical Code.

Sec. 6-34 J Services shall not be located where subject to physical damage.

Sec. 6-34 F Services installed on brick shall be in rigid conduit.

NFPA-70 Article 230-50 protection of cable against damage. Service cables shall be protected against damage.

This is a notice of violation pursuant to Section 6-118 of the Code. All referenced violations shall be corrected within 30 days of the dated of this notice. A re-inspection of the premises will occur on November 6, 2000 at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code.

Please feel free to contact Steve Wentworth @ 874-8709 if you wish to discuss the matter or have any questions.

Sincerely,

Steve Wentworth
Code Enforcement Officer

