

Exhibit 8

NFPA Code Summary



NFPA Code Overview

Use:	Assembly
Construction:	No minimum requirement
Sprinkler:	None
Occupancy:	66 Occupants

IBC Code Overview

Use:	A-2
Construction:	VB
Sprinkler:	None
Occupancy:	66 Occupants

NFPA 101

- 3.3.178.2 Assembly Occupancy

- 6.1.1.2 Assembly (Chapter 12 and 13)

- 7.1.5.1 Min headroom: 7'-6"
- 7.1.6.3 Cross Slope limited to 1:48
- 7.2.1.2.3.2 Egress door min clear width: 32"
- 7.2.1.4 Door swing and force to open shall comply with this section
- 7.2.1.5 Door locks, latches and alarms shall comply with this section
- 7.2.2.2.1.1 Max riser height: 7"

- Min Tread depth: 11"
- Min headroom: 6'-8"
- 7.2.2.2.1.2 Min stair width: 36" (for occupancy under 50)
- 7.2.2.3.2.3 Min landing depth: stair width
- 7.2.2.4.4.1 Handrail height: 36"
- 7.2.2.4.4.6 Handrail shape: 1 ½" circular cross section
- 7.2.2.4.4.9 Handrails shall return to wall or newel post
- 7.2.2.4.4.10 Handrails shall extend 12" at top of stair and one tread length at bottom
- 7.2.2.4.5.2 Min guard height: 42"
- 7.2.2.4.5.3 Open guards shall not allow the passage of a 4" sphere
- 7.2.2.5.4 Stairway identification shall comply with this section.
- 7.3.1.2 Occupancy Load
 - Assembly-Less concentrated: 15 gross at 1,000 SF is 66 occupants
- 7.4.1.1 Not less than 2 exits
- 7.5.1.3.3 Where two exits are required, they shall be located at a distance from one another not less than one-half the length of the maximum overall diagonal dimension of the building or area being served.
- 7.8 Egress Illumination shall be in accordance with this section.
- 7.9 Emergency Lighting shall be in accordance with this section.
- 7.10 Marking for means of egress shall comply with this section.

- 12.1 New Assembly Occupancy



ingenuity thoughtfulness empathy

- 12.2.3.6.2 2. Main entrance shall be of a width that accommodates one-half of the total occupant load
- 12.2.3.6.3 Main exit shall be at the level of exit discharge or shall connect to a stairway or ramp leading to a street
- 12.2.5.7.3 Aisle way to be measured in a line 19 inches measured perpendicularly to the edge of the table
- 12.2.6.2 200 ft travel distance to exit