



Associates, Inc.

One Autumn Street  
Portsmouth, NH 03801  
Tel (603)433-8639  
Fax (603)431-2811  
www.jsneng.com

December 17, 2013

City of Portland  
Planning & Urban Development Dept./ Inspections Division  
389 Congress St. Rm 315  
Portland, ME 04101  
Direct: (207) 874-8715  
Office: (207) 874-8703

Re: The Bay House, Middle Street, Portland

Subject: Car Lift Affidavit

To whom it may concern:

I certify that, to the best of my knowledge and belief, the slab-on-grade cast in the garage area of The Bay House is sufficient to support the car lifts that are proposed to be used in the garage (Harding Steel, SUV and SUV-XL), as presented to JSN Associates, Inc. by the General Contractor (Bob Grzyb, email dated 1/2/13), in that the slab is sufficient to transfer the vertical bearing loads of the lifts to the soils beneath the slab and to restrain the lateral loads of the lifts within the plate of the slab.

Sincerely,  
JSN Associates, Inc.

Jeffrey S. Nawrocki, P.E.  
President  
ME #6044

  
\_\_\_\_\_  
Notary Public

My commission expires \_\_\_\_\_

