389 Congress St.Rm 315 Portland, ME 04101 Phone: (207)874-8700 Fax: (207)874-8716

facsimile transmittal

Го:	Janet Hansen	From:	Mike Nugent	
ax:	772-1070	Date:	August 4, 2003	3
Phon	e 772-3846	Pages:	2	
Re:	65 India St. (020 E020)			
□ Ur	gent ☐ For Review ☐ Please Co	omment 🗹	Please Reply	☐ Please Recycle
	•	•	•	• •
	reviewing technical submissions for the	1 5		wing questions;
 There is no statement of Special Inspection, pursuant to Section 1705. Looking for a statement indicating that the existing structure will withstand the proposed new Loads. 				
Pages AE101, AE102, AE301, AE201,M1, M2, & M3 are not stamped. Is there clear labeling showing what wall assembly will be in what area?				
5) - '.	The East windows appear to be closer that	an 3 feet to the j	property line and	not permitted.