

# Memorandum

---

**To:** Janet Hansen/SMRT – Brent Poulin/Cainbro  
**From:** Mike Nugent/Manager of Inspection Services  
**Date:** 08/18/2003  
**Re:** 65 India St. (020 E020) Vertical Expansion

---

## Final questions

- 1) It appears that the new rear walls and stair towers on the East elevation are within 5 feet of the property lines. Your proposal shows a type “2” wall which has a 1 hour rating, this must be 2 hr.
- 2) What is the rating of the roof system?
- 3) I see references to your tread dimensions but not the risers. Where can I find that?
- 4) The letter from the engineer certifying the ability of the old structure to hold the new one? Can't seem to locate that in the “pile”

I think that's it. Please contact me