Page 2 Application 61 India ST

Grease Gutters provided? yes

Hood Clearance reduction to Combustibles design /specs:
18" Min.

Duct Clearance reduction to Combustibles design /specs:
18" Min.

Vibration Isolation System:
NU

Air Velocity within the duct system 2000 FPM

Grease accumulation prevention system:
yes

Cleanouts yes

Grease Duct enclosure Rio mater zero clearance insulation

Exhaust Termination Roof _____ Wall ✓

Fire Suppression System yes (Fire Guard)

Exhaust fan mounting and clearance from the roof / wall or Combustibles:
10' min.

Exhaust fan distance from property lines 12'

Exhaust fan distance from other vents or openings 10' min.

Exhaust fan distance from adjacent buildings 12'

Exhaust fan height above adjoining grade 10'

Hood Specs

Style of Hood Low Profile Sloped Canopy Hood.

Type of Filter Baffle

Height of filter above nearest cooking surface 48"

Capacity of hood CFM 4200 CFM

Make up Air system description and capacity
Perforated Supply Plenum
@ 3300 CFM