

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

PEARL PROPERTIES LLC /Lebels Sheet Metal

**Located at**

61 INDIA ST

**PERMIT ID:** 2013-02738

**ISSUE DATE:** 03/18/2014

**CBL:** 020 E021001

has permission to **install a Type I Hood System for Food Works**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Craig Messinger*

**Fire Official**

*/s/ Tammy Munson*

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Front building:1st floor= retail and office space and two DU on 2nd & 3rd floors  
Ell: 1st floor into back building = Restaurant, 2nd & 3rd flrs= Offices.  
Back building 1st flr = Restaurant with 2nd floor offices and 1 apt on 3rd & 4th floor combined

***Building Inspections***

***Fire Department***

**PERMIT ID:** 2013-02738

**Located at:** 61 INDIA ST

**CBL:** 020 E021001

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

|  |   |   |  |                            |
|--|---|---|--|----------------------------|
| <b>City of Portland, Maine - Building or Use Permit</b>  |   | <b>Permit No:</b><br>2013-02738                         | <b>Date Applied For:</b><br>12/16/2013 | <b>CBL:</b><br>020 E021001 |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716  |   |   |  |                            |
| <b>Proposed Use:</b><br>Same use   | <b>Proposed Project Description:</b><br>install a Type I Hood System for Food Works |   |  |                            |
| <b>Dept:</b> Zoning <b>Status:</b> Approved <b>Reviewer:</b> Marge Schmuckal <b>Approval Date:</b> 12/26/2013  |   | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |  |                            |
| <b>Note:</b>   |   |   |  |                            |
| <b>Conditions:</b>   |   |   |  |                            |
| <b>Dept:</b> Fire <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Craig Messinger <b>Approval Date:</b> 03/18/2014   |   | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |  |                            |
| <b>Note:</b>   |   |   |  |                            |
| <b>Conditions:</b>   |   |   |  |                            |
| 1) Shall meet the requirements of 2009 NFPA 1 Fire Code.   |   |   |  |                            |
| 2) Hood suppression system shall comply with NFPA 17A, 96, and UL 300. Activation of the suppression system shall activate the fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection if applicable. The Class K fire extinguisher and proper signage should be located at the suppression system pull station. |   |   |  |                            |