DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

THE VILLAGE AT OCEANGATE LLC

Located at

15 MIDDLE ST (Unit C2)

PERMIT ID: 2015-02906

ISSUE DATE: 12/18/2015

CBL: 020 E0290C2

has permission to Tenant fit-out of 895 SF on the ground floor for the "Jessica Johnson Beauty Salon".

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ David Petruccelli

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Unit C2 - personal services (salon)

Building Inspections

Type: 3B

Business - Salon Occupant load = 10

Use Group: B

Building is sprinkled NFPA 13

ENTIRE

MUBEC/IBC 2009

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping Electrical - Commercial Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 12/03/2015 2015-02906 020 E0290C2 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Tenant fit-out of 895 SF on the ground floor for the "Jessica Personal services (salon) Johnson Beauty Salon".

Dept: Zoning **Status:** Approved w/Conditions **Reviewer:** Christina Stacey **Approval Date:** 12/04/2015

Ok to Issue:

Note: C52 contract zone - underlying B-5b zone

Now part of IS-FBC zone

Conditions:

- 1) This unit shall remain as a personal services use. Any change of use or addition of new uses shall require a separate permit application for review and approval.
- 2) Separate permits shall be required for any new signage.
- 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

12/08/2015 **Dept:** Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Laurie Leader **Approval Date:** Ok to Issue: Note:

Conditions:

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Dept: Engineering DPS **Status:** Not Applicable **Reviewer: Approval Date:** 12/04/2015 Ok to Issue: Note:

Conditions:

1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov

Dept: Fire **Status:** Approved w/Conditions Reviewer: David Petruccelli 12/18/2015 **Approval Date:** Ok to Issue: Note:

Conditions:

- 1) Fire protection systems shall be maintained. If system is to be off line over 4 hours a fire watch shall be in place. Dispatch notification required 874-8576.
- 2) Construction or installation shall comply with City Code Chapter 10.
- 3) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer.
- 4) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.
- 5) All outstanding code violations shall be corrected prior to final inspection.
- 6) Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 7) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.
- 8) Shall meet the requirements of 2009 NFPA 1 Fire Code.
- 9) Fire extinguishers are required per NFPA 1 Table 13.6.2.

Located at: 15 MIDDLE ST (Unit C2) CBL: 020 E0290C2 **PERMIT ID:** 2015-02906