


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

September 6, 2017

Responsible Party 1: J & L PARTNERS LLC 193 CHURCH RD BRUNSWICK, ME 04011		
<i>Anna Phillips Nail Bar 15 Middle St Portland ME 04011</i>		
Location	CBL	Inspection Date
15 MIDDLE ST (Unit 1b)	020 E0290C3	8/9/2017
Inspector	Inspection Type	Status
Sean Donaghue	FP Routine Inspection	Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 9/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 10- 7.1.1 FIRE EXTINGUISHERS NEED ANNUAL SERVICE; The owner or designated agent or occupant of a property in which fire extinguishers are located shall be responsible for inspection, maintenance, and recharging. Need current inspection tag on fire extinguisher	11/1/17
NFPA 10- 7.2.2 FIRE EXTINGUISHER NOT ACCESSIBLE; Periodic inspection or electronic monitoring of fire extinguishers shall include a check of at least the following items: (1) Location in designated place (2) No obstruction to access or visibility (3) Pressure gauge reading or indicator in the operable range or position (4) Fullness determined by weighing hefting for self-expelling-type extinguishers, cartridge-operated extinguishers, and pump tanks (5) Condition of tires, wheels, carriage, hose, and nozzle for wheeled extinguishers (6) Indicator for nonrechargeable extinguishers using push-to-test pressure indicators Requires mounting in accessible area	11/1/17
PORTLAND FIRE DEPARTMENT CHAPTER 10 4.6.1, 4.6.2 UNIT/SUITE NUMBERS NOT MARKED; 4.6.1 Residential units shall be designated using numerals. 4.6.2 The first numeral of each residential unit shall be the floor designation. Unit number is not marked anywhere visible from the outside	11/1/17
FINAL DATE OF COMPLETED VIOLATION(S)	_/_/_
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	_/_/_

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

10/19/17
Date

Jessica Harnden
Responsible Party

Date

Responsible Party

SEEN AND AGREED

10/24/17
Date

CAPT. JRB #17
Fire Prevention Bureau