

Jeanie Bourke <jmb@portlandmaine.gov>
To: Michael Coyne <coyne@archetypepa.com>

Tue, Aug 1, 2017 at 3:44 PM

Thanks Mike, did you get the email I sent you yesterday with comments? I can send it again.

Jeanie

*Jeanie Bourke
Code Enforcement Officer/Plan Reviewer
Team Leader*

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715

[Quoted text hidden]

Michael Coyne <coyne@archetypepa.com>
To: Jeanie Bourke <jmb@portlandmaine.gov>

Tue, Aug 1, 2017 at 3:58 PM

Jeanie,

Attached are the revisions per your comments.

In regards to the detail (11/A5.00). I have talked with the structural engineer and contractors about this. We are going to pull that line of steel back just enough to allow the firewall to run continuous, without any interruption from the steel.

Let me know if you need anything else.

Thanks,

Michael Coyne

Archetype PA | 48 Union Wharf | Portland, Maine 04101 | tel. [207.772.6022](tel:207.772.6022) | www.archetype-architects.com

From: Jeanie Bourke [mailto:jmb@portlandmaine.gov]
Sent: Monday, July 31, 2017 4:05 PM

[Quoted text hidden]

[Quoted text hidden]

3 attachments

 **_CS1.1 - Cover Sheet.pdf**
916K

 **A4.00 - Wall Types.pdf**
204K