



# Schedule of Inspection and Testing Agencies

This Statement of Special Inspections / Quality Assurance Plan includes the following building systems:

- |  |   |
|--|---|
| <input checked="" type="checkbox"/> Soils and Foundations  | <input checked="" type="checkbox"/> Spray Fire Resistant Material |
| <input checked="" type="checkbox"/> Cast-in-Place Concrete | <input type="checkbox"/> Wood Construction                        |
| <input type="checkbox"/> Precast Concrete                  | <input type="checkbox"/> Exterior Insulation and Finish System    |
| <input checked="" type="checkbox"/> Masonry                | <input type="checkbox"/> Mechanical & Electrical Systems          |
| <input checked="" type="checkbox"/> Structural Steel       | <input type="checkbox"/> Architectural Systems                    |
| <input type="checkbox"/> Cold-Formed Steel Framing         | <input type="checkbox"/> Special Cases                            |

Special Inspection Agencies	Firm	Address, Telephone
1. Engineer of Record	<i>Veitas &amp; Veitas Engineers</i>	<i>639 Granite Street Braintree, Ma 781-843-2863</i>
2. Inspector (soils)	<i>S.W.Cole Engineering</i>	<i>286 Portland Road Grey, ME 04039 207-657-8866</i>
3. Inspector	<i>S.W. Cole Engineering</i>	<i>286 Portland Road Grey, ME 04039 207-657-8866</i>
4. Testing Agency	<i>S.W. Cole Engineering</i>	<i>286 Portland Road Grey, ME 04039 207-657-8866</i>
5. Testing Agency		
6. Other		

Note: The inspectors and testing agencies shall be engaged by the Owner or the Owner's Agent, and not by the Contractor or Subcontractor whose work is to be inspected or tested. Any conflict of interest must be disclosed to the Building Official, prior to commencing work.

# Quality Assurance Plan

---

## Quality Assurance for Seismic Resistance

Seismic Design Category *C*

Quality Assurance Plan Required (Y/N) *Y*

Description of seismic force resisting system and designated seismic systems:

*Special Concentrically Braced Frames*

## Quality Assurance for Wind Requirements

Basic Wind Speed (3 second gust) *100 mph*

Wind Exposure Category *B*

Quality Assurance Plan Required (Y/N) *N*

Description of wind force resisting system and designated wind resisting components:

*Special Concentrically Braced Frames*

## Statement of Responsibility

Each contractor responsible for the construction or fabrication of a system or component designated above must submit a Statement of Responsibility.

# Qualifications of Inspectors and Testing Technicians

---

The qualifications of all personnel performing Special Inspection and testing activities are subject to the approval of the Building Official. The credentials of all Inspectors and testing technicians shall be provided if requested.

## Key for Minimum Qualifications of Inspection Agents:

When the Registered Design Professional in Responsible Charge deems it appropriate that the individual performing a stipulated test or inspection have a specific certification or license as indicated below, such designation shall appear below the *Agency Number* on the Schedule.

PE/SE	Structural Engineer – a licensed SE or PE specializing in the design of building structures
PE/GE	Geotechnical Engineer – a licensed PE specializing in soil mechanics and foundations
EIT	Engineer-In-Training – a graduate engineer who has passed the Fundamentals of Engineering examination

### American Concrete Institute (ACI) Certification

ACI-CFTT	Concrete Field Testing Technician – Grade 1
ACI-CCI	Concrete Construction Inspector
ACI-LTT	Laboratory Testing Technician – Grade 1&2
ACI-STT	Strength Testing Technician

### American Welding Society (AWS) Certification

AWS-CWI	Certified Welding Inspector
AWS/AISC-SSI	Certified Structural Steel Inspector

### American Society of Non-Destructive Testing (ASNT) Certification

ASNT	Non-Destructive Testing Technician – Level II or III.
------	---

### International Code Council (ICC) Certification

ICC-SMSI	Structural Masonry Special Inspector
ICC-SWSI	Structural Steel and Welding Special Inspector
ICC-SFSI	Spray-Applied Fireproofing Special Inspector
ICC-PCSI	Prestressed Concrete Special Inspector
ICC-RCSI	Reinforced Concrete Special Inspector

### National Institute for Certification in Engineering Technologies (NICET)

NICET-CT	Concrete Technician – Levels I, II, III & IV
NICET-ST	Soils Technician - Levels I, II, III & IV
NICET-GET	Geotechnical Engineering Technician - Levels I, II, III & IV

### Exterior Design Institute (EDI) Certification

EDI-EIFS	EIFS Third Party Inspector
----------	----------------------------

### Other

---

Item	Agency # (Qualif.)	Scope
1. Shallow Foundations	2 PE/GE	<p><i>Inspect soils below footings for adequate bearing capacity and consistency with geotechnical report.</i></p> <p><i>Inspect removal of unsuitable material and preparation of subgrade prior to placement of controlled fill</i></p>
2. Controlled Structural Fill	2/4 PE/GE	<p><i>Perform sieve tests (ASTM D422 &amp; D1140) and modified Proctor tests (ASTM D1557) of each source of fill material.</i></p> <p><i>Inspect placement, lift thickness and compaction of controlled fill.</i></p> <p><i>Test density of each lift of fill by nuclear methods (ASTM D2922)</i></p> <p><i>Verify extent and slope of fill placement.</i></p>
3. Deep Foundations	2 PE/GE	<p><i>Inspect and log pile driving operations. Record pile driving resistance and verify compliance with driving criteria.</i></p> <p><i>Inspect piles for damage from driving and plumbness.</i></p> <p><i>Verify pile size, length and accessories.</i></p> <p><i>Inspect installation of drilled pier foundations. Verify pier diameter, bell diameter, lengths, embedment into bedrock and suitability of end bearing strata.</i></p>
4. Load Testing		
4. Other:		

Item	Agency # (Qualif.)	Scope
1. Mix Design	3 <i>ACI-CCI ICC-RCSI</i>	<i>Review concrete batch tickets and verify compliance with approved mix design. Verify that water added at the site does not exceed that allowed by the mix design.</i>
2. Material Certification		
3. Reinforcement Installation	3 <i>ACI-CCI ICC-RCSI</i>	<i>Inspect size, spacing, cover, positioning and grade of reinforcing steel. Verify that reinforcing bars are free of form oil or other deleterious materials. Inspect bar laps and mechanical splices. Verify that bars are adequately tied and supported on chairs or bolsters</i>
4. Post-Tensioning Operations	<i>N/A  ICC-PCSI</i>	<i>Inspect placement, stressing, grouting and protection of post-tensioning tendons. Verify that tendons are correctly positioned, supported, tied and wrapped. Record tendon elongations.</i>
5. Welding of Reinforcing	<i>N/A  AWS-CWI</i>	<i>Visually inspect all reinforcing steel welds. Verify weldability of reinforcing steel. Inspect preheating of steel when required.</i>
6. Anchor Rods	3	<i>Inspect size, positioning and embedment of anchor rods. Inspect concrete placement and consolidation around anchors.</i>
7. Concrete Placement	3 <i>ACI-CCI ICC-RCSI</i>	<i>Inspect placement of concrete. Verify that concrete conveyance and depositing avoids segregation or contamination. Verify that concrete is properly consolidated.</i>
8. Sampling and Testing of Concrete	4 <i>ACI-CFTT ACI-STT</i>	<i>Test concrete compressive strength (ASTM C31 &amp; C39), slump (ASTM C143), air-content (ASTM C231 or C173) and temperature (ASTM C1064).</i>
9. Curing and Protection	3 <i>ACI-CCI ICC-RCSI</i>	<i>Inspect curing, cold weather protection and hot weather protection procedures.</i>
10. Other:		

# Masonry

Required Inspection Level:  1  2

Page 7 of 9

Item	Agency # (Qualif.)	Scope
1. Material Certification		
2. Mixing of Mortar and Grout	3 ICC-SMSI	<i>Inspect proportioning, mixing and retempering of mortar and grout.</i>
3. Installation of Masonry	3 ICC-SMSI	<i>Inspect size, layout, bonding and placement of masonry units.</i>
4. Mortar Joints	3 ICC-SMSI	<i>Inspect construction of mortar joints including tooling and filling of head joints.</i>
5. Reinforcement Installation	3 ICC-SMSI AWS-CWI	<i>Inspect placement, positioning and lapping of reinforcing steel.</i>
6. Prestressed Masonry	N/A ICC-SMSI	<i>Inspect placement, anchorage and stressing of prestressing bars.</i>
7. Grouting Operations	3 ICC-SMSI	<i>Inspect placement and consolidation of grout. Inspect masonry clean-outs for high-lift grouting.</i>
7. Weather Protection	3 ICC-SMSI	<i>Inspect cold weather protection and hot weather protection procedures. Verify that wall cavities are protected against precipitation.</i>
9. Evaluation of Masonry Strength	4 ICC-SMSI	<i>Test compressive strength of mortar and grout cube samples (ASTM C780). Test compressive strength of masonry prisms (ASTM C1314).</i>
10. Anchors and Ties	3 ICC-SMSI	<i>Inspect size, location, spacing and embedment of dowels, anchors and ties.</i>
11. Other:		

Item	Agency # (Qualif.)	Scope
1. Fabricator Certification/ Quality Control Procedures <input checked="" type="checkbox"/> Fabricator Exempt	AWS/AISC- SSI ICC-SWSI	<i>Review shop fabrication and quality control procedures.</i>
2. Material Certification	3  AWS/AISC- SSI ICC-SWSI	<i>Review certified mill test reports and identification markings on wide-flange shapes, high-strength bolts, nuts and welding electrodes</i>
3. Open Web Steel Joists	3	<i>Inspect installation, field welding and bridging of joists.</i>
4. Bolting	3  AWS/AISC- SSI ICC-SWSI	<i>Inspect installation and tightening of high-strength bolts. Verify that splines have separated from tension control bolts. Verify proper tightening sequence. Continuous inspection of bolts in slip-critical connections.</i>
5. Welding	3  AWS-CWI  ASNT	<i>Visually inspect all welds. Inspect pre-heat, post-heat and surface preparation between passes. Verify size and length of fillet welds.</i>  <i>Ultrasonic testing of all full-penetration welds.</i>
6. Shear Connectors	3  AWS/AISC- SSI ICC-SWSI	<i>Inspect size, number, positioning and welding of shear connectors. Inspect suds for full 360 degree flash. Ring test all shear connectors with a 3 lb hammer. Bend test all questionable studs to 15 degrees.</i>
7. Structural Details	3  PE/SE	<i>Inspect steel frame for compliance with structural drawings, including bracing, member configuration and connection details.</i>
8. Metal Deck	3  AWS-CWI	<i>Inspect welding and side-lap fastening of metal roof and floor deck.</i>
9. Other:		

Item	Agency # (Qualif.)	Scope
1. Material Specifications		
2. Laboratory Tested Fire Resistance Design	3 <i>ICC-SFSI</i>	<i>Review UL fire resistive design for each rated beam, column, or assembly.</i>
3. Schedule of Thickness	3 <i>ICC-SFSI</i>	<i>Review approved thickness schedule.</i>
4. Surface Preparation	3 <i>ICC-SFSI</i>	<i>Inspect surface preparation of steel prior to application of fireproofing</i>
5. Application	3 <i>ICC-SFSI</i>	<i>Inspect application of fireproofing.</i>
6. Curing and Ambient Condition	3 <i>ICC-SFSI</i>	<i>Verify ambient air temperature and ventilation is suitable for application and curing of fireproofing.</i>
7. Thickness	3 <i>ICC-SFSI</i>	<i>Test thickness of fireproofing (ASTM E605). Perform a set of thickness measurements for every 1,000 SF of floor and roof assemblies and on not less than 25% of rated beams and columns.</i>
8. Density	3 <i>ICC-SFSI</i>	<i>Test the density of fireproofing material (ASTM E605).</i>
9. Bond Strength	3 <i>ICC-SFSI</i>	<i>Test the cohesive/adhesive bond strength of fireproofing ASTM E736). Perform not less than one test for each 10,000 SF.</i>
10. Other:		