MAX UL CLASSIFIED SIZE
FSD60 □B, 60-11□B, 37□B, 36□B, 35□B, 34□B

*A = 126" (3200)
FOR FSD36□B
*A = 120" (304B)
FOR FSD34□B, 35□B,
37□B, 60 □B, 60-11□B

B* = 122" (3099)
FOR FSD36□B
B* = 98" (2489) FOR
FSD60□B, 60-11□B
B*= 96" (243B) FOR
FSD34□B, 35□B, 37□B

14 GAGE (2) X
DAMPER
"A" DIMENSION X 5"
(127) WIDE
REINFORCING PLATE

ITEM.	DESCRIPTION
1.	ACTUATOR w/ END SWITCH (LOCATION MAY VARY). RUSKIN'S UL LISTED FIRE DAMPER, OR GREENHECK. ACTUATORS MAY BE FIELD INSTALLED IF PROPERLY LABELED. SEE ACTUATOR INSTALLATION INSTRUCTIONS FOR FIELD MOUNTING OF DAMPER ACTUATORS.
2.	FIRESTAT OR SP100
3.	AUXILIARY OPERATING JACK SHAFT
4.	FIRE / SMOKE DAMPER
5.	OVER CENTER LOCK
6.	SLEEVE
7.	CAULKING MATERIAL (MAY BE ON EITHER SIDE OF DAMPER FRAME
8.	PFMA OR CONVENTIONAL MOUNTING ANGLES
9.	S-JOINT/DUCT MATE, SLEEVE TO DUCT
10.	RUSKIN MODEL NUMBERS LISTED. APPROVED EQUAL PRODUCTS FROM GREENHECK ARE ACCEPTABLE.
11.	PROVIDE ACCESS DOORS AS REQUIRED.
12.	PROVIDE SMOKE DETECTORS.

ACTUATOR ABOVE DAMPER

ACTUATOR BELOW DAMPER

FSD60 OUT OF WALL INSTALLATION

COMBINATION FD / SD INSTALLATION DETAIL

NTS

Architect:
ARCHETYPE
Architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 ARCHETYPE@ARCHETYPEPA.COM

Consultant:
BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

Prepared For:
Archetype
Union Wharf
Portland, ME 04101

STATE OF MAINE
STEPHEN B. DUDA
No. 13367
LICENSED PROFESSIONAL ENGINEER
Date: 07/20/17

Project:
16 MIDDLE STREET
OFFICE BUILDING
MIDDLE STREET
PORTLAND, MAINE

Revisions:

Scale: 1/8"=1'-0" U.N.O.

Date: 13 APR 2017

BenKay Restaurant
MECHANICAL DETAILS

M1.03