

... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : 16 MIDDLE STREET 1ST FLOOR FUTURE TENANT SPACE #3
Drawing : FP-01
Location : 1ST FLOOR
Remote Area : #3
Contract : 062216-2
Data File : 1ST FLOOR FUTURE TENANT SPACE.WXF

HYDRAULIC CALCULATIONS
for

Project name: 16 MIDDLE STREET 1ST FLOOR FUTURE TENANT SPACE

Location: 1ST FLOOR

Drawing no: FP-01

Date: 7/26/17

Design

Remote area number: #3

Remote area location: 1ST FLOOR FUTURE MERCHANTILE TENANT SPACE

Occupancy classification: ORDINARY HAZARD GROUP 2

Density: .2 - Gpm/SqFt

Area of application: 1500 - SqFt

Coverage per sprinkler: 120 - SqFt

Type of sprinklers calculated: QUICK RESPONSE UPRIGHT

No. of sprinklers calculated: 13

In-rack demand: N/A - GPM

Hose streams: 250 - GPM

Total water required (including hose streams): 575.861 - GPM @ 85.1653 - Psi

Type of system: WET NFPA 13

Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 10-14-2016

Location: CORNER OF THAMES AND INDIA STREET

Source: PORTLAND WATER DISTRICT

Name of contractor: HIGH TECH FIRE PROTECTION

Address: 84 HACKETT MILLS ROAD / P.O. BOX 156 / POLAND, ME 04274

Phone number: 207-998-2551

Name of designer: ED POULIN

Authority having jurisdiction: STATE OF MAINE / CITY OF PORTLAND

Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
16 MIDDLE STREET 1ST FLOOR FUTURE TENANT SPACE #3

Page 2
Date 7/26/17

City Water Supply:
C1 - Static Pressure : 110
C2 - Residual Pressure: 106
C2 - Residual Flow : 1591

Demand:
D1 - Elevation : 6.930
D2 - System Flow : 325.861
D2 - System Pressure : 85.165
Hose (Demand) : 250
D3 - System Demand : 575.861
Safety Margin : 24.224



Fittings Used Summary

HIGH TECH FIRE PROTECTION
16 MIDDLE STREET 1ST FLOOR FUTURE TENANT SPACE #3

Page 3
Date 7/26/17

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
 16 MIDDLE STREET 1ST FLOOR FUTURE TENANT SPACE #3

Page 4
 Date 7/26/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
100	10.0	5.6	18.37	na	24.0	0.2	120	7.0
101	10.0	5.6	18.55	na	24.12	0.2	120	7.0
102	10.0	5.6	19.21	na	24.55	0.2	120	7.0
110	10.0	5.6	21.4	na	25.91	0.2	120	7.0
120	10.0	5.6	18.66	na	24.19	0.2	120	7.0
121	10.0	5.6	18.84	na	24.31	0.2	120	7.0
122	10.0	5.6	19.51	na	24.74	0.2	120	7.0
130	10.0	5.6	21.74	na	26.11	0.2	120	7.0
140	10.0	5.6	19.7	na	24.86	0.2	120	7.0
141	10.0	5.6	19.9	na	24.98	0.2	120	7.0
142	10.0	5.6	20.61	na	25.42	0.2	120	7.0
150	10.0	5.6	22.02	na	26.28	0.2	120	7.0
151	10.0	5.6	22.24	na	26.41	0.2	120	7.0
BA	10.0		21.67	na				
BB	10.0		22.01	na				
BC	10.0		23.23	na				
BD	10.0		51.32	na				
BE	10.0		68.29	na				
TOW	10.0		68.54	na				
BOW	4.0		75.15	na				
BASE	0.0		81.23	na				
H1	0.0		81.88	na				
H2	0.0		82.26	na				
H3	0.0		82.31	na	250.0			
TEST	-6.0		85.17	na				

The maximum velocity is 19.17 and it occurs in the pipe between nodes BC and BD

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
16 MIDDLE STREET 1ST FLOOR FUTURE TENANT SPACE #3

Page 5
Date 7/26/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
100 to 101	24.00 24.0	1.682 120.0 0.0183		0.0 0.0 0.0	10.000 0.0 10.000	18.367 0.0 0.183			K Factor = 5.60 Vel = 3.47	
101 to 102	24.12 48.12	1.682 120.0 0.0663		0.0 0.0 0.0	10.000 0.0 10.000	18.550 0.0 0.663			K Factor = 5.60 Vel = 6.95	
102 to BA	24.55 72.67	1.682 120.0 0.1420	1T	9.9 0.0 0.0	7.400 9.900 17.300	19.213 0.0 2.457			K Factor = 5.60 Vel = 10.49	
	0.0 72.67					21.670			K Factor = 15.61	
110 to BA	25.91 25.91	1.682 120.0 0.0211	1T	9.9 0.0 0.0	2.750 9.900 12.650	21.403 0.0 0.267			K Factor = 5.60 Vel = 3.74	
	0.0 25.91					21.670			K Factor = 5.57	
120 to 121	24.19 24.19	1.682 120.0 0.0186		0.0 0.0 0.0	10.000 0.0 10.000	18.656 0.0 0.186			K Factor = 5.60 Vel = 3.49	
121 to 122	24.31 48.5	1.682 120.0 0.0672		0.0 0.0 0.0	10.000 0.0 10.000	18.842 0.0 0.672			K Factor = 5.60 Vel = 7.00	
122 to BB	24.73 73.23	1.682 120.0 0.1440	1T	9.9 0.0 0.0	7.400 9.900 17.300	19.514 0.0 2.492			K Factor = 5.60 Vel = 10.57	
	0.0 73.23					22.006			K Factor = 15.61	
130 to BB	26.11 26.11	1.682 120.0 0.0213	1T	9.9 0.0 0.0	2.750 9.900 12.650	21.736 0.0 0.270			K Factor = 5.60 Vel = 3.77	
	0.0 26.11					22.006			K Factor = 5.57	
140 to 141	24.86 24.86	1.682 120.0 0.0196		0.0 0.0 0.0	10.000 0.0 10.000	19.704 0.0 0.196			K Factor = 5.60 Vel = 3.59	
141 to 142	24.98 49.84	1.682 120.0 0.0707		0.0 0.0 0.0	10.000 0.0 10.000	19.900 0.0 0.707			K Factor = 5.60 Vel = 7.20	
142 to BC	25.42 75.26	1.682 120.0 0.1515	1T	9.9 0.0 0.0	7.400 9.900 17.300	20.607 0.0 2.621			K Factor = 5.60 Vel = 10.87	
	0.0 75.26					23.228			K Factor = 15.62	
150 to 151	26.28 26.28	1.682 120.0 0.0216		0.0 0.0 0.0	10.000 0.0 10.000	22.021 0.0 0.216			K Factor = 5.60 Vel = 3.79	
151 to BC	26.41 52.69	1.682 120.0 0.0783	1T	9.9 0.0 0.0	2.750 9.900 12.650	22.237 0.0 0.991			K Factor = 5.60 Vel = 7.61	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
16 MIDDLE STREET 1ST FLOOR FUTURE TENANT SPACE #3

Page 6
Date 7/26/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 52.69						23.228		K Factor = 10.93	
BA to BB	98.57	2.635 120.0		0.0	12.000	21.670 0.0				
BB to BC	98.57 99.34	0.0280 2.635 120.0		0.0	12.000	0.336 22.006 0.0			Vel = 5.80	
BC to BD	197.91 127.95	0.1018 2.635 120.0	2X	29.654	80.000	23.228 29.654 0.0				
BD to BE	325.86 0.0	0.2562 2.635 120.0		0.0	109.654	28.092 51.320 3.000			Vel = 19.17	* Fixed loss = 3
			1Fsp	0.0	1.000					Vel = 19.17
			1B	9.61	53.541					
			1E	8.237	54.541					
			1S	19.22						
			1T	16.474						
BE to TOW	0.0 325.86	4.26 120.0	1V	8.954	1.000	68.293 0.0				
TOW to BOW	0.0 325.86	4.26 120.0	1B	15.8	4.000	68.539 5.599			Vel = 7.34	* Fixed loss = 3
BOW to BASE	0.0 325.86	4.26 120.0	1Fsp	0.0	36.867	1.009			Vel = 7.34	
			1X	21.067	40.867					
			1Zib	0.0	3.000	75.147				
			1X	21.067	21.067	5.486			* Fixed loss = 3.753	
				0.0	24.067	0.594			Vel = 7.34	
BASE to H1	0.0 325.86	6.16 140.0	2E	40.168	125.000	81.227 0.0				
H1 to H2	0.0 325.86	8.27 140.0	1T	55.354	460.000	81.881 0.0				
H2 to H3	0.0 325.86	12.34 140.0		0.0	55.354	0.0			Vel = 1.95	
			1T	93.767	360.000	82.260				
				0.0	93.767	0.0				
				0.0	453.767	0.047			Vel = 0.87	
H3 to TEST	250.00 575.86	6.16 140.0	1E	20.084	5.000	82.307 2.599			Qa = 250	
			1G	4.304	24.388				Vel = 6.20	
				0.0	29.388	0.259				
	0.0 575.86						85.165		K Factor = 62.40	