

**... Fire Protection by Computer Design**

HIGH TECH FIRE PROTECTION  
84 HACKETT MILLS ROAD  
P.O. BOX 156  
POLAND, ME 04274  
207-998-2551

Job Name : 16 MIDDLE STREET PARKING GARAGE #4  
Drawing : FP-01  
Location : 1ST FLOOR  
Remote Area : #4  
Contract : 062216-2  
Data File : PARKING GARAGE.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**Project name:** 16 MIDDLE STREET 1ST EXTERIOR DRIVE THRU  
**Location:** 1ST FLOOR  
**Drawing no:** FP-01  
**Date:** 7/26/17

**Design**

**Remote area number:** #4  
**Remote area location:** 1ST FLOOR THROUGH BUILDING DRIVE WAY  
**Occupancy classification:** ORDINARY HAZARD GROUP 1  
**Density:** .15 - Gpm/SqFt  
**Area of application:** 1950 - SqFt  
**Coverage per sprinkler:** 120 - SqFt  
**Type of sprinklers calculated:** QUICK RESPONSE DRY PENDENTS  
**No. of sprinklers calculated:** 19  
**In-rack demand:** N/A - GPM  
**Hose streams:** 250 - GPM  
**Total water required (including hose streams):** 662 - GPM @ 71 - Psi  
**Type of system:** DRY NFPA 13  
**Volume of dry or preaction system:** 220 - Gal

**Water supply information**

**Date:** 10-14-2016  
**Location:** CORNER OF THAMES AND INDIA STREET  
**Source:** PORTLAND WATER DISTRICT

**Name of contractor:** HIGH TECH FIRE PROTECTION  
**Address:** 84 HACKETT MILLS ROAD / P.O. BOX 156 / POLAND, ME 04274  
**Phone number:** 207-998-2551  
**Name of designer:** ED POULIN  
**Authority having jurisdiction:** STATE OF MAINE / CITY OF PORTLAND  
**Notes: (Include peaking information or gridded systems here.)**


# Water Supply Curve (C)

HIGH TECH FIRE PROTECTION  
16 MIDDLE STREET PARKING GARAGE #4

Page 2  
Date 7/26/17

City Water Supply:  
C1 - Static Pressure : 110  
C2 - Residual Pressure: 106  
C2 - Residual Flow : 1591

Demand:  
D1 - Elevation : 7.363  
D2 - System Flow : 411.589  
D2 - System Pressure : 70.397  
Hose ( Demand ) : 250  
D3 - System Demand : 661.589  
Safety Margin : 38.814



# Fittings Used Summary

HIGH TECH FIRE PROTECTION  
16 MIDDLE STREET PARKING GARAGE #4

Page 3  
Date 7/26/17

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Dge	Dry Reliable EX						3.1	4.3	9		10		20.9	38.1							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION  
16 MIDDLE STREET PARKING GARAGE #4

Page 4  
Date 7/26/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.6	12.13	na	19.5	0.15	130	7.0
10	11.0	K = K @ EQ01	13.11	na	19.5			
11	11.0	K = K @ EQ01	13.32	na	19.66			
12	11.0	K = K @ EQ01	14.08	na	20.21			
13	11.0		15.42	na				
14	11.0		15.98	na				
15	11.0	K = K @ EQ01	16.29	na	21.74			
20	11.0	K = K @ EQ01	13.27	na	19.62			
21	11.0	K = K @ EQ01	13.48	na	19.78			
22	11.0	K = K @ EQ01	14.25	na	20.33			
23	11.0		15.61	na				
24	11.0		16.17	na				
25	11.0	K = K @ EQ01	16.49	na	21.87			
30	11.0	K = K @ EQ01	13.93	na	20.1			
31	11.0	K = K @ EQ01	14.15	na	20.26			
32	11.0	K = K @ EQ01	14.96	na	20.83			
33	11.0		16.37	na				
34	11.0		16.97	na				
35	11.0	K = K @ EQ01	17.3	na	22.4			
40	11.0	K = K @ EQ01	15.67	na	21.32			
41	11.0	K = K @ EQ01	15.92	na	21.49			
42	11.0	K = K @ EQ01	16.81	na	22.08			
43	11.0		18.39	na				
44	11.0		19.05	na				
45	11.0	K = K @ EQ01	19.43	na	23.74			
51	11.0	K = K @ EQ01	21.75	na	25.12			
52	11.0	K = K @ EQ01	22.08	na	25.31			
53	11.0		23.07	na				
54	11.0		23.49	na				
55	11.0	K = K @ EQ01	23.72	na	26.23			
DA	10.0		18.6	na				
DB	10.0		18.81	na				
DC	10.0		19.71	na				
DD	10.0		22.06	na				
DE	10.0		25.84	na				
DF	10.0		41.09	na				
TOD	10.0		48.95	na				
BOD	4.0		59.88	na				
BASE	0.0		65.8	na				
H1	0.0		66.81	na				
H2	0.0		67.39	na				
H3	0.0		67.46	na	250.0			
TEST	-6.0		70.4	na				

The maximum velocity is 24.22 and it occurs in the pipe between nodes DE and DF

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
16 MIDDLE STREET PARKING GARAGE #4

Page 5  
Date 7/26/17

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	19.50 19.5	1.049 100.0 0.1740	2T	7.137 0.0 0.0	1.000 7.137 8.137	12.125 -0.433 1.416			K Factor = 5.60 Vel = 7.24	
	0.0 19.50						13.108		K Factor = 5.39	
10 to 11	19.50 19.5	1.682 100.0 0.0174		0.0 0.0 0.0	12.000 0.0 12.000	13.108 0.0 0.209			K Factor @ node EQ01 Vel = 2.82	
11 to 12	19.66 39.16	1.682 100.0 0.0634		0.0 0.0 0.0	12.000 0.0 12.000	13.317 0.0 0.761			K Factor @ node EQ01 Vel = 5.65	
12 to 13	20.20 59.36	1.682 100.0 0.1369	1V	3.091 0.0 0.0	6.700 3.091 9.791	14.078 0.0 1.340			K Factor @ node EQ01 Vel = 8.57	
13 to 14	0.0 59.36	1.682 100.0 0.1369	1V	3.091 0.0 0.0	1.000 3.091 4.091	15.418 0.0 0.560			Vel = 8.57	
14 to 15	0.0 59.36	1.682 100.0 0.1370		0.0 0.0 0.0	2.300 0.0 2.300	15.978 0.0 0.315			Vel = 8.57	
15 to DA	21.74 81.1	1.682 100.0 0.2439	1T	7.065 0.0 0.0	0.600 7.066 7.666	16.293 0.433 1.870			K Factor @ node EQ01 Vel = 11.71	
	0.0 81.10						18.596		K Factor = 18.81	
20 to 21	19.62 19.62	1.682 100.0 0.0177		0.0 0.0 0.0	12.000 0.0 12.000	13.270 0.0 0.212			K Factor @ node EQ01 Vel = 2.83	
21 to 22	19.78 39.4	1.682 100.0 0.0641		0.0 0.0 0.0	12.000 0.0 12.000	13.482 0.0 0.769			K Factor @ node EQ01 Vel = 5.69	
22 to 23	20.33 59.73	1.682 100.0 0.1384	1V	3.091 0.0 0.0	6.700 3.091 9.791	14.251 0.0 1.355			K Factor @ node EQ01 Vel = 8.62	
23 to 24	0.0 59.73	1.682 100.0 0.1386	1V	3.091 0.0 0.0	1.000 3.091 4.091	15.606 0.0 0.567			Vel = 8.62	
24 to 25	0.0 59.73	1.682 100.0 0.1383		0.0 0.0 0.0	2.300 0.0 2.300	16.173 0.0 0.318			Vel = 8.62	
25 to DB	21.87 81.6	1.682 100.0 0.2467	1T	7.065 0.0 0.0	0.600 7.066 7.666	16.491 0.433 1.891			K Factor @ node EQ01 Vel = 11.78	
	0.0 81.60						18.815		K Factor = 18.81	
30 to 31	20.10 20.1	1.682 100.0 0.0184		0.0 0.0 0.0	12.000 0.0 12.000	13.930 0.0 0.221			K Factor @ node EQ01 Vel = 2.90	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
16 MIDDLE STREET PARKING GARAGE #4

Page 6  
Date 7/26/17

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
31	20.26	1.682		0.0	12.000	14.151			K Factor @ node EQ01	
to		100.0		0.0	0.0	0.0				
32	40.36	0.0671		0.0	12.000	0.805			Vel = 5.83	
32	20.83	1.682	1V	3.091	6.700	14.956			K Factor @ node EQ01	
to		100.0		0.0	3.091	0.0				
33	61.19	0.1448		0.0	9.791	1.418			Vel = 8.84	
33	0.0	1.682	1V	3.091	1.000	16.374				
to		100.0		0.0	3.091	0.0				
34	61.19	0.1447		0.0	4.091	0.592			Vel = 8.84	
34	0.0	1.682		0.0	2.300	16.966				
to		100.0		0.0	0.0	0.0				
35	61.19	0.1448		0.0	2.300	0.333			Vel = 8.84	
35	22.40	1.682	1T	7.065	0.600	17.299			K Factor @ node EQ01	
to		100.0		0.0	7.066	0.433				
DC	83.59	0.2579		0.0	7.666	1.977			Vel = 12.07	
	0.0									
	83.59					19.709			K Factor = 18.83	
40	21.32	1.682		0.0	12.000	15.669			K Factor @ node EQ01	
to		100.0		0.0	0.0	0.0				
41	21.32	0.0206		0.0	12.000	0.247			Vel = 3.08	
41	21.49	1.682		0.0	12.000	15.916			K Factor @ node EQ01	
to		100.0		0.0	0.0	0.0				
42	42.81	0.0748		0.0	12.000	0.898			Vel = 6.18	
42	22.08	1.682	1V	3.091	6.700	16.814			K Factor @ node EQ01	
to		100.0		0.0	3.091	0.0				
43	64.89	0.1614		0.0	9.791	1.580			Vel = 9.37	
43	0.0	1.682	1V	3.091	1.000	18.394				
to		100.0		0.0	3.091	0.0				
44	64.89	0.1613		0.0	4.091	0.660			Vel = 9.37	
44	0.0	1.682		0.0	2.300	19.054				
to		100.0		0.0	0.0	0.0				
45	64.89	0.1613		0.0	2.300	0.371			Vel = 9.37	
45	23.74	1.682	1T	7.065	0.600	19.425			K Factor @ node EQ01	
to		100.0		0.0	7.066	0.433				
DD	88.63	0.2874		0.0	7.666	2.203			Vel = 12.80	
	0.0									
	88.63					22.061			K Factor = 18.87	
51	25.12	1.682		0.0	12.000	21.748			K Factor @ node EQ01	
to		100.0		0.0	0.0	0.0				
52	25.12	0.0278		0.0	12.000	0.334			Vel = 3.63	
52	25.31	1.682	1V	3.091	6.700	22.082			K Factor @ node EQ01	
to		100.0		0.0	3.091	0.0				
53	50.43	0.1013		0.0	9.791	0.992			Vel = 7.28	
53	0.0	1.682	1V	3.091	1.000	23.074				
to		100.0		0.0	3.091	0.0				
54	50.43	0.1012		0.0	4.091	0.414			Vel = 7.28	
54	0.0	1.682		0.0	2.300	23.488				
to		100.0		0.0	0.0	0.0				
55	50.43	0.1013		0.0	2.300	0.233			Vel = 7.28	

# Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
16 MIDDLE STREET PARKING GARAGE #4

Page 7  
Date 7/26/17

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
55 to DE	26.23 76.66	1.682 100.0 0.2197	1T	7.065 0.0 0.0	0.600 7.066 7.666	23.721 0.433 1.684			K Factor @ node EQ01 Vel = 11.07	
	0.0 76.66						25.838		K Factor = 15.08	
DA to DB	81.10 81.1	2.635 100.0 0.0274		0.0 0.0 0.0	8.000 0.0 8.000	18.596 0.0 0.219			Vel = 4.77	
DB to DC	81.61 162.71	2.635 100.0 0.0993		0.0 0.0 0.0	9.000 0.0 9.000	18.815 0.0 0.894			Vel = 9.57	
DC to DD	83.59 246.3	2.635 100.0 0.2138		0.0 0.0 0.0	11.000 0.0 11.000	19.709 0.0 2.352			Vel = 14.49	
DD to DE	88.63 334.93	2.635 100.0 0.3777		0.0 0.0 0.0	10.000 0.0 10.000	22.061 0.0 3.777			Vel = 19.71	
DE to DF	76.66 411.59	2.635 100.0 0.5530	1X	10.582 0.0 0.0	17.000 10.582 27.582	25.838 0.0 15.252			Vel = 24.22	
DF to TOD	0.0 411.59	2.635 100.0 0.5529	1V	4.213 0.0 0.0	10.000 4.213 14.213	41.090 0.0 7.859			Vel = 24.22	
TOD to BOD	0.0 411.59	2.635 100.0 0.5529	1B 1Dge	6.859 4.213 0.0	4.000 11.072 15.072	48.949 2.599 8.334			Vel = 24.22	
BOD to BASE	0.0 411.59	4.26 120.0 0.0380	1Zib	0.0 0.0 0.0	3.000 0.0 3.000	59.882 5.803 0.114			* Fixed loss = 4.071 Vel = 9.26	
BASE to H1	0.0 411.59	6.16 140.0 0.0047	2E 1T 1G	40.168 43.037 4.304	125.000 87.509 212.509	65.799 0.0 1.009			Vel = 4.43	
H1 to H2	0.0 411.59	8.27 140.0 0.0011	1T	55.354 0.0 0.0	460.000 55.354 515.354	66.808 0.0 0.582			Vel = 2.46	
H2 to H3	0.0 411.59	12.34 140.0 0.0002	1T	93.767 0.0 0.0	360.000 93.767 453.767	67.390 0.0 0.073			Vel = 1.10	
H3 to TEST	250.00 661.59	6.16 140.0 0.0114	1E 1G	20.084 4.304 0.0	5.000 24.388 29.388	67.463 2.599 0.335			Qa = 250 Vel = 7.12	
	0.0 661.59						70.397		K Factor = 78.85	