

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

EAST INDIA LAND COMPANY LLC

Located at

33 INDIA ST (185 Fore St) (Unit #101)

PERMIT ID: 2016-00291

ISSUE DATE: 04/06/2016

CBL: 020 F023001

has permission to **Interior fit out of tenant space to be used as a day spa (4,486 SF) (First Floor Condo Unit #101) for "Nine Stones Spa".**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Personal services (spa)

Building Inspections

Use Group: B

Type: 5A

Business - Salon

Occupant load = 52

NFPA 13 Sprinkler System

COMMERCIAL SUITE ONLY

MUBEC/IBC 2009

Fire Department

PERMIT ID: 2016-00291

Located at: 33 INDIA ST (185 Fore St) (Unit

CBL: 020 F023001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Final - Electric

Final - Fire

Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-00291	Date Applied For: 02/09/2016	CBL: 020 F023001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Mixed use 1 commercial and 8 residential condos (First Floor Condo Unit #101 - "Nine Stones Spa")		Proposed Project Description: Interior fit out of tenant space to be used as a day spa (4,486 SF) (First Floor Condo Unit #101) for "Nine Stones Spa".		
<p>Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 04/05/2016</p> <p>Note: IS-FBC zone Ok to Issue: <input checked="" type="checkbox"/></p> <p>1 off-street parking space/400 sf floor area = 11 spaces required, lease addendum provides 11 - OK</p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) Separate permits shall be required for any new signage. 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. 				
<p>Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Laurie Leader Approval Date: 03/21/2016</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 2) This project includes alterations that Maine state law requires for compliance with the 2010 ADA Standards for Accessible Design. 3) The continuity of the fire resistance rated wall or floor/ceiling assembly shall be installed and maintained as described in IBC Ch. 7 and all penetrations shall be treated with approved materials and methods. 4) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 				
<p>Dept: Engineering DPS Status: Not Applicable Reviewer: Rachel Smith Approval Date: 02/19/2016</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov 				
<p>Dept: Fire Status: Approved w/Conditions Reviewer: Craig Messinger Approval Date: 03/24/2016</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) Application requires State Fire Marshal approval. 2) All construction shall comply with City Code Chapter 10. 3) System acceptance and commissioning must be coordinated with a fire alarm technician and suppression system contractors and the Fire Department. Call 874-8400 to schedule. 4) Shall meet the requirements of NFPA 101, Chapter 30, New Apartment Buildings. 5) Ground Level shall meet the requirements of NFPA 101, Chapter 38, New Business. 6) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve. 7) Application requires State Fire Marshal approval. 8) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation. 				

PERMIT ID: 2016-00291

Located at: 33 INDIA ST (185 Fore St) (Unit

CBL: 020 F023001

