



THIRD FLOOR PLAN
SCALE: 1/4" = 1'-0"

SYMBOL LEGEND

- SELF CONTAINED EMERGENCY LIGHT W/2 HEADS, 25 WATTS FOR 90 MINUTES
- INTERIOR REMOTE HEAD
- EXTERIOR REMOTE HEAD
- EXIT LIGHT FIXTURE, UNSWITCHED
- EXIT/ EMERGENCY LIGHT COMBO
- FIRE ALARM CONTROL PANEL WITH DEDICATED TELEPHONE JACK
- FIRE ALARM ANNUNCIATOR PANEL
- FIRE ALARM AUDIO/VISUAL, MOUNT 6'-8" AFF, NUMBER DENOTES CANDELA RATING. "I" DENOTES MINIHORN, "CL" DENOTES CEILING MOUNTED, NO DESIGNATION EQUALS 15c
- FIRE ALARM PULL STATION, MOUNT 48" AFF
- FIRE ALARM VISUAL STROBE ONLY, FLUSH MOUNT 6'-8" AFF, NUMBER DENOTES CANDELA RATINGS. "CL" DENOTES CEILING MOUNTED
- SYSTEM CONNECTED SMOKE / CARBON MONOXIDE DETECTOR, PHOTOELECTRIC TYPE
- SYSTEM CONNECTED FIXED TEMPERATURE HEAT DETECTOR
- SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED.
- SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED. "ER" DENOTES ELEV RECALL
- CARBON MONOXIDE DETECTOR
- DUCT SMOKE DETECTOR & TEST STATION
- FIRE/SMOKE DAMPER, SUPPLIED AND INSTALLED BY MECHANICAL CONTRACTOR. ELECTRICAL CONTRACTOR TO PROVIDE ALL WIRING CONNECTIONS AND FIRE ALARM DUCT SMOKE DETECTORS, ADDRESSABLE MODULES AND PROGRAMMING.
- SPRINKLER SYSTEM FLOW SWITCH } SUPPLIED BY SPRINKLER CONTRACTOR
- SPRINKLER SYSTEM TAMPER SWITCH } WIRED BY EC, VERIFY LOCATIONS WITH SPRINKLER CONTRACTOR.

Date:	17 March 2016	Scale:	As indicated	Project:	185 FORE STREET Portland, Maine
Revisions:	: : :	Architect:	ARCHETYPE architects 48 Union Wharf Portland, Maine 04101 (207) 772-6022 Fax (207) 772-4056		
Consultant:	BENNETT ENGINEERING MECHANICAL, ELECTRICAL (207) 866-9476				
Prepared For:	THIRD FLOOR LIFE SAFETY PLAN LS-3				