

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
 389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager 111 FRANKLIN STREET LLC		Inspector Mike Nugent	Inspection Date 6/28/2006
Locatation 113 FRANKLIN ST	CBL 021 D005001	Status Re-Inspect 30 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.4	Exterior			Porch	
Violation: Stairways, stairwells, stairs, porches.					
Notes: Exterior porch has damaged floor boards, there was an approximate 6 inch by 9 inch hole in one board and a smaller hole in an adjacent board . This was repaired temporarily at inspection time A complete permanent repair with suitable sheathing materials must occur in this area and any other deteriorated area on the exterior porches and means of egress.					

Comments: