

F. W. CUNNINGHAM & SONS

BUILDING CONSTRUCTION

131 STATE STREET

PORTLAND, MAINE

INCORPORATED 1905

SPRUCE 3-0246

May 26, 1961

Sears, Director
of Building Inspection
Portland
Maine


Central High School

Enclosing herewith the revised plans on Alterations of the
High School to comply with your letter of May 23, 1961.

Very truly yours,

F. W. CUNNINGHAM & SONS

Eugene R. Connor
Eugene R. Connor



AP- 305 Congress Street

May 23, 1961

F. W. Cunningham & Son
181 State Street

cc to: Roman Catholic Bishop of Portland
307 Congress Street

Gentlemen:

Check of plans filed with application for permit for alterations to school building at the above named location to provide two new second means of egress from basement class rooms discloses the following questions as to compliance with Building Code requirements:

1. Exit from front of building:

- a. New door is required to be at least 3 feet wide instead of the 2 foot 8 inch width indicated. - O.K.
- b. A hand rail is required on at least one side of stairway or on both sides if it is over 40 inches wide. - O.K.
- c. Should there not be a railing on top of the long side of the new concrete wall to prevent anyone falling into the stairwell? - O.K.

2. Exit from rear of building:

- a. New door required to be at least 3 feet wide. - O.K.
- b. Handrail required on at least one side of stairs or on both sides if over 40 inches wide. - O.K.
- c. Plan appears to indicate that wood platform is to be built directly against wall of incinerator. Clearances, depending upon the type of incinerator, its construction, etc. are required from any combustible material to the walls of the unit. - See letter
- d. Walls of pent house construction over new stairway above existing roof level are required to be covered inside as well as outside, with incombustible material in accordance with the requirements of Section 402-b-15 of the Building Code. - O.K.
- e. Header and trimmers around new opening in roof need to be doubled. - O.K.
- f. Opening in roof needs to be made large enough to provide head room of at least 6 foot 4 inches at all points. - O.K.

Information indicating how compliance is to be provided with above requirements is needed before a permit for the alterations can be issued.

Very truly yours,

Albert J. Sears
Building Inspection Director

AJS:ra



PG RESIDENCE ZONE
APPLICATION FOR PERMIT

Class of Building or Type of Structure 2nd class
Portland, Maine, May 18, 1961

PERMIT ISSUED
MAY 18 1961
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 307 Congress St. Within Fire Limits? Dist. No.
Owner's name and address Roman Catholic Bishop of Portland 307 Congress St. Telephone
Lessee's name and address Telephone
Contractor's name and address F.W. Cunningham & Sons 181 State St. Telephone 3-0245
Architect Specifications Plans yes No. of sheets 1
Proposed use of building Rectory No. families
Last use No. families
Material brick No. stories 3 Heat Style of roof Roofing
Other buildings on same lot Fee \$ 100.00
Estimated cost \$ 400.00 2.00

General Description of New Work

To provide a hollow metal fire door between Rectory and Church on second floor as per plan.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber-Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor , 2nd , 3rd , roof
On centers: 1st floor , 2nd , 3rd , roof
Maximum span: 1st floor , 2nd , 3rd , height?
If one story building with masonry walls, thickness of walls?

If a Garage

No. cars now accommodated on same lot , to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Roman Catholic Bishop of Portland
F.W. Cunningham & Sons

APPROVED:

Carl P. Johnson
CHIEF OF FIRE DEPT.

CS 301

INSPECTION COPY

Signature of owner

by:

F.W. Cunningham & Sons
Pauline Marie

P16

Permit No. 311295
 Licensee 307
 Owner name Catholic Priory
 Date of permit 1/22/61
 Notif. closing-in
 Inspn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued
 Staking Out Notice
 Form Check Notice

6/5/5

307 Professor H.

Owner W. H. H. H. H. H.

Date of permit ✓ 22/22

Notif. cloaing-in

Inspn. closing-in

Final Noif.

Final Index.

Year of Occurrence Issued

CERT. OF DEEDS

Staking Out Notice

6/11/1915 - Mac - not selected - Allen
7/11/1915 - Mac - not selected - Allen
8/11/1915 - Mac - not selected - Allen

A large, dark, handwritten 'X' mark is centered on a background of horizontal lines. The 'X' is formed by two intersecting diagonal strokes. The background consists of many thin, horizontal lines, some of which are slightly irregular, suggesting a scanned document or a piece of lined paper. The 'X' is the most prominent feature, spanning across several lines.



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, July 22, 1957

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 307 Congress St. Use of Building Church No. Stories 3 New Building Existing "
Name and address of owner of appliance Moran Catholic Bishop, 307 Congress St.
Installer's name and address Fels Co., Inc. 42 Union St. Telephone 2-1939

General Description of Work

To install two steam boilers and oil burning equipment (replacement)

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 9'
From top of smoke pipe 3' From front of appliance over 4' From sides or back of appliance over 3'
Size of chimney flue 36x36 Other connections to same flue ~~XXXXXXXXXXXX~~ no
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Preferred Utilities Labelled by underwriters' laboratories? yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? top
Type of floor beneath burner concrete Size of vent pipe existing
Location of oil storage underground (xix vault) Number and capacity of tanks 1-5000 gal (existing)
Low water shut off yes Make M&M No. 51-2
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.50 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

7.22.57

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Fels Co., Inc.

By:

G. Lee Williams

Signature of Installer

CITY MAINE PRINTING CO.

INSPECTION COPY

10-16 C-1
Permit No. 52/1023

Location 307 Congress St.

Owner Roman Catholic Bishop

Date of permit 7/22/57

Approved 10-15-57 J. J. [Signature]

NOTES

1	Fill type	✓
2	Vent type	✓
3	Kind of heat	✓
4	Burial Rigidity & Support	✓
5	Name & Label	✓
6	Stack Control	✓
7	High Lift Control	✓
8	Remote Control	✓
9	Piping System & Protection	✓
10	Valves to Reg. & Line	✓
11	Capacity of Tanks	✓
12	Tank Rigidity & Support	✓
13	Tank Distance	✓
14	Oil Phase	✓
15	Insulation	✓
16	Low Temp. P.	✓

9.24.57. Quantity
Secretary, City of New York
10/15/57



APPLICATION FOR PERMIT

Class of Building or Type of Structure _____

Portland, Maine, Dec. 16, 1954

PERMIT 1954-77
01337
17 1954
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ ~~alter~~ ~~repair~~ ~~demolish~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 307 Congress St. Within Fire Limits? yes Dist. No. _____
Owner's name and address Roman Catholic Bishop, 307 Congress St. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address Fels Co., Inc., 12 Union St. Telephone 2-1939
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building _____ No. families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ _____ Fee \$ 2.00

General Description of New Work

To install ventilation of tank vault as per plan.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** Fels Co., Inc.

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number

Will automobile repairing be done other than minor repairs to cars here? _____

APPROVED:

INSPECTION COPY

12271
Cangara St
Wickham 13
12/17/54

1227/
Cargan
am. White Rock
12/17/54

The undersigned hereby applies for a permit to erect alter repairs or additions install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, Plans and specifications, if any, submitted herewith and the following specifications:

Location 307 Congress St. Within Fire Limits? yes Dist. No. _____
Owner's name and address Roman Catholic Bishop, 307 Congress St. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address Fels Co., Inc., 12 Union St. Telephone 2-1939
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building _____ No. families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ _____ Fee \$ 1.00

General Description of New Work

To install 1-5000 gallon fuel oil tank, piping etc. as per plan.

RELATED Permit.

No further info needed.
noted

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** Fels Co., Inc.

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Roman Catholic Bishop
Fels Co., Inc.

Signature of owner by:

Clyde Bralby

INSPECTION COPY

Permit No. 55/167

Location 307 Congress St.

Owner Roman Catholic Bishop

Date of permit 2/8/55

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

Staking Out Notice

Form Check Notice

NOTES

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

1/10/55

STAINLESS STEEL FABRICATION


Paper and Textile Mill Specialties
"Pine Tree" Copper Range Boilers
Truck Tanks - Oil Tanks
Machinery Development

January 14, 1955.

To Whom it May Concern:

This is to certify that the 5,000 gallon Oil Storage Tank which was built at our plant and installed at the Cathedral of the Immaculate Conception, was designed by our Mr. Melvin J. Marco. The welding on this tank was performed by our employee Mr. Frank Wakem, who has a card from the office of Building Inspector of Portland certifying him as a duly qualified welder, as required by the City of Portland, said card being still in effect as of the above date.

George H. Hayes



January 13, 1955

WHCD 1/17/55 BP 307 Congress St.—Installation of fuel oil tank for Roman
Catholic Bishop of Portland

F. W. Cunningham & Sons
181 State St.
Fels Co., Inc.
42 Union St.
Portland Copper & Tank Works
80 Second St. So. Portland

Copy to Roman Catholic Bishop of Portland
307 Congress St.

Gentlemen:

Through some oversight or misunderstanding, this work had been completed with at least two points in non-conformity with Code regulations. For the protection of the owner and so that the duties of this department may be discharged, it is necessary that these defects as to conformity be cleared up now. Please see to it that they are fully taken care of as indicated before January 21, 1955.

Please refer to paragraph numbered I of our letter of December 9 sent with the construction permit for the vault and copy of which was sent to each of you. Fels Company applied for the separate permit covering connections to the new tank etc., but did not secure it, so we still have it unissued, for the reasons which will appear below.

Nevertheless, the connections have evidently been made and the construction contractor has sealed up the tank by constructing the new top slab without notice to this department for inspection.

Fels Company applied for their permit on December 15. We were unable to issue that permit because we did not have a design plan of the tank bearing upon it the required statement of design of the designer. Upon phoning the Fels Company, it was found that they had nothing to do with procuring the tank but that it was evidently procured and placed in the vault by the general contractor—perhaps it was assembled right in the vault by Portland Copper & Tank Works. Not having any direct relationship to this latter company, we phoned the general contractor's office where we were told that they would notify the Tank Company to file the required design plan with statement of design. That has never been received; so, we are still holding the Fels permit.

To proceed to get the matter fully cleared up, it is expected that all concerned will have the design plan bearing the statement of design filed in this office before January 21; also, that the Portland Copper & Tank Works will before that date have written to me giving assurance that the welding on the tank was performed by welders duly qualified and carrying an effective certificate to that effect from this department.

A Tank Company plan was filed here on December 9, but we are unable to use it because it shows neither the thickness of the steel shell, the size of the structural framing members, and does not bear upon it the signed statement of design called for by the Building Code.

Very truly yours,

Warren McDonald
Inspector of Buildings

WHCD/B

1A



APPLICATION FOR PERMIT

Class of Building or Type of Structure _____

Portland, Maine, Dec., 6, 1954

PERMIT ISSUED

0222

DEC 9 1954

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair or demolish the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 307 Congress St. Within Fire Limits? yes Dist. No. _____
Owner's name and address Roman Catholic Bishop, 307 Congress St. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address F. W. Cunningham & Sons, 161 State St. Telephone 3-0246
Architect _____ Specifications _____ Plans yes No. of sheets 1
Proposed use of building _____ No. families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____ Fee \$ 5.00
Estimated cost \$ 3,000.

General Description of New Work

To provide concrete vault for new fuel oil tank as per plan.

Permit Issued with Letter _____

CERTIFICATE OF OCCUPANCY
REQUIREMENT WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO F. W. Cunningham & Sons

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet:
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Roman Catholic Bishop
F. W. Cunningham & Sons


APPROVED:

INSPECTION COPY

Signature of owner by: John P. Boyle

NOTES

1/13/55 - see letter
about violations
with appl for
oil burner installation
permit not issued
(unpaid form) W.D.



Permit No. 54/2328
Location 307 Commercial
Owner James O. H. O'Connell
Date of permit 12/9/54
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn.
Cert. of Occupancy issued
Sinking Out Notice
Form Check Notice

1. Is the building used for the purpose stated on the permit?
2. Is the building used for the purpose stated on the permit?
3. Is the building used for the purpose stated on the permit?
4. Is the building used for the purpose stated on the permit?
5. Is the building used for the purpose stated on the permit?
6. Is the building used for the purpose stated on the permit?
7. Is the building used for the purpose stated on the permit?
8. Is the building used for the purpose stated on the permit?
9. Is the building used for the purpose stated on the permit?
10. Is the building used for the purpose stated on the permit?
11. Is the building used for the purpose stated on the permit?
12. Is the building used for the purpose stated on the permit?
13. Is the building used for the purpose stated on the permit?
14. Is the building used for the purpose stated on the permit?
15. Is the building used for the purpose stated on the permit?
16. Is the building used for the purpose stated on the permit?
17. Is the building used for the purpose stated on the permit?
18. Is the building used for the purpose stated on the permit?
19. Is the building used for the purpose stated on the permit?
20. Is the building used for the purpose stated on the permit?

INVESTIGATOR'S COPY

December 9, 1954

AP 307 Congress St.—Provision of concrete vault for new fuel oil tank

F. W. Cunningham & Sons
181 State St.
Roman Catholic Bishop of Portland
307 Congress St.

Copies to: The Fels Company
42 Union St.
Portland Copper & Tank Works
80 Second St. S. P.

Gentlemen:

Building permit for construction of vault only is issued herewith, subject to the following conditions. If these conditions are not understood, or you are unable to comply with them, please refrain from starting the work and contact this office with more information to show compliance with Building Code regulations.

1. The installer of connections from new tank to oil burning equipment, the fill pipe and vent pipe is to secure a separate permit from this department before starting that part of the work, and included in that permit will be the design and construction of tank, access tube, etc. Portland Copper & Tank Company are believed to be the designers and manufacturers of the tank and access tube. It is our impression that this Company is entitled to apply the label of Underwriters' Laboratories, Inc., and that this tank will bear that label. If not the applicant for the installation permit should furnish the design plan of tank and access tube bearing upon it the statement of design of the designer.

The use of a metal access shaftway is new to us, and it is assumed that this is proven safe in view of the sparking propensities of metal, especially of a metal ladder.

2. The plan seems to show no means of access to the space between the new tank and the vault except that within the access tube. It is assumed, therefore, that the access shaftway will be made "gas-tight" to prevent exposure of any person passing through it, from being exposed to any toxic fumes which may have accumulated in the considerable space between the tank and walls and top slab of the vault.

3. It appears that the existing tank was encased in sand fill, but presumably such fill is not to be used again. There is no prohibition of it, but the Fire Underwriters report bad experience with sand fill in such cases which tends to corrode the tank.

4. It seems to be the general opinion of Fire Underwriters and the oil people, also, that it is not a good practice to "seal-up" such a tank in a way that no inspection can be made of the outside of it. However, there is no regulation to prevent that. In cases where access is provided to the space between tank and vault, it is considered necessary to provide some adequate means of ventilation of that space, which may give the assurance that any toxic fumes will be exhausted before the person enters this space.

Very truly yours,

Warren McDonald
Inspector of Buildings

WMCD/B

9B + 1A



To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ ~~alter~~ ~~repair~~ ~~demolish~~ install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 307 Congress Street Within Fire Limits? yes Dist. No. 1
 Owner's name and address Cathedral of Immaculate Conception Telephone _____
307 Congress Street
 Lessee's name and address _____ Telephone _____
 Contractor's name and address Marshall Engineering, 116 Middle St. Telephone 3-1524
 Architect _____ Specifications _____ Plans yes No. of sheets _____
 Proposed use of building _____ No. families _____
 Last use _____ No. families _____
 Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____
 Estimated cost \$ _____ Fee \$ 1.00

General Description of New Work

To install 1000 gallon fuel oil tank outside above ground -
 Tank to set on concrete driveway - temporary location until existing tank is repaired.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** Marshall Engineering

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing lumber—Kind _____ Dressed or full size? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

APPROVED

CHIEF OF FIRE DEPT.

Miscellaneous

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Cathedral of Immaculate Conception
 Marshall Engineering Co.

Signature of owner By: W. Marshall

INSPECTION COPY

it No. 54/2036

ion 307 Congress St.

of permit 11/16/54

closing-in

closing-in

Notif.

ispm.

Occupancy issued

Out Notice

heck Notice

11/14/54 - Work done - other

INSPECTION ONLY



Steam

FILL IN COMPLETELY AND SIGN WITH INK

PERMIT 15670
0303

Permit No. MAR 23 1935

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, March 23, 1935

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 307 Congress Street Use of Building Church
Name and address of owner Roman Catholic Bishop of Portland Cathedral Parish, 307 Congress St. Ward 3
Contractor's name and address Easternoil Inc., 135 Marginal Way Telephone 3-6495

General Description of Work

To install One Model A1 Easternoil Oil Burner with two 275 gal. tanks

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel oil
Material of supports of heater or equipment (concrete floor or what kind) concrete
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, _____
from top of smoke pipe _____, from front of heater _____ from sides or back of heater _____

IF OIL BURNER

Name and type of burner Easternoil-gun type Labeled and approved by Underwriters' Laboratories? yes
Will operator be always in attendance? no Type of oil feed (gravity or pressure) Pressure
Location oil storage cellar No. and capacity of tanks two 275 gal. tanks
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? _____

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

EASTERNOIL INC.

Signature of contractor by L. J. McLaughlin

INSPECTION COPY

Ward 3 Permit No. 35/303

Location 307 Congress St

Owner Roman Catholic Bishop

Date of permit 3/23/35

Notif. closing-in 3/23/35

Inspn. closing-in

Final Notif.

Final Inspn. 4/4/35 O.T. C.B.

Cert. of Occupancy issued None.

NOTES

Located in hole, room of central heating plant for heating hot water.

1. Kind of heat Hot Water heater

2. Label

3. Anti-siphon

4. Oil storage

5. Tank distance

6. Vent pipe

7. Fill pipe

8. Gauge

9. Safety

10. Feed safety

11. Fit, clean & material

12. Control valve

13. Pressure

14. Temperature

15. Water

16. Tank

3/27/35. Tanks installed.



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED

Permit No. 1528

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 4, 1934

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 307 Congress St., Portland, ME. Use of Building Church & School

Name and address of owner Catholic Diocese of Maine, Portland, Maine Ward 3

Contractor's name and address Ballard Oil & Equip Co. of Me. Portland, Me Telephone 2-1991

General Description of Work

To install Ray Heavy Fuel Oil Equipment

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel #6 A P L

Material of supports of heater or equipment (concrete floor or what kind) Concrete

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, Concrete Fireproof
from top of smoke pipe _____, from front of heater _____ from sides or back of heater _____

IF OIL BURNER

Name and type of burners 2-Ray #88-141 Automatic Labeled and approved by Underwriters' Laboratories? yes

Will operator be always in attendance? No Type of oil feed (gravity or pressure) Pressure

Location oil storage Basement No. and capacity of tanks (1) App 5000 Gal.

Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? one

Amount of fee enclosed \$1.50 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor

Ballard Oil & Equip Co. of Maine
R. A. T. Barton

INSPECTION COPY

Ward 3 Permit No. 34/1528
 Location 307 Congress St
 Owner Primer Catholic Bishop
 Date of permit 10/5/34
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif. _____
 Final Inspn. 2/20/35 O.T. W.B.
 Cert. of Occupancy issued None

NOTES

1. Kind of heat Steam
2. Label ✓
3. Anti-siphon ✓
4. Oil storage ✓
5. Tank distance ✓
6. Vent pipe ✓
7. Fill pipe ✓
8. Gauge ✓
9. Rigidity ✓
10. Feed safety ✓
11. Pipe sizes & material ✓
12. Control valve ✓
13. Air pit vent ✓
14. Temp. & pressure safety ✓
15. Insurance card ✓
16. _____

2/13/35 Mr. Davidson
said vent pipe outlet
would be turned down

2/13/35 Nothing done
2/20/35 Vent pipe fixed

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

1154
AUG 22 1933
Portland, Maine, August 22, 1933

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 307 Congress Street

Ward 3

Within Fire Limits? yes

Dist. No. 1

Owner's or lessee's name and address Roman Catholic Bishop of Portland

Contractor's name and address F. W. Cunningham & Sons 181 State St.

Telephone

Telephone 4-1893

Architect's name and address

Proposed use of building Rectory

Other buildings on same lot

No. families

Plans filed as part of this application? yes

No. of sheets

1

Estimated cost \$ 1200.00

Fee \$ 3.75

Description of Present Building to be Altered

Material brick No. stories 3 Heat

Style of roof

Roofing

No. families

Last use Rectory

General Description of New Work

To build one story open piazza 14' x 41' on east side of building as per plan submitted

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately, or in the name of the heating contractor.

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED.
CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED.

Details of New Work

Size, front depth

No. stories

Height average grade to top of plate

To be erected on solid or filled land?

Height average grade to highest point of roof

Material of foundation

Thickness, top

earth or rock?

bottom

Material of underpinning

Height

Thickness

Kind of Roof Hip

Rise per foot 4"

Roof covering

Slate shingles

No. of chimneys

Material of chimneys

of lining

Kind of heat

Type of fuel

Is gas fitting involved?

Corner posts

Sills

Girt or ledger board?

Size

Material columns under girders

Size

Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters:

1st floor

2nd

3rd

roof

On centers:

1st floor

2nd

3rd

roof

Maximum span:

1st floor

2nd

3rd

roof

If one story building with masonry walls, thickness of walls?

height?

If a Garage

No. cars now accommodated on same lot

to be accommodated

Total number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street?

no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

By Roman Catholic Bishop of Portland

By F. W. Cunningham & Sons

Signature of owner

INSPECTION COPY

444B

Ward 3 Permit No. 33/1154

Location 307 Congress Street

Owner Roman Catholic Bishop

Date of perm. 8/22/33

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 9/6/33

Cert. of Occupancy issued None

NOTES

8/24/33 - Excavation started. A.G.B.

8/28/33. Floor framed. roof framing started. O.B.

8/30/33. Roof framed. O.B.

9/5/33. Putting on finish slate on roof. A.G.B.



APPLICATION FOR PERMIT

Class of Building or Type of Structure Second class

Permit No. 1000

FEB 20 1921

INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, February 15, 1921

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if submitted herewith and the following specifications:

Location 107 Congress Street Ward 3 Within Fire Limits? yes Dist. No. 1
Owner's or lessee's name and address Roman Catholic Bishop of Portland
Contractor's name and address P. T. Cunningham & Sons, 121 State St. Telephone 5280
Proposed use of building dwellling (Bishop's)
No. of families 1
Is this building on same lot as building already on same lot? yes
Is this building included as part of this application? yes
Estimated cost \$ 200. No. of sheets 1

Description of Present Building to be Altered
No. stories 5 Height 20 ft. Style of roof dwellling (Bishop's) Roofing as is
General Description of New Work
Add various new partitions and cut in doorways in third story
Bathrooms (not including the number of occupants) so as to provide additional
bath rooms is to have an outside window of legal size

That this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of contractor.

Details of New Work
Height average grade to top of plate
Height average grade to highest point of roof
earth or rock?
Thickness, top
bottom
Height
Thickness
Rise per foot
Roof covering
Material of chimneys
Type of fuel
Is gas fitting involved?
Sills
Girt or ledger board?
Size
Max. on centers
Bridging in every floor and flat roof
Rafters: 1st floor, 2nd, 3rd, roof
Sills and carrying partitions) 2x4-16" O.C. Girders 6x8 or larger
Sills and corner posts all one piece in cross section
1st floor, 2nd, 3rd, roof
1st floor, 2nd, 3rd, roof
1st floor, 2nd, 3rd, roof
Bridging with masonry walls, thickness of walls?
height?

If a Garage
Accommodated on same lot
Commercial cars to be accommodated
to be accommodated
Repairs to be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous
Require removal or disturbing of any shade tree on a public street? no
Charge of the above work a person competent to see that the State and City requirements pertaining thereto
By Roman Catholic Bishop of Portland
By P. T. Cunningham & Sons

Signature of owner

Thomas F. Tallma



APPLICATION FOR PERMIT

Class of Building or Type of Structure Second

Portland, Maine, Feb. 11, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 577 Congress Street Ward 3 Within Fire Limits? yes Dist. No. 1

Owner's or Lessee's name and address Roman Catholic Bishop Telephone

Contractor's name and address F. W. Cunningham & Sons, 161 State St. Telephone F 5183

Architect's name and address

Proposed use of building Res. dwelling house No. families 2

Other buildings on same lot

Plans filed as part of this application? no No. of sheets

Estimated cost \$ 1200. Fee \$ 75

Description of Present Building to be Altered

Material brick No. stories 3 Heat Style of roof Roofing

Last use dwelling house No. families 1

General Description of New Work

To partition off bath room and linen closet on third floor

Bath room to be vented thru roof roof by shaft at least six square inches in cross section

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front depth No. stories Height average grade to top of plate

To be erected on solid or filled land? earth or rock? Height average grade to highest point of roof

Material of foundation Thickness, top bottom

Material of underpinning Height Thickness

Kind of Roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining

Kind of heat Type of fuel Is gas fitting involved?

Corner posts Sills Girt or ledger board? Size

Material columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-10" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor 2nd 3rd roof

On centers: 1st floor 2nd 3rd roof

Maximum span: 1st floor 2nd 3rd roof

If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot to be accommodated

Total number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

By Roman Catholic Bishop of Portland
F. W. Cunningham & Sons

By Thomas J. Connolly

Ward 3 Permit No. 31/121

To 307 Congress St.

Owner Roman Catholic Bishop

Date of permit 2/12/31

Notif. closing-in 2/13/31 2. 30 P.M.

Inspu. closing-in 2/13/31-930 A.M.G.

Final Notif.

Final Inspu. 2/20/31

Cert. of Occupancy issued None

NOTES

2/13/31 - Various closet partitions being rearranged & several new doorways being cut in. Several new partitions have been put in to divide old library into suites. Six suites and two single rooms are being provided on third floor. Suites consisting of bedroom and study. Three bath and toilet rooms are being provided, all of which have windows to the outside air. There is only one stairway to this

floor, although access may be had thru a window to the roof of an adjoining two story portion. A.J.C.



(B) LIMITED BUSINESS ZONE

Permit No. 0728

APPLICATION FOR PERMIT PERMIT ISSUED

Class of Building or Type of Structure 2nd.JUN 1 1927
Portland, Maine, June 1 1927

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 307 Congress St. Ward 2 Within Five Limits? yes Dist. No. 1
Owner's or Lessee's name and address Bishop Barry 307 Congress St. Telephone _____
Contractor's name and address J. A. Kilbridge 32 Central St Telephone 7 4381
Architect's name and address _____
Proposed use of building Dwelling House No. families 1
Other buildings on same lot Church

Description of Present Building to be Altered

Material Brick No. stories 2 1/2 Heat _____ Style of roof _____ Roofing _____
Last use Dwelling House No. families 1

General Description of New Work

Replace window with door, and build 1 story open porch (no roof)
8'-0" x 25'-0"

NOTIFICATION BEFORE EXCAVATION
OR CLOSING-IN IS WAIVED.CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED.

Details of New Work

Size, front 8 depth 25 No. stories 1 Height average grade to highest point of roof no roof
To be erected on solid or filled land? solid earth or rock? earth
Material of foundation brick piers Thickness, top 6 Sq. bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof none Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Distance, heater to chimney _____
If oil burner, name and model _____
Capacity and location of oil tanks _____
Is gas fitting involved? _____ Size of service _____
Corner posts _____ Sills 4x5 Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor 2x6 2nd _____ 3rd _____ roof _____
On centers: 1st floor 16 2nd _____ 3rd _____ roof _____
Maximum span: 1st floor 8'-0 2nd _____ 3rd _____ roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Plans filed as part of this application? yes No. sheets 1
Estimated cost: \$ 100 Fee \$.50
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner _____

3655H

Ward 2 Permit No. 27728 H

Location 307 Congren

Owner Bishop Murray

Date of permit June 1/27

☐ Closing-in


Inspn. closing-in

Final Notif.

Final insp. 8/23/27 J.C. Hill

Cert. of Occupancy issued

NOTES





APPLICATION FOR PERMIT TO BUILD

CLASS BUILDING

Portland, Maine, 1919

To the INSPECTOR OF BUILDINGS, PORTLAND, ME:

The undersigned hereby applies for a permit to build, according to the following specifications, the Laws of the State of Maine, and the Building Ordinance of the City of Portland:

Location: 107 Ocean Street Ward: Within Fire Limits? ☒
Owner's name and address? John J. Smith, 107 Ocean Street
Contractor's name and address? John J. Smith, 107 Ocean Street
Architect's name and address? John J. Smith, 107 Ocean Street
Proposed occupancy of building (purpose)? Residence
No. families? 2 apartments? 0 lodgers? 0
Size, front? 24, depth? 12, No. stories? 1, height, average grade to highest point of roof? 10
To be erected on solid or filled land? solid earth or rock? solid
Material of foundation? stone Thickness, top? 12 bottom? 12
Material of underpinning? stone over 4 ft. high? 12 thickness? 12
Kind of roof (pitch, hip, etc.)? pitch Kind of roofing? asph.
Kind of heat? gas Material of chimney? brick, of lining? brick

Size of Framing Members

Corner posts? 6x8 Sills? 6x8 Rafters or roof beams? 6x8 on center? 16
Material and size of columns under girders? 6x8 on center? 16
Ledger board used? 2x4 Size? 16 Studs (outside walls and carrying partitions) 2 x 4 16" O. C.
Girders 6" x 8" or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts will be all one piece in cross section.

Floor timbers: 1st floor 2x10, 2nd 2x10, 3rd 2x10, 4th 2x10
On centers: 1st floor 16, 2nd 16, 3rd 16, 4th 16
Span: 1st floor 16, 2nd 16, 3rd 16, 4th 16

If 1st or 2nd Class Building

External walls } thickness { 1st story 12, 2nd story 12
Party walls } thickness { 1st story 12, 2nd story 12
Material of cornice? brick How fastened? nailed

If Apartment, Tenement or Lodging House

Dimensions of lot? 24x12
Descriptions of other buildings on lot? none
Clear distance to rear lot line? 12, to one side lot line? 12, to other side lot line? 12

If a Private Garage

No. cars now accommodated on lot? none Total number to be accommodated? 1
Other buildings on same lot? none
Distance from nearest present building to proposed garage? 12
All parts of garage, including eaves, will be at least 2 ft. from all lot lines.
Garage will be at least 12 feet from nearest windows of adjoining property.
Will there be a heating plant within building? no
If so, how protected? no

Miscellaneous

Will the above construction require the removal or disturbing of any shade tree on the public street? no
Plans filed as part of this application? yes No. sheets? 1
Estimated total cost \$ 2,000 Fee? 1.00

Signature of owner or authorized representative? John J. Smith

READ!

Portland, Maine, June 16, 1936 19

To the INSPECTOR OF BUILDINGS, PORTLAND, ME

The undersigned hereby applies for a permit to erect the following described building according to the following specifications, the Laws of the State of Maine, and the Building Ordinance of the City of Portland:

Location 107 Thompson Street How Many Ward 5 Within Fire Limits? yes
Owner's name and address? John J. G. Ireland Co., 107 Calvary St
Contractor's name and address? Cum Hogan & Son, 131 State Street
Architect's name and address?
Last use of building? Gallerie No. Families? 1
Proposed use of building? Gallerie No. Families? 1

Description of Present Building

Material brick No. of Stories 3 Style of Roof flat Roofing t. & c.

General Description of New Work

Build brick entrance 9x1 foot and place high with a 4" gable roof

NOTIFICATION
Before
LEAVING OR CLOSING IN
Is
WAIVED

Size of New Framing Members

Corner posts? _____ Sills? _____ Rafters or roof beams? _____ on center? _____
Material and size of _____ under girders? _____ on center? _____
Ledger board used? _____ Size? _____. Studs (outside walls and carrying partitions) 2 x 4 16" O. C.
Girders 6" x 8" or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts will
be all one piece in cross section.

Floor timbers: 1st floor _____, 2nd _____, 3rd _____, 4th _____
On centers: 1st floor _____, 2nd _____, 3rd _____, 4th _____
Span: 1st floor _____, 2nd _____, 3rd _____, 4th _____

If 1st or 2nd Class Construction

External walls } thickness { 1st story 21 in —, 2nd story _____
Party walls } { 1st story _____, 2nd story _____

Other Details New Construction

To be erected on solid or filled land? solid earth or rock? _____
 Material of foundation? brick Thickness, top? 12 bottom? 12
 Material of underpinning? _____ over 4 ft. high? _____ thickness? _____
 Kind of roof (pitch, hip, etc.)? flat Kind of roofing? tar & G
 No. of new chimneys? no Material of chimneys? _____ of lining? _____

If a Private Garage

No. cars now accommodated on lot? _____ Total number to be accommodated? _____
Other Buildings on same lot? _____
Distance from nearest present building to proposed garage? _____
All parts of garage, including eaves, will be at least 2 ft. from all lot lines.
Garage will be at least _____ feet from nearest windows of adjoining property.

Miscellaneous

Will the above construction require the removal or disturbing of any shade tree on the public street? no
Plans filed as part of this application? _____ No. sheets? _____
Estimated total cost \$ 10.00 Fee? 1.00

Signature of owner or authorized representative? _____



City of Portland.

3345

10, 11, 12

6-29-1911.

To the Inspector of Buildings of the City of Portland:

The undersigned respectfully makes application for a permit to erect enlarge a building on Longue street, at number 307 to be 1 stories high 45 feet long, 2 stories high, 29 feet wide; also an addition to be 30 feet long, 28 feet wide, and to be used as a Garage House & Dwelling

The material to be used in the erection enlargement of said building is to be as follows:

Exterior walls to be made of

Roof to be made of

Gutters to be made of

Cornices to be made of

Bay windows to be made of

Dormer windows to be made of

The builder is

The architect is

The owner is

Quik
Tailor
Metal

F. H. Cunningham & Son 435
Longue St.
At Rev. L. J. Walsh Address 307 Longue St.

(Applicant to sign here) F. H. Cunningham & Son

OFFICE OF
INSPECTOR OF BUILDINGS,
FOR THE
CITY OF PORTLAND.
OFFICE HOURS:
10-11 A. M. 4-6 P. M.

The above petition was granted the 29 day of June 1911

301-311 CONGRESS STREET

2

The image displays a high-contrast, black-and-white scan of a document page. The page is characterized by a grid of dark, rectangular frames arranged in three rows. The frames appear to be part of a film strip or a document page, with some frames containing faint, illegible markings. The overall image is heavily degraded with noise and artifacts, including a prominent vertical line running down the center and a horizontal line near the bottom. The frames are separated by thin white lines, and the background is a light, textured gray.

PLUMBING APPLICATION

Department of Human Services
Division of Health Engineering
(207) 288-3428

PROPERTY ADDRESS	
Town Or Plantation	<u>Portland</u>
Street	<u>305</u>
Subdivision Lot #	<u>10</u>
PROPERTY OWNERS NAME	
Last	First
<u>Smith</u>	<u>John</u>
Applicant Name:	
<u>John Smith</u>	
Mailing Address of Owner/Applicant (if different)	
<u>1500 1st St</u>	

PORTLAND		PERMIT #	441	TOWN COPY
Date		5.10.84		FEE
Signature		<u>John Smith</u>		L.P.L. #

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for a Local Plumbing Inspector to deny a Permit.

John Smith Date 5-10-84

Signature of Owner/Applicant

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

May 12 1984

Local Plumbing Inspector Signature

Date Approved

PERMIT INFORMATION		
This Application is for	Type Of Structure To Be Served:	Plumbing To Be Installed By:
	1. ☒ NEW PLUMBING 2. ☐ RELOCATED PLUMBING 3. ☐ SINGLE FAMILY DWELLING 4. ☐ MODULAR OR MOBILE HOME 5. ☐ MULTIPLE FAMILY DWELLING 6. ☐ OTHER - SPECIFY: <u>Church</u>	1. ☐ MASTER PLUMBER 2. ☐ OIL BURNERMAN 3. ☐ MFG'D. HOUSING DEALER/MECHANIC 4. ☐ PUBLIC UTILITY EMPLOYEE 5. ☐ PROPERTY OWNER LICENSE # <u>11554</u>

Number	Hook-Ups And Piping Relocation	Number	Column 2 Type Of Fixture	Number	Column 1 Type Of Fixture
	HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.		Hosebibb / Silcock		Bathtub (and Shower)
			Floor Drain		Shower (Separate)
			Unial		Sink
	HOOK-UP: to an existing subsurface wastewater disposal system.		Drinking Fountain		Wash Basin
			Indirect Waste		Water Closet (Toilet)
			Water Treatment, Softener, Filter, etc.		Clothes Washer
	PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.		Grease Oil Separator		Dish Washer
			Dental Cuspidor		Garbage D'sposal
			Bidet		Laundry Tub
	Hook-Ups (Subtotal)		Other	2	Water Heater
\$	Hook-Up Fee		Fixtures (Subtotal) Column 2	2	Fixtures (Subtotal) Column 1
SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE				2	Fixtures (Subtotal) Column 2
				2	Total Fixtures
				\$ 6	Fixture Fee
				\$	Hook-Up Fee
				\$ 6	Permit Fee (Total)

TOWN COPY

Subdivision Lot # 2.4 **PORTLAND** **PERMIT # 527** **TOWN COPY**

PROPERTY OWNERS NAME

Last: First

Applicant Name: Paul R. Gaudin

Mailing Address of Owner/Applicant (if different):

Date: 6.29.84 \$ 100.00 FEE Charged

L.P.L. #

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant: Paul R. Gaudin Date:

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumber's Inspector Signature: Paul R. Gaudin Date Approved: JUL 2 - 1984

PERMIT INFORMATION

This Application is for:

1. ☐ NEW PLUMBING

2. ☐ RELOCATED PLUMBING

Type Of Structure To Be Served:

1. ☐ SINGLE FAMILY DWELLING

2. ☐ MODULAR OR MOBILE HOME

3. ☐ MULTIPLE FAMILY DWELLING

4. ☐ OTHER - SPECIFY:

Plumbing To Be Installed By:

1. ☐ MASTER PLUMBER

2. ☐ OIL BURNERMAN


3. ☐ MFG D. HOUSING DEALER MECHANIC

4. ☐ PUBLIC UTILITY EMPLOYEE

5. ☐ PROPERTY OWNER

LICENSE # 11111


Number	Hook-Ups And Piping Relocation	Number	Column 2 Type Of Fixture	Number	Column 1 Type Of Fixture
	HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.		Hosebibb / Silcock		Bath (and Shower)
			Floor Drain		Shower (Separate)
			Urinal		Sink
	HOOK-UP: to an existing subsurface wastewater disposal system.		Drinking Fountain		Wash Basin
			Indirect Waste		Water Closet (Toilet)
			Water Treatment Softener, Filter, etc.		Clothes Washer
	PIPING RELOCATION: of sanitary line, drains, and piping without new fixtures.		Grease Oil Separator		Dish Washer
			Dental Cuspidor		Garbage Disposal
			Bidet		Laundry Tub
	Hook-Ups (Subtotal)		Other: <u></u>		Water Heater
\$	Hook-Up Fee		Fixtures (Subtotal) Column 2		Fixtures (Subtotal) Column 1
SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE					Fixtures (Subtotal) Column 2
					Total Fixtures
			\$		Fixture Fee
			\$		Hook-Up Fee
				\$	Permit Fee (Total)



Height approx 20'

capping section removed to be
replaced with a steel chase with a
copper flashing on top,

307 Congress St.



APPLICATION FOR PERMIT

955

CITY OF PORTLAND

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION

PORTLAND, MAINE Aug. 8, 1984

AUG 8 1984

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 307 Congress Street

Fire District #1 ☐ #2 ☐

1. Owner's name and address Cathedral of the Immaculate Conception - same Telephone 773-7746

2. Lessee's name and address Telephone

3. Contractor's name and address Ducharme Bros. Inc., 37 Academy St., Auburn, Maine Telephone 782-6153
Mason Cont.

Proposed use of building church - repair chimney No. of sheets

Last use No. families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 25,000

FIELD INSPECTOR - Mr.

@ 775-5451

Appeal Fees \$

Base Fee

Late fee

TOTAL \$ 135.00

To repair chimney, as per plan.

Stamp of Special Conditions

ISSUE PERMIT TO #3

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work?

Is any electrical work involved in this work?

Is connection to be made to public sewer?

If not, what is proposed for sewage?

Has septic tank notice been sent?

Form notice sent?

Height average grade to top of plate

Height average grade to highest point of roof

Size, front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining Kind of heat fuel

Framing Lumber - Kind Dressed or full size? Corner posts Sills

Size Girder Columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters 1st floor 2nd 3rd roof

On centers 1st floor 2nd 3rd roof

Maximum span 1st floor 2nd 3rd roof

If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:

DATE

MISCELLANEOUS

BUILDING INSPECTION - PLAN EXAMINER

Will work require disturbing of any tree on a public street? N/A

ZONING

BUILDING CODE

Fire Dept.

Health Dept.

Others

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of Applicant Marcel Ducharme Phone #

Type Name of above Marcel Ducharme for Ducharme Bros. ☐ 1 ☐ 2 ☒ 3 ☐ 4Other
and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY

ma. add to

NOTES

8-9-84. Work in progress
 OK. Common, headin
 board being used. WIP/OK. da
 8-20-84. Chimneys complete
 and capped off. OK. da
 8-25-84. All work
 complete. OK. da

Allocation

Garage

Dwelling

Approved

Date to permit

Permit No.

Location

307 Congress St

8/15/84

8/18/84

Chambers

955/84

307 Congress St

8/15/84

8/18/84

Chambers

955/84


307 Congress St

8/15/84

8/18/84

Chambers


Perchance Bros Inc. = Contractor
Immaculate Conception Church = job



Height approx 20'

copping section removed to be
replaced with a straight chase with a
copper flashing on top,

307 Congress St.



To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 307 Congress Street Fire District #1 ☐ #2 ☐

1. Owner's name and address Cathedral of the Immaculate Conception - same Telephone 773-7746...

2. Lessee's name and address Telephone

3. Contractor's name and address Ducharme Bros., Inc., 37 Academy St., Auburn, Maine 782-6153
Mason Cont. No. of sheets

Proposed use of building church - repair chimney No. families

Last use No. families

Material No. stories Heat Style of roof Roofing

Other buildings on same lot

Estimated contractual cost \$ 25,000 Appeal Fees \$

FIELD INSPECTOR—Mr. Base Fee

@ 775-5451 Late Fee

To repair chimney, as per plan.

TOTAL \$ 135.00

Stamp of Special Conditions

ISSUE PERMIT TO #3

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?

Is connection to be made to public sewer? If not, what is proposed for sewage?

Has septic tank notice been sent? Form notice sent?

Height average grade to top of plate Height average grade to highest point of roof

Size, front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cellar

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimneys of lining Kind of heat fuel

Framing Lumber—Kind Dressed or full size? Corner posts Sills

Size Girder Columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2nd 3rd roof

On centers: 1st floor 2nd 3rd roof

Maximum span: 1st floor 2nd 3rd roof

If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street? N/A

ZONING: Will there be in charge of the above work a person competent

BUILDING CODE: to see that the State and City requirements pertaining thereto

Fire Dept.: are observed? ... yes ..

Health Dept.:

Others:

Signature of Applicant Marcel Ducharme Phone #

Type Name of above Marcel Ducharme for Ducharme Bros. 1 ☐ 2 ☐ 3 ☒ 4 ☐

Other

and Address

FIELD INSPECTOR'S COPY

APPLICANT'S COPY

OFFICE FILE COPY

12 MAR 1985

8-9-84 Work in progress
OK. Common, header
base - using mach. WIP/OK. aa
8-20-84 Timmings complete
and capped off OK. aa
8-26-84 All work
complete OK. aa

ation *Chimney*

ge

illing

oved

of permit

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

8/8/84

(207) 631-25

PROPERTY ADDRESS	
Town Or Plantation	Portland, Maine
Street	307 Congress Street
Subdivision Lot #	
PROPERTY OWNERS NAME	
Cathedral Rectory	
Last:	First:
Applicant Name:	Scribner & Iverson, Inc.
Mailing Address of Owner Applicant (if Different)	P.O. Box 27 Portland, Maine 04112

PORTLAND	PERMIT # 1,431	TOWN COPY
Date Permitted <i>12-2-85</i>	\$	FEE Double Fee Charged
Local Plumbing Inspector Signature <i>Donald O. McQuibben</i>	L.P.I. #	

Owner Applicant Statement
I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Donald O. McQuibben
Signature of Owner Applicant Date *12/2/85*

Caution: Inspection Required
I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules
DEC 3 - 1985
DEC 6 - 1985
Local Plumbing Inspector Signature Date

PERMIT INFORMATION		
This Application is for 1. ☐ NEW PLUMBING 2. ☐ RELOCATED PLUMBING	Type Of Structure To Be Served:	Plumbing To Be Installed By:
	1. ☒ SINGLE FAMILY DWELLING	1. ☒ MASTER PLUMBER
	2. ☐ MODULAR OR MOBILE HOME	2. ☐ OIL BURNERMAN
	3. ☐ MULTIPLE FAMILY DWELLING	3. ☐ MFG D HOUSING DEALER MECHANIC
	4. ☐ OTHER - SPECIFY: _____	4. ☐ PUBLIC UTILITY EMPLOYEE
		5. ☐ PROPERTY OWNER
		LICENSE # <u>0,0,69,4</u>

Number	Hook-Ups And Piping Relocation	Number	Column 2 Type Of Fixture	Number	Column 1 Type Of Fixture
	HOOK-UP to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District		Hosebibb / Sillcock	1	Bathtub (and Shower) replace
			Floor Drain		Shower (Separate)
			Urinal		Sink
	HOOK-UP to an existing subsurface wastewater disposal system		Drinking Fountain	1	Wash Basin replace
			Indirect Waste	1	Water Closet (Toilet) replace
			Water Treatment Softener, Filter, etc		Clothes Washer
	PIPING RELOCATION of sanitary es, drains and piping without new fixtures		Grease/Oil Separator		Dish Washer
			Dental Cuspidor		Garbage Disposal
			Bidet		Laundry Tub
	Hook-Ups (Subtotal)		Other: _____		Water Heater
\$	Hook-Up Fee		Fixtures (Subtotal) Column 2	3	Fixtures (Subtotal) Column 1
SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE				3	Fixtures (Subtotal) Column 2
					Total Fixtures
				\$ 9.00	Fixture Fee
				\$	Hook-Up Fee
				\$ 9.00	Permit Fee (Tip)



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 309 Congress Street

Date of Issue

Issued to Roman Catholic Bishop

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. , has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Church

Entire - no conditions

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

10-23-89

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

PERMIT # 001501 CITY OF Portland BUILDING PERMIT APPLICATION

MAP # LOT #

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: The Roman Catholic Bishop/The Cathedral of Immaculate Conception

Address: 0 Box 6720, Woodford Station, 510 Ocean Ave., Portland 04101

LOCATION OF CONSTRUCTION 309 Congress Street

CONTRACTOR: owner SUBCONTRACTORS: 775-5671, or 773-6471

ADDRESS: Est. Construction Cost: \$400,000 Type of Use: Church

Past Use: Building Dimensions: L W Sq. Ft. # Stories: Lot Size:

Is Proposed Use: Seasonal Condominium Apartment Conversion - Explain Renovating interior - Changing main doorway, changing walls and installing elevator XXX

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE Residential Buildings Only: # Of Dwelling Units # Of New Dwelling Units as per plans.

Foundation: 1. Type of Soil: 2. Set Backs - Front Rear Side(s) 3. Footings Size: 4. Foundation Size: 5. Other

Floor: 1. Sills Size: Sills must be anchored. 2. Girder Size: Size: 3. Lally Column Spacing: Spacing 16" O.C. 4. Joists Size: Size: 5. Bridging Type: Size: 6. Floor Sheathing Type: Size: 7. Other Material:

Exterior Walls: 1. Studding Size Spacing 2. No. windows 3. No. Doors Span(s) 4. Header Sizes 5. Bracing: Yes No 6. Corner Posts Size Size 7. Insulation Type Size 8. Sheathing Type Size 9. Siding Type Weather Exposure 10. Masonry Materials 11. Metal Materials

Interior Walls: 1. Studding Size Spacing 2. Header Sizes Span(s) 3. Wall Covering Type 4. Fire Wall if required 5. Other Materials

For Official Use Only

Date: December 16, 1988 Subdivision: Yes / No

Name: Lot: Block: Permit Expiration: Ownership: Public Private

Inside Fire Limits: Bldg Code: Time Limit: Estimated Cost: \$400,000 Value Structure: Fee \$2,020

Ceiling: 1. Ceiling Joists Size: 2. Ceiling Strapping Size Spacing PERMIT ISSUED 3. Type Ceilings: Size JAN 4 1989 4. Insulation Type 5. Ceiling Height:

Roof: 1. Truss or Rafter Size Span City of Portland 2. Sheathing Type 3. Roof Covering Type 4. Other

Chimneys: Type: Number of Fire Places

Heating: Type of Heat:

Electrical: Service Entrance Size: Smoke Detector Required Yes No

Plumbing: 1. Approval of soil test if required Yes No 2. No. of Tubs or Showers 3. No. of Flushes 4. No. of Lavatories 00,200 5. No. of Other Fixtures

Swimming Pools: 1. Type: Square Footage 2. Pool Size: 3. Must conform to National Electrical Code and State Law.

Zoning: District R-6 Street Frontage Req. Provided Side Side Required Setbacks: Front Back

Review Required: Zoning Board Approval: Yes No Date: Planning Board Approval: Yes No Date: Conditional Use: Variance Site Plan Subdivision Shore and Floodplain Mgmt. Special Exception Other (Explain) Date Approved

Permit Received By Nancy Grossman

Signature of Applicant Date 12/16/88

Signature of CEO Date 1-3-89

Inspection Dates

White-Tax Assesor

Yellow-GPCOG

White Tag-CEO

Copyright GPCOG 1987

PERMIT ISSUED WITH LETTER

PERMIT ISSUED WITH LETTER

PLOT PLAN

N



FEES (Breakdown From Front)
 Base Fee \$ 25.00
 Subdivision Fee \$
 Site Plan Review Fee \$
 Other Fees \$ 1995.00
 (Explain)
 Late Fee \$

Type	Inspection Record	Date

COMMENTS 1-20-89 - Frame work in progress. Other phases
 1 work in progress OK. OK
 4-18-89 - W.P/O.K. Frame, petalines, general work
 OK. OK
 6-9-89 - W.P/O.K interior - exterior. OK. OK
 7-18-89 - Cosmetics in progress. OK. OK
 9-15-89 - OK
 10-23-89 - Final OK for C of E.

Signature of Applicant Frank Morrison Agent Owner Date 12/16/88



CITY OF PORTLAND, MAINE

389 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

January 4, 1989

The Roma Catholic Bishop/The Cathedral of Immaculate Conception
P.O. Box 6720
Woodford Street
Portland, Maine 04101

Re: 309 Congress Street


Dear Sir:

Your application to make alterations as per plans has been reviewed and a permit is herewith issued subject to the following requirements:

A complete automatic fire alarm system including heat, smoke detectors, and manual pullstations to be installed. Alarm activation shall operate magnetic holdbacks on doors. A separate permit for the alarm system must be applied for.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,


P. Samuel Hoffses
Chief, Inspection Services

cc: Lt. W. Carroway, P.F.D.

The undersigned hereby applies for a permit to install electrical work in accordance with the provisions of the
Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:
LOCATION OF WORK: Rectory Bldg. 307 Congress St.
OWNER'S NAME: Catholic Diocese ADDRESS: 307 Congress .

	FEES
OUTLETS: Receptacles 100 Switches 40 Plugmold _____ ft. TOTAL 140	13.00
FIXTURES: (number of) Incandescent 100 12 Fluorescent 8 8 (not strip) TOTAL 110	4.00
Strip Fluorescent _____ ft.	13.00
SERVICES: Overhead _____ Underground _____ Temporary _____ TOTAL amperes _____ ..	
METERS: (number of) _____	
MOTORS: (number of) Fractional _____ 1 HP or over _____	
RESIDENTIAL HEATING: Oil or Gas (number of units) _____ Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____ Oil or Gas (by separate units) _____ Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of) Ranges _____ Water Heaters _____ Cook Tops _____ Disposals _____ Wall Ovens _____ Dishwashers _____ Dryers _____ Compactors _____ Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of) Branch Panels 3	3.00
Transformers _____	
Air Conditioners Central Unit _____ Separate Units (windows) _____	
Signs 20 sq. ft. and under _____ Over 20 sq. ft. _____	
Swimming Pools Above Ground _____ In Ground _____	
Fire/Burglar Alarms Residential 1	2.00
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____ over 30 amps _____	
Circus, Fairs, etc. _____	2.00
Alterations to wires X	
Repairs after fire	
Emergency Lights, battery	
Emergency Generators	
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE:	
FOR REMOVAL OF A "STOP ORDER" (SA-16.b)	
TOTAL AMOUNT DUE:	24.00

INSPECTION:

Will be ready on 2/3/89, 19; or Will Call _____

CONTRACTOR'S NAME: E. S. Boulos Co.

ADDRESS: 40 Circus Time . So. Portland, Maine 04106

TEL.: 772-3706

MASTER LICENSE NO.: 3374

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

E. S. Boulos