SimplexGrinnell
BE SAFE.

20 Thomas I
WESTBROC
(207) 842 64
FAX: (207) 8
www.simple:

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

SimplexGrinnell Material List (THIS IS NOT A PRICE QUOTATIC Date: 07/15/13

TO:
Somma Electric
16 Marie St
GRAY, ME 04039-9755
Attn: Joseph Somma
(207) 632-3485 EXT(____) Fax:

Project: Cathedral Residence 4010es
Customer Reference:
SimplexGrinnell Reference: 966801201
Date: 10/02/2012
Page 1 of 2

QUANTITY	MODEL NUMBER	DESCRIPTION
	Cathedral Residence 4010es	
	Cathedral Residence 4010es	
1	4010-9402	4010ES FACP 120V PLATINUM
1	4010-9912	SERIAL DACT
2	2081-9274	BATTERY 10AH
1	SSU00672	CAB DOC STORAGE 12X13X2D RED
5	4099-9003	MANUAL STATION - DOUBLE ACTION
19	4098-9714	PHOTO SENSOR
27	4098-9792	SENSOR BASE
8	4098-9733	HEAT SENSOR
5	4906-9127	HORN/STROBE MC RED
1	ETHEDROP	ETHERNET-NETWORK COMPATIBLE
	DPSVC	DP SVCS (PERMITS/FEES/BONDS)
	Temporary Use of Zone Card	
1	4010-9920	8 ZONE IDC MODULE CLASS B
	Professional Services - Cathedral Residence 4010es	
	PM LAB	PROJECT/CONSTRUCTION MGMT
	Technical Services - Cathedral Residence 4010es	
	TECH LAB	TECHNICAL SERVICE

Comments

This quote includes the following:

1. A Simplex 4010es Addressable Panel.
2. Addressable replacements for the existing conventional devices.
3. Replacement ADA Compliant Horn-Strobes.
4. A Digital Communicator.
5. Programming and Testing.
6. A Fire Alarm Permit from the Portland Fire Dept.

This quote does not include any additional devices. If additional devices are required it would be at an additional cost.

This quote does not include Monitoring.

This quote is subject to the approval of the Portland Fire Dept.

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions

SimplexGrinnell Material List (THIS IS NOT A PRICE QUOTATIC Date: 07/15/13

Comments (continued)